

Southampton Island Caribou Harvest Spill Contingency Plan – Re: NWB4SOU9800

1.0 Detection

All fuel containers, lines, valves and equipment are visually inspected for leaks, by camp maintenance personnel, daily through the duration of the harvest operation.

2.0 Volumes of Hazardous Materials

The types and volumes of hazardous materials located at the camp include:

- Up to 3,000 liters of gas stored a minimum of 30 meters from the high water mark;
- Up to 24 x 45 gallon drums of diesel 12 of which will be at the camp to fuel tent heaters with the remainder located 30 meters from the high water mark;
- Up to 240 liters of snowmobile oil which is stored 30 meters from the high water mark.

The exact quantities of fuel located at the camp at a given point in time vary in accordance with consumption as a function of the delivery schedule.

3.0 Response Equipment

Two spill kits are maintained at the camp and are located in close proximity to the generator shed. The project manager, the camp maintainer and one additional person are made familiar with their use at the beginning of each harvest season.

4.0 Report, Contain, Clean & Dispose

In the event that a leak is discovered, it is repaired immediately. If a repair can not be quickly effected, the fuel from the leaking container is transferred to empty 45 gallon drums, a quantity of which are located at the camp for contingency purposes.

In the event of a spill, the spill kits are deployed, the spill is contained, cleaned up and disposed of under the supervision of DSD personnel.

5.0 Activation & Notification

This spill contingency plan will be activated when a leak or spill is detected. In the event of a spill, the 24-Hour Spill Line (867) 920-8130 and the DSD in Coral Harbour will be contacted via satellite phone which is located at the camp.