

Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Igaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

Richard Dwver < richard.dwver@nwb-oen.ca> To: Karén Kharatyan <karen.kharatyan@nwb-oen.ca> Tue. Nov 13, 2018 at 12:18 PM

Cc: licensing@nwb-oen.ca. Dave Baines <dave.baines@nwb-oen.ca>

Hi Karén,

Will this require npc/nirb?

Richard



Richard Dwyer- へっとくって コムムマ

Laisaliginigmun

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT Da≫ ALCAP BOLP P- NUNAVUT IMALIRIYIN KATIMAYINGI

P.O. Box 119 Gjoa Haven, NU X0B 1J0

C.P. 119 Gjoa Haven, NU X0B 1J0 MASS SE ASL Day 50 3 , Dage XOB 1JO

Titigaqaqvia 119 Ughiqting, NU, X0B 1J0

Tel / Téléphone / アペトレウ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / アレーザーグ / Fax-kut: (867) 360-6369

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



Africa de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Tue, Nov 13, 2018 at 10:19 AM Karén Kharatyan karen.kharatyan@nwb-oen.ca wrote:

Richard,

This will be assigned to Dave please. Regards,



Karén Kharatyan, Ph. D- bへ bSハケ bSハケ

Director Technical Services - Directeur des services technique → 5000

A⊃4560_56⊃C5d∩oc- Hivuligiti Piluagnagtuligutinut

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT DOSC DLCOSC BOLASC-NUNAVUT IMALIRIYIN KATIMAYINGI

P.O. Box 119 C.P. 119 Gjoa Haven, NU X0B 1J0 Gjoa Haven, NU X0B 1J0

∩∩5 % & % ▶% / %) % , _o_> (X0B 1J0

Tel / Téléphone / プペトトC / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ぱっぱ / Fax-kut: (867) 360-6369 Toll Free / Sans / <\P\\^\C\\^\G\\\\ Akiittuq: 1-855-521-3745

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above, distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete the copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) piece(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre persont la présente avisée qu'il hi est strictement interdit de le diffinser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez infomer l'expédieur par combire électronique immédiatement et détruire ce message et toute copie de cehi-ci. Merci par vivre collaboration.

Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Tue, Nov 13, 2018 at 9:59 AM Marc Losier <marc@mosher.ca> wrote:

Please find attached Application for Amendment of the reference water license.
Regards,
Marc Losier, G.S.C.
Project Manager
Inukshuk Construction Ltd, Mosher Engineering Ltd
Tel: 902-429-0272
Fax: 902-429-7762
From: Dave Baines <dave.baines@nwb-oen.ca></dave.baines@nwb-oen.ca>
Sent: Monday, November 5, 2018 11:45 AM To: Marc Losier <marc@mosher.ca></marc@mosher.ca>
Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>; Dave Mosher <dave@mosher.ca>; site@mosher.ca; licensing@nwb-oen.ca</dave@mosher.ca></jacob_saunders@inukshukconstruction.ca>
Subject: Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment
Mark,
To me it sounds like you need two (2) amendments to your Licence.
 You'd like to amend the expiry date by one (1) year; and You'd like to add an additional source.
Both of these can be addressed by filing an Application for Water Licence Amendment. I have attached the appropriate form to this email.
The board only grants Licence terms in full year multiples, so though your email states you only need a few more months,
we would grant until June 2020. If you are looking at an additional source, please do not apply to remove the other sources so that the Licence retains maximum flexibility. The application will need to go to our Licencing department. I've cc'd them
on this email.
Regards,
Dave

Dave Baines MSc EP

Technical Advisor

Nunavut Water Board

867-360-6338 x29



Dave Baines- C△° <△°

Technical Advisor - Conseiller technique ヘンダ® なっちつこん σっしょ Δbマット Piluagnaghuliginigmun Ikayugti

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT ΔΩΣ ΔLC ΔΣ ΔΛΕΤΑΝΙΝΑVUT IMALIRIYIN KATIMAYINGI

www.nwb-oen.ca

P.O. Box 119 Gjoa Haven, NU X0B 1J0 C.P. 119 Gjoa Haven, NU X0B 1J0

 Titigaqaqvia 119 Uqhuqtuuq, NU, X0B 1J0

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour voire collaboration.



📤 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank vou for thinking of the environment before printing this email

On Mon, Nov 5, 2018 at 7:12 AM Marc Losier <marc@mosher.ca> wrote:

Hi Dave,

Please be advise that have not been able to perform the hydrostatic testing of the new tank this fall due to the late arrival of the sealift.

We just completed the tank and we plan on testing the tank in June 2019. We will not have time to complete the testing by the water license June 7, 2019 expiry date. Therefore, we would like to extend the expiry date by 3 months to ensure we are covered.

Also, by doing the testing in June, there will be a lot of water running beside the tank as shown on the attached print from Google Earth. We are proposing to use that water runoff as an alternate water source to fill the tank.

Please review and comment.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762