

Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

9 messages

Dave Baines <dave.baines@nwb-oen.ca>

Mon, Nov 5, 2018 at 8:44 AM

To: Marc Losier <marc@mosher.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>, Dave Mosher <dave@mosher.ca>, site@mosher.ca, licensing@nwb-oen.ca

Mark,

To me it sounds like you need two (2) amendments to your Licence.

- You'd like to amend the expiry date by one (1) year; and
- You'd like to add an additional source.

Both of these can be addressed by filing an Application for Water Licence Amendment. I have attached the appropriate form to this email.

The board only grants Licence terms in full year multiples, so though your email states you only need a few more months, we would grant until June 2020. If you are looking at an additional source, please do not apply to remove the other sources so that the Licence retains maximum flexibility. The application will need to go to our Licencing department. I've cc'd them on this email.

Regards,

Dave

Dave Baines MSc EP
Technical Advisor
Nunavut Water Board
867-360-6338 x29



Dave Baines- $C\Delta^e < \Delta^{a_1}$

Technical Advisor - Conseiller technique ᐱᓕᑦᑐᒃᑐᓂᓄᓐ ᐃᔪᓄᓐ-
Piluagnagtuliginigmun Ikayugti

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᐅᑲᓂᕐ ᐱᓪᓴᐅᓄᓂᕐ ᑲᐅᐳᓄᓂᕐ - NUNAVUT IMALIRIYIN KATIMAYINGI

www.nwb-oen.ca

P.O. Box 119
Gjøa Haven, NU X0B 1J0

C.P. 119
Gjoa Haven, NU X0B 1J0

በገናኙል ልጄ
ገናኙል ልጄ ለገናኙል X013 110

Titigaqavua 119
Uqhuqtina, NU, X013 110

Tel / Téléphone / ᓃᐅᓄᑦᑐᒃ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / hvJ4f5 / Fax-kut: (867) 360-6369
Toll Free / Sans / ᐱᕈᖅᑐᓂᐅᖅ / Akiittug: 1-855-521-3745

WARNING: This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Mon, Nov 5, 2018 at 7:12 AM Marc Losier <marc@mosher.ca> wrote:

Hi Dave,

Please be advise that have not been able to perform the hydrostatic testing of the new tank this fall due to the late arrival of the sealift.

We just completed the tank and we plan on testing the tank in June 2019. We will not have time to complete the testing by the water license June 7, 2019 expiry date. Therefore, we would like to extend the expiry date by 3 months to ensure we are covered.

Also, by doing the testing in June, there will be a lot of water running beside the tank as shown on the attached print from Google Earth. We are proposing to use that water runoff as an alternate water source to fill the tank.

Please review and comment.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762



100401-Application_for_Water_Licence_Amendment-OEDE-edited130401.doc
292K

Marc Losier <marc@mosher.ca>

Tue, Nov 13, 2018 at 9:59 AM

To: Dave Baines <dave.baines@nwb-oen.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>, Dave Mosher <dave@mosher.ca>, site@mosher.ca, licensing@nwb-oen.ca

Hi Dave,

Please find attached Application for Amendment of the reference water license.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762

From: Dave Baines <dave.baines@nwb-oen.ca>

Sent: Monday, November 5, 2018 11:45 AM

To: Marc Losier <marc@mosher.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>; Dave Mosher <dave@mosher.ca>; site@mosher.ca; licensing@nwb-oen.ca

Subject: Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

Mark,

To me it sounds like you need two (2) amendments to your Licence.

- You'd like to amend the expiry date by one (1) year; and
- You'd like to add an additional source.

Both of these can be addressed by filing an Application for Water Licence Amendment. I have attached the appropriate form to this email.

The board only grants Licence terms in full year multiples, so though your email states you only need a few more months, we would grant until June 2020. If you are looking at an additional source, please do not apply to remove the other sources so that the Licence retains maximum flexibility. The application will need to go to our Licencing department. I've cc'd them on this email.

Regards,


Dave

Dave Baines MSc EP

Technical Advisor

Nunavut Water Board

867-360-6338 x29



Tue, Nov 13, 2018 at 10:19 AM

Director Technical Services - Directeur des services technique ལྷ་ཁྱེད་ཀྱི་
 འཕྲོད་ལྷན་པོ་- Hivulioti Piluanaactulicuntut

Titigaaqvia 119
Uqhuqtuuq, NU, X0B 1J0

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(des) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courriel électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.

 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

Subject: Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Mon, Nov 5, 2018 at 7:12 AM Marc Losier <marc@mosher.ca> wrote:

Hi Dave,

Please be advise that have not been able to perform the hydrostatic testing of the new tank this fall due to the late arrival of the sealift.

We just completed the tank and we plan on testing the tank in June 2019. We will not have time to complete the testing by the water license June 7, 2019 expiry date. Therefore, we would like to extend the expiry date by 3 months to ensure we are covered.

Also, by doing the testing in June, there will be a lot of water running beside the tank as shown on the attached print from Google Earth. We are proposing to use that water runoff as an alternate water source to fill the tank.

Please review and comment.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762


Richard Dwyer <richard.dwyer@nwb-oen.ca>
To: Karén Kharatyan <karen.kharatyan@nwb-oen.ca>
Cc: licensing@nwb-oen.ca, Dave Baines <dave.baines@nwb-oen.ca>

Tue, Nov 13, 2018 at 12:18 PM

Hi Karén,

Will this require npc/nirb?

Richard



NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᑭᔪ ᐃᒐᓕᓚᓖᔪ ᑲᓂᒐᓖᓱ- NUNAVUT IMALIRIYIN
KATIMAYINGI

Titigaqavua 119
Uqumqumq, NU, X013 1J0

 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

Richard,
This will be assigned to Dave please.
Regards,



NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᑭᑦ ᐃᑭᑦᓴᑦ ᑲᑎᑭᓴᓴᑦ- NUNAVUT IMALIRIYIN
KATIMAYINGI

Titigaqavua 119
Uqhuqtuuq, NU, X0B 1J0

 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

Tel: 902-429-0272

Fax: 902-429-7762

From: Dave Baines <dave.baines@nwb-oen.ca>

Sent: Monday, November 5, 2018 11:45 AM

To: Marc Losier <marc@mosher.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>; Dave Mosher <dave@mosher.ca>; site@mosher.ca; licensing@nwb-oen.ca

Subject: Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

Mark,

To me it sounds like you need two (2) amendments to your Licence.

- You'd like to amend the expiry date by one (1) year; and
- You'd like to add an additional source.

Both of these can be addressed by filing an Application for Water Licence Amendment. I have attached the appropriate form to this email.

The board only grants Licence terms in full year multiples, so though your email states you only need a few more months, we would grant until June 2020. If you are looking at an additional source, please do not apply to remove the other sources so that the Licence retains maximum flexibility. The application will need to go to our Licencing department. I've cc'd them on this email.

Regards,

Dave

Dave Baines MSc EP

Technical Advisor

Nunavut Water Board

867-360-6338 x29

Tue, Nov 13, 2018 at 12:22 PM

Nevermind it just an extension request.

Richard Dwyer- $\Omega^{\infty} \mathcal{P}^{\infty} \mathcal{C} \rightarrow \mathcal{C}$

Manager of Licensing - Responsable des Permis ᑭᐅᓕᖃᔪ ᓕᐃᙵᓕᓂᓄᖅ Maniyauyuq
Laisaliginimun

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᑭᓪ ᐃᓚᓕᓴᓪᓃᓪ ᑲᓴᓚᓪᓃᓪ - NUNAVUT IMALIRIYIN
KATIMAYINGI

P.O. Box 119
Gjøa Haven, NU X0B 1J0

C.P. 119
Gjoa Haven, NU X0B 1J0

በበና ነፍሱ ልኪ
ፆታ ምጋጃ ፆታ ፆታ X013 110

Titigaqavua 119
Uqhuqtuq, NU, X0B 1J0

Tel / Téléphone / ᐅᓕᓴᓴᑦ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᐱᖃᓴᓴᑦ / Fax-kut: (867) 360-6369
Toll Free / Sans / ᐱᓯᖃᓴᓴᑦ / Akiittuq: 1-855-521-3745

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Tue, Nov 13, 2018 at 12:18 PM Richard Dwyer <richard.dwyer@nwb-oen.ca> wrote:

Hi Karén.

Will this require npc/nirb?

Richard

Richard Dwyer- $\Omega^{\infty} \mathcal{P}^{\infty} \mathcal{D} \Delta \mathcal{P}^{\infty}$

Manager of Licensing - Responsable des Permis ᐃᑭᓕᓴᓴᓂ ᓕᐃᓴᓕᓴᓂ^{6b}]ᓕ Maniyauyuq
Laisaliginiqmun

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᑭᓪ ᐃᓕᓕᓴᓪ ᑲᓕᓴᓴᓪ - NUNAVUT IMALIRIYIN
KATIMAYINGI

P.O. Box 119
Cocoa Haven, NU X0B 1J0

C.P. 119
Gjoa Haven, NU X0B 1J0

በበናዬ ልዩ
ጉዞ ላይ ሲገኝ X013 110

Titigacaqvia 119
Uqhuqtina, NU, X0B 1J0

Tel / Téléphone / ᐅᐱᐅᐱᐅᐱ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᐱᐅᐱᐅᐱᐅᐱ / Fax-kut: (867) 360-6369
Toll Free / Sans / ᐱᐅᐱᐅᐱᐅᐱᐅᐱᐅᐱ / Akiittug: 1-855-521-3745

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Tue, Nov 13, 2018 at 10:19 AM Karén Kharatyan <karen.kharatyan@nwb-oen.ca> wrote:

Richard,
This will be assigned to Dave please.
Regards,



Karén Kharatyan, Ph. D- ᑲᓕᓕᓐ ᑲᑦᑎᓐ

Director Technical Services - Directeur des services technique ᑭᓐᓂᓐᑎᓐ
ᐱᓐᓂᓐᑎᓐ ᑭᓐᓂᓐᑎᓐ ᑭᓐᓂᓐᑎᓐ

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᑭᓐᓂᓐᑎᓐ ᑭᓐᓂᓐᑎᓐ ᑭᓐᓂᓐᑎᓐ - NUNAVUT IMALIRIYIN
KATIMAYINGI

P.O. Box 119
Gjoa Haven, NU X0B 1J0

C.P. 119
Gjoa Haven, NU X0B 1J0

ᑎᓄᓐᓂᓐ ᑕᓄᓐᓂᓐ
ᑭᓐᓂᓐᑎᓐ ᑭᓐᓂᓐᑎᓐ X0B 1J0

Titigaqvia 119
Uqhuqtuuq, NU, X0B 1J0

Tel / Téléphone / ᑭᓐᓂᓐᑎᓐ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᑭᓐᓂᓐᑎᓐ / Fax-kut: (867) 360-6369
Toll Free / Sans / ᑭᓐᓂᓐᑎᓐ / Akiittuq: 1-855-521-3745

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(s) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.

 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Tue, Nov 13, 2018 at 9:59 AM Marc Losier <marc@mosher.ca> wrote:

Hi Dave,

Please find attached Application for Amendment of the reference water license.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762

From: Dave Baines <dave.baines@nwb-oen.ca>

Sent: Monday, November 5, 2018 11:45 AM

To: Marc Losier <marc@mosher.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>; Dave Mosher <dave@mosher.ca>; site@mosher.ca; licensing@nwb-oen.ca

Subject: Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

Mark,

To me it sounds like you need two (2) amendments to your Licence.

- You'd like to amend the expiry date by one (1) year; and
- You'd like to add an additional source.

Both of these can be addressed by filing an Application for Water Licence Amendment. I have attached the appropriate form to this email.

The board only grants Licence terms in full year multiples, so though your email states you only need a few more months, we would grant until June 2020. If you are looking at an additional source, please do not apply to remove the other sources so that the Licence retains maximum flexibility. The application will need to go to our Licencing department. I've cc'd them on this email.

Regards,

Dave

Dave Baines MSc EP

Technical Advisor

Nunavut Water Board

867-360-6338 x29



Dave Baines- ᑕᐃᑦ ᑕᐃᑦᐅᐅ

Technical Advisor - Conseiller technique ᐱᐃᐅᑦᐅᐅᑕᑦᐅᐅᑦᐅᑦ ᐃᑕᑦᐅᐅ-
Piluaghaqtuliginimun Ikavutqi

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᐅᐅᑦᐅᑦ ᐃᑕᑦᐅᐅᑦ ᑕᐅᑕᐅᐅᐅᐅ - NUNAVUT IMALIRIYIN KATIMAYINGI

www.nwb-oen.ca

P.O. Box 119
Gjoa Haven, NU X0B 1J0

C.P. 119
Gjoa Haven, NU X0B 1J0

ᑕᑕᑦᐅᑦ ᐅᐅᑦ
ᐅᐅᑦᐅᑦᐅᑦᐅᑦᐅᑦ X0B 1J0

Titigagaqvia 119
Uqhuqhuq, NU, X0B 1J0

Tel / Téléphone / y?/s]b / Hivayaut: (867) 360-6338 | Fax / Télécopieur / hvJ4I3 / Fax-kut: (867) 360-6369
Toll Free / Sans / ᐅᐅᑦᐅᑦᐅᑦᐅᑦᐅᑦ / Akiittuq: 1-855-521-3745

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Mon, Nov 5, 2018 at 7:12 AM Marc Losier <marc@mosher.ca> wrote:

Hi Dave,

Please be advise that have not been able to perform the hydrostatic testing of the new tank this fall due to the late arrival of the sealift.

We just completed the tank and we plan on testing the tank in June 2019. We will not have time to complete the testing by the water license June 7, 2019 expiry date. Therefore, we would like to extend the expiry date by 3 months to ensure we are covered.

Also, by doing the testing in June, there will be a lot of water running beside the tank as shown on the attached print from Google Earth. We are proposing to use that water runoff as an alternate water source to fill the tank.

Please review and comment.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762

Dave Baines <dave.baines@nwb-oen.ca>

Fri, Nov 16, 2018 at 9:51 AM

To: Marc Losier <marc@mosher.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>, Dave Mosher <dave@mosher.ca>, site@mosher.ca, licensing@nwb-oen.ca

Marc,

Thanks for getting this application to the NWB to extend your licence to 2020, add a new source, and add a new disposal plan.

In Section 8 of the Application that you provided, you have indicated that this amendment does not change the original NIRB screening determination. However, you have not provided written confirmation from NIRB confirming that a screening is not required. The NWB cannot proceed with reviewing your application until such time as you have confirmation from NIRB that this change has been screened or that the existing screening remains valid for the new scope.

Once the NWB can proceed further with the review of your Application, we will be interested in gaining a better understanding on the volume of snow melt available, how it typically ponds, where it usually goes and any impacts and planned mitigation for release of that water to the original source.

Dave

Dave Baines MSc EP
Technical Advisor
Nunavut Water Board
867-360-6338 x29

On Tue, Nov 13, 2018 at 9:59 AM Marc Losier <marc@mosher.ca> wrote:

Hi Dave,

Please find attached Application for Amendment of the reference water license.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762

From: Dave Baines <dave.baines@nwb-oen.ca>

Sent: Monday, November 5, 2018 11:45 AM

To: Marc Losier <marc@mosher.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>; Dave Mosher <dave@mosher.ca>; site@mosher.ca; licensing@nwb-oen.ca

Subject: Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

Mark,

To me it sounds like you need two (2) amendments to your Licence.

- You'd like to amend the expiry date by one (1) year; and
- You'd like to add an additional source.

Both of these can be addressed by filing an Application for Water Licence Amendment. I have attached the appropriate form to this email.

The board only grants Licence terms in full year multiples, so though your email states you only need a few more months, we would grant until June 2020. If you are looking at an additional source, please do not apply to remove the other sources so that the Licence retains maximum flexibility. The application will need to go to our Licencing department. I've cc'd them on this email.

Regards,

Dave

Dave Baines MSc EP

Technical Advisor
Nunavut Water Board
867-360-6338 x29

On Mon, Nov 5, 2018 at 7:12 AM Marc Losier <marc@mosher.ca> wrote:

Hi Dave,

Please be advise that have not been able to perform the hydrostatic testing of the new tank this fall due to the late arrival of the sealift.

We just completed the tank and we plan on testing the tank in June 2019. We will not have time to complete the testing by the water license June 7, 2019 expiry date. Therefore, we would like to extend the expiry date by 3 months to ensure we are covered.

Also, by doing the testing in June, there will be a lot of water running beside the tank as shown on the attached print from Google Earth. We are proposing to use that water runoff as an alternate water source to fill the tank.

Please review and comment.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762

Marc Losier <marc@mosher.ca>

Fri, Nov 16, 2018 at 10:55 AM

To: Dave Baines <dave.baines@nwb-oen.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>, Dave Mosher <dave@mosher.ca>, site@mosher.ca,
licensing@nwb-oen.ca

Hi Dave,

Thanks for your reply. I will check with NIRB and get back to you.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762

From: Dave Baines <dave.baines@nwb-oen.ca>

Sent: Friday, November 16, 2018 12:51 PM

To: Marc Losier <marc@mosher.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>; Dave Mosher <dave@mosher.ca>; site@mosher.ca; licensing@nwb-oen.ca

Subject: Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

Marc,

Thanks for getting this application to the NWB to extend your licence to 2020, add a new source, and add a new disposal plan.

In Section 8 of the Application that you provided, you have indicated that this amendment does not change the original NIRB screening determination. However, you have not provided written confirmation from NIRB confirming that a screening is not required. The NWB cannot proceed with reviewing your application until such time as you have confirmation from NIRB that this change has been screened or that the existing screening remains valid for the new scope.

Once the NWB can proceed further with the review of your Application, we will be interested in gaining a better understanding on the volume of snow melt available, how it typically ponds, where it usually goes and any impacts and planned mitigation for release of that water to the original source.

Dave

Dave Baines MSc EP

Technical Advisor

Nunavut Water Board

On Tue, Nov 13, 2018 at 9:59 AM Marc Losier <marc@mosher.ca> wrote:

Hi Dave,

Please find attached Application for Amendment of the reference water license.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762

From: Dave Baines <dave.baines@nwb-oen.ca>

Sent: Monday, November 5, 2018 11:45 AM

To: Marc Losier <marc@mosher.ca>

Cc: Jacob Saunders <jacob_saunders@inukshukconstruction.ca>; Dave Mosher <dave@mosher.ca>; site@mosher.ca; licensing@nwb-oen.ca

Subject: Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

Mark,

To me it sounds like you need two (2) amendments to your Licence.

- You'd like to amend the expiry date by one (1) year; and
- You'd like to add an additional source.

Both of these can be addressed by filing an Application for Water Licence Amendment. I have attached the appropriate form to this email.

The board only grants Licence terms in full year multiples, so though your email states you only need a few more months, we would grant until June 2020. If you are looking at an additional source, please do not apply to remove the other sources so

that the Licence retains maximum flexibility. The application will need to go to our Licencing department. I've cc'd them on this email.

Regards,

Dave

Dave Baines MSc EP
Technical Advisor
Nunavut Water Board
867-360-6338 x29

On Mon, Nov 5, 2018 at 7:12 AM Marc Losier <marc@mosher.ca> wrote:

Hi Dave,

Please be advise that have not been able to perform the hydrostatic testing of the new tank this fall due to the late arrival of the sealift.

We just completed the tank and we plan on testing the tank in June 2019. We will not have time to complete the testing by the water license June 7, 2019 expiry date. Therefore, we would like to extend the expiry date by 3 months to ensure we are covered.

Also, by doing the testing in June, there will be a lot of water running beside the tank as shown on the attached print from Google Earth. We are proposing to use that water runoff as an alternate water source to fill the tank.

Please review and comment.

Regards,

Marc Losier, G.S.C.
Project Manager
Inukshuk Construction Ltd, Mosher Engineering Ltd
Tel: 902-429-0272

Tue, Apr 9, 2019 at 3:04 PM

As

1BH



NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᑭᓪ ᐃᓚᓕᓂᓐᑦ ᑲᓂᓚᓐᑦ - NUNAVUT IMALIRIYIN
KATIMAYINGI

Uqimutit, NU, X0B 1J0

 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

Dave Baines MSc EP
Technical Advisor
Nunavut Water Board
867-360-6338 x29

Tue, Apr 9, 2019 at 3:07 PM

Yes, would be good.



Assol Kubeisinova- ᐱᕐᕈᓴᑦ ᐃᐱᐅᓯᐅᑦ

Technical Advisor - Conseiller technique ᐱᓕᑦᑐᒃᑐᓂᓄᓐ ᐃᔭᑦᐅᓂᓐ
Piluagnaqtuliginigmun Ikavugti

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᑭᔪ ᐃᒪᕐᕋᑦ ᑲᑎᒪᑭᑦ - NUNAVUT IMALIRIYIN KATIMAYINGI

www.nwb-oen.ca

P.O. Box 119
Gjøa Haven, NU X0B 1J0

C.P. 119
Gjoa Haven, NU X0B 1J0

በጥናቱ ልዩ
ጥናታዊ ዓላማ X013 110

Titigaqavua 119
Uqhuqtuq, NU, X013 110

Tel / Téléphone / y?/s]b / Hivayauta: (867) 360-6338 Fax / Télécopieur / hvJ4I3 / Fax-kut: (867) 360-6369
Toll Free / Sans / <P^b^P^b / Akiittuq: 1-855-521-3745

WARNING: This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

On Tue, Apr 9, 2019 at 3:05 PM Richard Dwyer <richard.dwyer@nwb-oen.ca> wrote:
1BH-IBF e-mail chain maybe I oughtta save it eh?

Richard Dwyer- $\mathcal{L}^{\mathcal{C}}\mathcal{J}^{\mathcal{G}} \supset \triangleleft \Delta \mathcal{L}^{\mathcal{G}}$

Manager of Licensing - Responsable des Permis ᐃᑭᓕᓴᓂᓪ ᓕᐃᙵᓕᓱᓂ^{a,b}]ᓕ Maniyauyuq
Laisalginiqmun

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᑭᓪ ᐃᓚᓕᓴᓪᓃᓪ ᑲᑎᓚᓪᓴᑦ - NUNAVUT IMALIRIYIN
KATIMAYINGI

P.O. Box 119
Gloa Haven, NU X0B 1J0

C.P. 119
Gjoa Haven, NU X0B 1J0

በገናኙል ልጄ
ገናኙል ገናኙል ገናኙል X013 110

Titigacaqvia 119
Uqumutma, NU, X0B 1J0

Tel / Téléphone / ᐱᐱᐱᐱᐱ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᐱᐱᐱᐱᐱ / Fax-kut: (867) 360-6369
Toll Free / Sans / ᐱᐱᐱᐱᐱᐱᐱᐱ / Akiittug: 1-855-521-3745

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

----- Forwarded message -----

From: **Dave Baines** <dave.baines@nwb-oen.ca>

Date: Mon, Nov 5, 2018 at 8:45 AM

Date: Mon, Nov 3, 2014 at 6:45 AM
Subject: Re: NWB New Water Licence No. 1BH-IBF1819, 303 - QEC Iqaluit Bulk Fuel Storage Farm Upgrade Project, Inukshuk Construction Ltd - Request for Amendment

To: Marc Losier <marc@mosher.ca>

We just completed the tank and we plan on testing the tank in June 2019. We will not have time to complete the testing by the water license June 7, 2019 expiry date. Therefore, we would like to extend the expiry date by 3 months to ensure we

are covered.

Also, by doing the testing in June, there will be a lot of water running beside the tank as shown on the attached print from Google Earth. We are proposing to use that water runoff as an alternate water source to fill the tank.

Please review and comment.

Regards,

Marc Losier, G.S.C.

Project Manager

Inukshuk Construction Ltd, Mosher Engineering Ltd

Tel: 902-429-0272

Fax: 902-429-7762