

Water Resources Division Nunavut Regional Office Iqaluit, NU X0A 0H0

Feb 1, 2010

Richard Dwyer License Administrator P.O. Box 119 Gjoa Haven, NU X0A 0H0

## Re: Rankin Inlet Fuel Storage Facility Upgrade and Expansion Addendum E2 - Hamlet of Rankin Inlet

NWB File: 1BH-RFS0910

CIDMS #: 387790

Please be advised that Indian and Northern Affairs Canada (INAC) have completed a review of the fuel storage facility upgrade and expansion addendum e2 at Rankin Inlet 1BH-RFS0910 – Hamlet of Rankin Inlet. The NWB circulated the addendum E2 for information purposes only on January 8, 2010. All documents related to the addendum posted on the NWB ftp site under 1BH-RFS were included in my review.

Should you have any questions or comments, please do not hesitate to contact me at (867) 979-4282 or by email at <a href="mailto:lan.Parsons@inac.gc.ca">lan.Parsons@inac.gc.ca</a>.

Sincerely,

Original signed by

lan Parsons Water Resources Technician

Cc. Lou-Ann Cornacchio, Manager of Water Resources – Indian and Northern Affairs Canada, Nunavut Regional Office





## **Technical Review Memorandum**

To: Richard Dwyer – License Administrator, NWB

Marc Losier – Project Manager, Mosher Engineering Limited

From: Ian Parsons – Water Resources Technician, Indian & Northern Affairs Canada.

Re: 1BH-RFS0910 – Rankin Inlet Fuel Storage Facility Upgrade and Expansion Addendum E2 - Hamlet of Rankin Inlet

## **Background**

The Rankin Inlet Fuel Storage Upgrade and Expansion Addendum E2 is a requirement under Part E Item 2 of the water license 1BH-RFS0910. This Addendum is in reference to Mosher Engineering's Hydrostatic Testing Procedures that were approved with the water license application.

## **Recommendations/Comments**

1) The Addendum did not address Item "a" Under Part E #2 of the water license. This Item requires clarification of the "reference to fresh water and Repulse Bay" in Item #6 of the Original hydrostatic Testing procedures.

This remains outstanding and it is recommended that it be addressed before the Addendum for Hydrostatic Testing is accepted for water license # 1BH-RFS0910.

Cc. Lou-Ann Cornacchio, Manager of Water Resources – Indian and Northern Affairs Canada, Nunavut Regional Office Peter Kusugak, District Manager – Indian and Northern Affairs Canada, Nunavut Regional Office

