



P.O. Box 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓂᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File No.: 1BH-RFS0910/TR/H1

February 15, 2010

Marc Losier, G.S.C
Project Manager
Mosher Engineering Limited/ Inukshuk Construction Limited
1869 Upper Water Street, Anchorage House Suite AH202
Halifax, NS B3J 1S9
Email: marc@mosher.ca

RE: Spill Contingency Plan Approval for Licence 1BH-RFS0910 Part H Item 1, Type “B”

Dear Mr. Losier:

The Nunavut Water Board (“NWB”) received on January 12, 2010, the updated Plan entitled “Spill Contingency Plan, Fuel Facility Upgrade Project, Rankin Inlet.” On Jan 12, 2010, the NWB acknowledged receipt of the Plan and distributed it for a public-review period with a comment deadline of February 12, 2010. In addition to comments received in the original application review, submissions were received from Indian and Northern Affairs Canada and Environment Canada. Following a review of the plan and submissions, the document does not fulfill the requirements of Part H, Item 1, of the Licence which states:

“The Licensee shall submit within thirty (30) days of issuance of the Licence, a Spill Contingency Plan, in the format set out by the Consolidation of Spill Contingency Planning and Reporting Regulations R-068-93 that addresses comments received by interested parties.”

The NWB reminds the Licensee that a complete Spill Contingency Plan that addresses comments received was required by December 21, 2009. The Licensee is requested to submit a revised plan that addresses or includes the following prior to a Board Decision on the Plan:

1. Include the date the plan was prepared and the effective period of the plan;
2. Include the tank farm location in GPS coordinates;
3. Include a complete fuel/hazardous material inventory that is consistent with the application and hydrostatic testing procedures;
4. Include the 24-hr Spill Report Line and INAC’s Manager of Field Operations contact number within the reporting section of the plan--(867)-920-8130 and (867)-975-4295 respectively);

5. Include step-by-step clean up instructions for the most likely spill scenarios on land, into water and on ice/snow;
6. Include disposal information for any contaminated soils and materials including relevant transporting procedures and obtaining permission for the use of local land farm facilities;
7. Include precise location of spill kits within the bermed area and a detailed inventory of the content of each spill kit;
8. Include information on training;
9. Include contact information for:
 - a. Environment Canada-867-975-46444
 - b. GN-Department of Environment-867-975-7700
 - c. Hamlet of Rankin Inlet
 - d. Kivalliq Inuit Association
10. Include a section on preventative measures in place;
11. Include a section on hazardous water/sludge collections, storage and removal; and
12. A more detailed description of the site along with the site's history is recommended.

Should you have any questions, please feel free to contact the undersigned at 867-360-6338 ext 25 or by email at sjoseph@nunavutwaterboard.org.

Yours truly,

Original Signed By:

Sean Joseph
Technical Advisor

cc: Distribution List – Kivalliq
Wayne Thistle – CGS