



NWB Tools

Robin Ikkutisluk <robin.ikkutisluk@nwb-oen.ca>

[Licensing] Licence 1BR-DYE0914 -Renewal/Amendment Application

Van Dyck, Tamara <Tamara.VanDyck@dcc-cdc.gc.ca>

Fri, Mar 6, 2015 at 8:03 AM

To: Sean Joseph <sean.joseph@nwb-oen.ca>

Cc: Licensing Department <licensing@nwb-oen.ca>, "Laura.D'Costa@forces.gc.ca" <Laura.D'Costa@forces.gc.ca>

Good morning Sean,

1. The monitoring program documents do list all of the on-site monitoring wells, at DYE-M there are 22 wells; the list of analytes are also included in the program documents, this information is provided to the NWB. The amount of water taken for sampling purposes from each site will vary between monitoring events; depending on whether the monitoring wells contain enough water for a sample. If each monitoring well has water, the maximum amount of water taken for sampling could be 3.5 litres at each of DYE-M's 22 monitoring well locations. Therefore the maximum amount of water that could be taken from DYE-M for sampling purposes could be 77 litres or 0.077 cu. m.

During a teleconference with David Hohnstein, Brady MacCarl, Andrew Keim, Phyllis Beaulieu, myself and the DND DEW Line Clean Up Project Manager Laura D'Costa, this topic was raised and going forward the volume of water taken during a monitoring event will included the annual report submission cover letter (please see attached email).

2. The final As-built Drawings will be submitted to NWB once they have been finalized, this is expected sometime in June 2015.

Regards,

Tamara

From: Sean Joseph [mailto:sean.joseph@nwb-oen.ca]**Sent:** Thursday, March 05, 2015 5:29 PM**To:** Van Dyck, Tamara**Cc:** Licensing Department**Subject:** Licence 1BR-DYE0914 -Renewal/Amendment Application

[Quoted text hidden]

noname.eml
46K

