

**Defence Construction Canada**

**Spill Contingency Plan**

**Lady Franklin Point DEW Line Site**

---

Prepared by:

**AECOM Canada Ltd.**

2540 Kensington Road NW, Calgary, AB, Canada T2N 3S3  
T 403.270.9200 F 403.270.0399 [www.aecom.com](http://www.aecom.com)

Project Number:

0171-146-01-08

Date:

June 9, 2009

# Statement of Qualifications and Limitations

© 2009 AECOM CANADA LTD. OR CLIENT (IF COPYRIGHT ASSIGNED TO CLIENT). ALL RIGHTS RESERVED. THIS DOCUMENT IS PROTECTED BY COPYRIGHT AND TRADE SECRET LAW AND MAY NOT BE REPRODUCED IN ANY MANNER, EXCEPT BY CLIENT FOR ITS OWN USE, OR WITH THE WRITTEN PERMISSION OF AECOM CANADA LTD. OR CLIENT (IF COPYRIGHT ASSIGNED TO CLIENT).

The attached Report (the "Report") has been prepared by AECOM Canada Ltd. ("Consultant") for the benefit of the client ("Client") in accordance with the agreement between Consultant and Client, including the scope of work detailed therein (the "Agreement").

The information, data, recommendations and conclusions contained in the Report:

- are subject to the budgetary, time, scope, and other constraints and limitations in the Agreement and the qualifications contained in the Report (the "Limitations");
- represent Consultants' professional judgement in light of the Limitations and industry standards for the preparation of similar reports;
- may be based on information provided to Consultant which has not been independently verified;
- have not been updated since the date of issuance of the Report and their accuracy is limited to the time period and circumstances in which they were collected, processed, made or issued;
- must be read as a whole and sections thereof should not be read out of such context;
- were prepared for the specific purposes described in the Report and the Agreement;
- in the case of subsurface, environmental or geotechnical conditions, may be based on limited testing and on the assumption that such conditions are uniform and not variable either geographically or over time.

Unless expressly stated to the contrary in the Report or the Agreement, Consultant:

- shall not be responsible for any events or circumstances that may have occurred since the date on which the Report was prepared or for any inaccuracies contained in information that was provided to Consultant;
- makes no representations whatsoever with respect to the Report or any part thereof, other than that the Report represents Consultant's professional judgement as described above, and is intended only for the specific purpose described in the Report and the Agreement;
- in the case of subsurface, environmental or geotechnical conditions, is not responsible for variability in such conditions geographically or over time.

Except as required by law or otherwise agreed by Consultant and Client, the Report:

- is to be treated as confidential;
- may not be used or relied upon by third parties.

Any use of this Report is subject to this Statement of Qualifications and Limitations. Any damages arising from improper use of the Report or parts thereof shall be borne by the party making such use.

This Statement of Qualifications and Limitations is attached to and forms part of the Report.

THIS DOCUMENTATION IS SUPPLIED TO CLIENT BY CONSULTANT AND CONSTITUTES CONFIDENTIAL TRADE SECRETS, OR COMMERCIAL, FINANCIAL, SCIENTIFIC, OR TECHNICAL INFORMATION. THIS DOCUMENTATION IS SUBMITTED TO CLIENT IN CONFIDENCE. IT HAS SIGNIFICANT ECONOMIC VALUE TO CONSULTANT AND ITS DISCLOSURE, WITHOUT THE EXPRESS CONSENT OF CONSULTANT, COULD REASONABLY BE EXPECTED TO LEAD TO SIGNIFICANT AND UNDUE FINANCIAL AND OTHER HARM TO CONSULTANT, INCLUDING HARM TO CONSULTANT'S COMPETITIVE AND NEGOTIATING POSITIONS, AND UNDUE FINANCIAL GAIN TO ONE OR MORE THIRD PARTIES.

## Distribution List

# OF COPIES	ASSOCIATION / COMPANY NAME	PDF	HARD COPY
1	NUNAVUT WATER BOARD	1	1
1	DEFENCE CONSTRUCTION CANADA	1	

## Revision Log

REVISION #	REVISED BY	DATE	ISSUE / REVISION DESCRIPTION
1	EMS	JANUARY 16, 2009	DRAFT
2	EMS	JUNE 9, 2009	FINAL

# Table of Contents

Statement of Qualifications and Limitations

Distribution List

Revision Log

page

<b>1. Contact Information .....</b>	<b>1</b>
<b>2. Introduction .....</b>	<b>2</b>
2.1 Scope and Purpose .....	2
2.2 Site Information.....	2
2.3 Potential Safety Hazards.....	2
2.4 Environmental Mapping .....	2
2.5 Resource Inventory.....	3
2.6 Training and Exercises .....	3
<b>3. Response Organization .....</b>	<b>4</b>
3.1 Roles and Responsibilities .....	4
3.2 Communications and Contacts .....	4
<b>4. Action Plan.....</b>	<b>6</b>
4.1 Initial Action .....	6
4.2 Barrel Storage Area .....	6
<b>5. Reporting Procedures.....</b>	<b>7</b>

---

## 1. Contact Information

The Spill Contingency Plan (SCP) was prepared for the PIN-3, Lady Franklin Point landfill monitoring team. The SCP is effective as of June 1, 2009 and will be available as a stand-alone document to all team members and will also be posted on-site in the camp.

The landfill monitoring is being conducted as a follow up to the DEW Line Clean Up Project, as represented by the Department of National Defence and Defence Construction Canada. To request additional information, or additional copies of the SCP, please contact:

**Douglas Craig, M.Sc.**  
**Environmental Officer – DEW Line Clean Up Project**  
**Defence Construction Canada**  
**Constitution Square, Suite 1720**  
**350 Albert Street**  
**Ottawa, ON K1A 0K3**

---

## 2. Introduction

The following contingency plan presents the prescribed course of action to be taken in the case of an unanticipated spill event occurring during the landfill monitoring program at the PIN-3 site. The plan will enable the site team to maximize the effectiveness of the environmental protection response and meet all regulatory requirements for reporting to the appropriate authorities.

### 2.1 Scope and Purpose

The purpose of the plan is to:

- Provide a clear statement of the procedures to be followed in response to a spill;
- Minimize the potential environmental impact of a spill by establishing a pre-determined action plan;
- Protect the health and ensure the safety of the personnel involved in the Spill Response activities;
- Provide a reporting network for spills;
- Ensure site restoration;
- Identify the roles and responsibilities involved in the spill response activities; and
- Identify sufficient personnel, materials and equipment needed to make an adequate response to a spill.

### 2.2 Site Information

It is estimated that the camp operation will require minimal amounts of gasoline for the all-terrain vehicles, with an estimated volume of 1 x 200 litre barrel or less. The fuel will be stored at the camp on the airstrip apron. A spill kit will be located at the camp.

### 2.3 Potential Safety Hazards

The most significant potential safety hazard related to a fuel spill at the PIN-3 site is the possible soil and water contamination from the spill. The barrel storage area is located away from waterbodies and watercourses to avoid this hazard. Although soil contamination is a real potential hazard, the likelihood is small, and potential spill volumes are small.

### 2.4 Environmental Mapping

The attached drawing shows the site plan, including the airstrip apron area where the camp and fuel are located.

---

## 2.5 Resource Inventory

The following equipment is typically on-site during a landfill monitoring program event: ATV, small spill kits, and shovels. All equipment is stored at the camp site.

## 2.6 Training and Exercises

As the potential spill volume is small (200 L or less), no formal spill response training is typically provided. However, general spill response awareness and use of the spill clean up materials is provided as part of the Health and Safety training for the site.



## 3. Response Organization

### 3.1 Roles and Responsibilities

The contractor will be responsible for spill response clean up in the event of a spill during the landfill monitoring activities at PIN-3. The responsibilities are described below.

- Ensure the team is aware of the spill kit location and its use.
- Ensure sufficient materials and equipment are available for adequate response to fuel and hazardous material spills.
- Verbally report all spills to the DCC Project Manager as soon as practical.
- Stop or reduce discharge, if it is safe to do so.
- Make every effort to contain the spill by dyking with earth or other barriers.
- Deploy hand tools and absorbents to the spill site.
- Follow all guidelines and regulations for disposal of spilled materials and contaminated soil as established by appropriate government agencies.
- Document all events/actions.
- Report the spill to the Spill Report Line and follow up with a written spill report. This report shall summarize the initial report information; confirmation of spill volume; actions taken; future remediation/monitoring requirements; and a sketch map and/or photographs of the spill area.

### 3.2 Communications and Contacts

Intra-site communication is via two-way radios, and a satellite phone will be used for all other communications. The following table provides relevant contact numbers.

Resource	Location	Phone No.
24 Hour Spill Line	NWT/Nunavut	867-920-8130
Environment Canada	Environmental 24 hour Emergency	867-920-5131
Environment Canada	Enforcement Officer	867-975-4644
Government of Nunavut – Environmental Protection	Iqaluit	867-975-5907
Indian and Northern Affairs Canada – Water Resources Inspector	Nunavut Regional Office	867-975-4550
Indian and Northern Affairs Canada – Land Administration Minister	Nunavut Regional Office	867-975-4280
Department of Fisheries and Oceans	Nunavut Regional Office	867-975-8000
Defence Construction Canada	Environmental Officer – Douglas Craig	613-998-7288

Resource	Location	Phone No.
(representatives for the Department of National Defence)	Deputy Project Manager – Scott Munn	613-990-9641
	Project Manager – LCol. David Eagles	613-998-9523

---

## 4. Action Plan

Gasoline could potentially be spilled at the PIN-3 site. The fuel will be stored in the original barrel in the upright position, so the potential spill volumes are relatively small and would only affect the immediate area around the camp, where the fuel will be stored.

### 4.1 Initial Action

In the event of a spill, protection of human health and safety is paramount. Contamination of personnel involved in a clean up is a real possibility, as is contamination of the surrounding workplace and environment. The individual discovering a spill shall:

- Warn the people in the immediate vicinity and evacuate if necessary.
- Isolate or remove any ignition sources and take all safety precautions before approaching.
- Attempt to stop the leakage and contain the spill, if safe to do so.
- Deploy equipment and personnel to initiate containment and clean up, report to the DCC Project Manager.
- Prepare the Government of the Northwest Territories Spill Report Form.
- Notify all other pertinent parties, including the DND and other government agencies.

### 4.2 Barrel Storage Area

In order to prevent spill or accidents at barrel storage area, the following procedures apply:

- Conduct ATV fuelling in a manner that avoids spillage. Operators are to be in attendance for the duration of the refuelling operation and are to ensure that all storage container outlets are properly sealed after use.
- Smoking is prohibited within 7.5 metres of the fuel storage facility. Provide appropriate signage.
- Store the barrel in an upright elevated position.
- The barrel shall be labelled. The label is to be to industry standards and should provide all information necessary for health and safety, and environmental purposes. This should include a Material Safety Data Sheet.
- Remove all fuel and associated materials from the site at the conclusion of the work.

## 5. Reporting Procedures

When reporting a spill to the 24 Hour Spill Report Line and completing the Nunavut Spill Report Form, the following information shall be included:

- Date and time of the spill;
- Location of the spill and direction the spill may be moving;
- Name and phone number of a contact person close to the location of the spill;
- Type of contaminant spilled and quantity spilled;
- Cause of the spill;
- Whether the spill is continuing or has stopped;
- Description of the existing containment;
- Action taken to contain, recover, clean up and dispose of spilled material;
- Name, address and phone number of the person reporting the spill; and
- Name of owner or person in charge, management or control of the contaminants at the time of the spill.

The spill report is to be submitted to the INAC Water Resources Officer no later than 30 days after initially reporting the spill to the spill report line. The contact list is provided in Section 2.2.