



Environment Environnement
Canada Canada

Environmental Protection Branch
Qimugjuk Building 969 P.O. Box 1870
Iqaluit, NU X0A 0H0
Tel: (867) 975-4639
Fax: (867) 975-4645

September 7, 2004

Our file: 4517 000 001

Phyllis Beaulieu
Manager, Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU X0B 1J0
Tel: (867) 360-6338
Fax: (867) 983-6369

Via Email at licensing@nwb.nunavut.ca

RE: NWB5GLA – UMA Engineering Ltd. – 2003 Annual Report, CAM-2, Gladman Point, NU
NWB5GLA – UMA Engineering Ltd. – Monitoring Plan and QA/QC Plan, CAM-2, Gladman Point, NU

On behalf of Environment Canada (EC), I have reviewed the information submitted with the above-mentioned application. The following specialist advice has been provided pursuant to Environment Canada's mandated responsibilities for the enforcement of the *Canadian Environmental Protection Act*, Section 36(3) of the *Fisheries Act*, the *Migratory Birds Convention Act*, and the *Species at Risk Act*.

The 2003 Annual report indicates that the sewage lagoon constructed in 2003 to support the construction camp did not retain the effluent discharged into the lagoon. Environment Canada requests information regarding how sewage is to be handled for the duration of the project, as the lagoon is no operating properly.

Based on the information provided, EC has no major concerns with the monitoring plan or the QA/QC plan.

If there are any changes in the proposed project, EC should be notified, as further review may be necessary. Please do not hesitate to contact me with any questions or comments with regards to the foregoing at (867) 975-4639 or by email at colette.meloche@ec.gc.ca.

Yours truly,

Original signed by

Colette Meloche
Environmental Assessment / Contaminated Sites Specialist

cc: (Stephen Harbicht, Head, Assessment and Monitoring, Environment Canada, Yellowknife)