



ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᓂᓂᓕᓂᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File: 1BR-KEI1722

November 09, 2018

Charlotte Lamontagne
Director, Contaminated Sites (NRO)
Crown-Indigenous Relations and Northern Affairs Canada
P. O. Box 2200, Iqaluit, NU X0A 0H0

Email: charlotte.lamontagne@canada.ca

RE: Licence No. 1BR-KEI1722 Type “B”; CAM-E (Keith Bay) Site Remediation Project, Crown-Indigenous Relations and Northern Affairs Canada; 2017 Annual Report Review

Dear Ms. Lamontagne:

The Nunavut Water Board (NWB) has completed a technical review of the 2017 Annual Report (the Report) for Type “B” Water Licence 1BR-KEI1722 (the Licence). The Report was received on August 31, 2018 from Crown-Indigenous Relations and Northern Affairs Canada (CIRNAC or the Licensee), submitted as a requirement under Part B of the Licence.

Copies of all documents received during Report review can be accessed through the NWB’s Public Registry and FTP site using the following link:

[ftp://ftp.nwb-oen.ca/registry/1%20INDUSTRIAL/1B/1BR%20-%20Remediation/1BR-KEI1722%20CAM%20E%20Keith%20Bay/3%20TECH/1%20GENERAL%20\(B\)/2%20ANNUAL%20RPT/2017/](ftp://ftp.nwb-oen.ca/registry/1%20INDUSTRIAL/1B/1BR%20-%20Remediation/1BR-KEI1722%20CAM%20E%20Keith%20Bay/3%20TECH/1%20GENERAL%20(B)/2%20ANNUAL%20RPT/2017/)

NWB noted the following deficiencies in the course of the Report review:

- 1) The allowable domestic water use of five (5) cubic metres per day was exceeded. The Report indicates 8.5 m³/day as the actual rate of water use. In addition, the Report indicates that the permitted rate of water use is 14 m³/day, which was prescribed by the original Licence but amended on November 29, 2017. NWB would like to remind the Licensee not to exceed the maximum permitted rate of water use. If the Licensee forecasts an increase in water requirement over the allowable limit, the Licensee ought to apply for a Licence amendment. The amendment application form can be found on the NWB FTP website at the following link:

[ftp://ftp.nwb-oen.ca/other%20documents/Water%20License%20Applications/100401-Application for Water Licence Amendment-OEDE-edited130401.doc](ftp://ftp.nwb-oen.ca/other%20documents/Water%20License%20Applications/100401-Application%20for%20Water%20Licence%20Amendment-OEDE-edited130401.doc)

- 2) The results of the monitoring program prescribed in Licence Part K are not provided in the 2017 annual report.

The Licensee is requested to eliminate the deficiencies in the next annual report. If you have any questions, please contact the undersigned at assol.kubeisinova@nwb-oen.ca or (867) 360 6338.

Regards,

Assol Kubeisinova
Nunavut Water Board,
Technical Advisor

Copy: Distribution list - Kitikmeot