



NWB Tools

Ida Porter &lt;ida.porter@nwb-oen.ca&gt;

---

## 180529 1BR-MTH1722 Submission of Technical Documents CAM-C Matherson Point Kitikmeot Region-OAAE

---

**Assol Kubeisinova** <assol.kubeisinova@nwb-oen.ca>

Tue, May 29, 2018 at 3:21 PM

To: dele.morakinyo@canada.ca, david.rochette@aandc-aadnc.gc.ca

Cc: Licensing Department &lt;licensing@nwb-oen.ca&gt;

Dear Dele Morakinyo,

I am the NWB technical advisor working on the 1BR-MTH1722 file. Thank you for submitting the document package. Please find some comments below.

Licence Part D, Item 5: "The Licensee shall submit for the Board's approval, prior to commencing onsite remediation work, a "Wastewater Treatment Facility Design, Operation and Maintenance Plan." The Plan was provided today and mentions that "the camp will generate approximately 75 m<sup>3</sup> of wastewater". Could you please clarify what the capacity of a single lagoon is going to be? Since both sewage and industrial wastewater will be collected in both lagoons, what is the plan for contingent overload? What is the maximum allowable flowrate through the treatment system? What would be the plan if the actual flowrate exceeds the maximum allowable value?

Licence Part D, Items 6 and 7: "The Licensee shall submit for the Board's approval, prior construction of any onsite landfarm or landfill, a Facility Design, Operation and Management Plan for the proposed facility" and "The Licensee shall submit to the Board for approval, ninety (90) days prior to commencing any remediation work that involves "Type B PHC Contaminated Soil", a "Type B PHC Contaminated Soil Treatment Plan" for the CAM-C site." Does INAC intend to consider the submitted "Soil Treatment Plan" (P-0012811-0-01-001) as containing both plans mentioned in these items?

Licence Part H, Item 3: "The Licensee shall provide all issued for construction drawing sets to the Board." Would INAC like to submit the stamped engineering drawings in the "Wastewater Treatment Plan" (P-0012811-0-01-001) and "Soil Treatment Plan" (P-0012811-0-01-001) as submissions requested in this Item?

Licence Part K, Item 4: "The Licensee shall submit to the Board for review and acceptance a QA/QC Plan within sixty (60) days following issuance of the Licence. The Plan shall include a letter from an analyst conforming that the plan is acceptable for achieving the monitoring proposed." Could you please submit the letter from the lab?

In your email, you have stated that the works will commence in June. However, NWB ought to issue the documents (the "Wastewater Treatment Plan", "Soil Treatment Plan", updated "Spill Contingency Plan", and the "Erosion, Sediment and Drainage Control Plan") for review by interested parties and allowing for sufficient review time.

Regards,



## Assol Kubeisinova- ᠠᠰᠣᠯ ᠬᠤᠪᠡᠰᠢᠨᠣᠪᠠᠶ᠋ᠠᠨ

Technical Advisor - Conseiller technique ᐱᓕᑦᑐᒃᑐᓂᓄᓗ ᐃᔭᓂᓴᓂ-  
Piluagnaqtuliginigmun Ikayuqti

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT  
ᓄᓇᑭᑦ ᐃᓕᓕᓴᑦ ᑲᑎᓴᑦᓴᑦ - NUNAVUT IMALIRIYTN KATIMAYINGI

[www.nwb-oen.ca](http://www.nwb-oen.ca)

P.O. Box 119  
Gjoa Haven, NU X0B 1J0

C.P. 119  
Gjoa Haven, NU X0B 1J0

በበና ሄሮ ልሳ  
ፎቶ ሄጃ፣ ወጪ፣ X013 110

Titigaqavua 119  
Uqhuqtuuq, NU, X013 1J0

Tel / Téléphone / ᖃᖅᓴᓂᖅ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᖃᖅᓴᓂᖅ: (867) 360-6369  
Toll Free / Sans / ᐱᖅᓴᓂᖅ: 1-855-521-3745

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

[Quoted text hidden]

**6 attachments**

 **180529 1BR-MTH1722 P 0012811 CAM-C Erosion Sediment Drainage Plan-IAAE.pdf**  
97K

 180529 1BR-MTH1722 P 0012811 CAM-C Wastewater-IAAE.pdf  
304K

 180529 1BR-MTH1722 P 0012811 Part D Item 5 CAM-C Soil Treatment Plan-IAAE.pdf  
1466K

 **180529 1BR-MTH1722 P 0012811 CAM-C Spill Contingency Plan-IAAE.pdf**  
175K

 **180529 1BR-MTH1722 P 0012811 CAM-C QA QC Plan-IAAE.pdf**  
959K

 **180529 1BR-MTH1722 P 0012811 CAM-C Sampling-IAAE.pdf**  
409K