From:	Melissa Joy
To:	Nunatta Environmental
Cc:	Andrew Keim; Phyllis Beaulieu
Subject:	Re: Intent to discharge water (1BR-NUN)
Date:	Friday, May 11, 2012 3:37:26 PM

Hi Jim,
Notice to discharge in the coming weeks has been received. Based on the sample results you sent earlier, I have no issues with the current discharge. Please ensure to submit results for upcoming discharge events as soon as possible before you discharge: as long as results continue to be below criteria, I have no issues.

Thank you for keeping us informed,
Melissa

Melissa Joy, B. Env Sc.
Water Resource Officer
Aboriginal Affairs & Northern Development Canada
P.O. Box 100, Iqaluit, NU, X0A 0H0
PH: (867) 975-4288
FAX: (867) 979-6445
email: melissa.joy@aandc.gc.ca

This transmission is confidential. Any unauthorized disclosure,
distribution, or other use is strictly prohibited. If you have received
this message in error, please contact sender immediately and delete this
transmission and any attachments.
>>> Nunatta Environmental <nunatta@northwestel.net> 5/11/2012 4:52 PM >>>
Hi Melissa

Sorry this is such short notice but we need to discharge water due to
the very fast spring melt conditions.
I have sent you a copy of our water test results (from Paracel Labs
which confirm the water is safe to discharge into the environment)
All Values are in PPB not PPM and values are well below criteria.
I will be filling the same tanks again after pumping out is complete and
then again once they are released so I am giving notice of water pumping
request
for next week and maybe into the following week.
All discharged water will pass through a carbon filter system on its way
to the environment.
I can batch approx 46,000L or water and feel I have about 150,000 L
surplus water on hand.
Thank you in advance

JIM

--
This message was sent to you by:
James H. Wilson
General Manager,
Nunatta Environmental Services Inc.
P.O..Box 267
Building #1575, Federal Road,
Iqaluit, Nu.

X0A-0H0
1-867-979-1488 Office
1-867-979-1478 Fax
1-867-222-4111 Cell