From: Luigi Torretti
To: "Phyllis Beaulieu"
Cc: Geoff Clark; Stanley Anablak; Evelyn Bolt; ANN KLENGENBERG
Subject: RE: 120321 1BR-PEE1116 Submission - OM Procedures Wastewater Treatment Facility
Date: Thursday, April 12, 2012 3:45:47 PM

Hello Phyllis,

The KIA has reviewed the waste water OM plan and we have one comment: the plan does not account for the additional 3 m^3 of water use (increase from 7 m^3 to 10 m^3) as was requested in their recent Type "B" water licence amendment. The additional water use may affect lagoon capacity.

Thank you for the opportunity to comment on this file.

Luigi Torretti, M.Sc., B.Comm.
Senior Environment Officer
Kitikmeot Inuit Association
(867) 982-3310
www.kitia.ca

From: Phyllis Beaulieu [mailto:licensing@nunavutwaterboard.org]
Sent: Wednesday, March 21, 2012 11:44 AM
To: Mark Yetman (Mark.Yetman@aandc-aadnc.gc.ca)
Cc: Phyllis Beaulieu
Subject: 120321 1BR-PEE1116 Submission - OM Procedures Wastewater Treatment Facility

Please see attached letter requesting review and comments on the above. The documents submitted are available on our ftp site at the following link, please refer to the folder entitled O and M
ftp://nunavutwaterboard.org/1%20PRUC/1%20INDUSTRIAL/1B/1BR%20-%20Remediation/1BR-PEE1116%20PIN%20E/3%20TECH/

Deadline for comments is April 20, 2012

Phyllis Beaulieu
Manager of Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU X0B 1J0
Phone: (867) 360-6338, Ext. 26
Fax: (867) 360-6369
Email: licensing@nunavutwaterboard.org