



NWB Tools

Richard Dwyer <richard.dwyer@nwb-oen.ca>

1BR-ROS1727 and 1BR-SAR1727 Spill Plan

Forte, Sarah (AADNC/AANDC) <sarah.forte@canada.ca>

Fri, Nov 16, 2018 at 7:13 PM

To: Richard Dwyer <richard.dwyer@nwb-oen.ca>, Licensing Department <licensing@nwb-oen.ca>

Cc: "Parsons, Ian (AADNC/AANDC)" <ian.parsons@canada.ca>, "Hack, Justin (AADNC/AANDC)" <justin.hack@canada.ca>

Hello Richard,

Crown-Indigenous Relations and Northern Affairs Canada Water Resources Division has reviewed the Spill Contingency Plan for 1BR-ROS1727 and 1BR-SAR1727.

The Plan refers to using drip trays during refuelling. It is not clear if this means fuel drums will be stored on site, or perhaps the aircraft will be transporting their own fuel for unexpected weather. If drums are stored on site, more information should be provided in the Plan, including the drum cache locations and secondary containment measures.

Regards,

Sarah

Sarah Forté

Water Management Specialist, Water Resources, Nunavut Regional Office

Crown-Indigenous Relations and Northern Affairs Canada

sarah.forte@canada.ca / Tel : (867) 975-3876

Specialiste de la gestion de l'eau, Ressources hydriques, Bureau régional du Nunavut

Relations Couronne-Autochtones et Affaires du Nord Canada

sarah.forte@canada.ca / Tel : (867) 975-3876**From:** Richard Dwyer [mailto:richard.dwyer@nwb-oen.ca]**Sent:** 2 novembre 2018 18:57**To:** Allen, Jean (AADNC/AANDC); Lamontagne, Charlotte (AADNC/AANDC)**Cc:** licensing@nwb-oen.ca**Subject:** 1BR-ROS1727 and 1BR-SAR1727 Spill Plan

