



P.O. Box 119  
GJOA HAVEN, NU X0B 1J0  
TEL: (867) 360-6338  
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓂᓪ  
NUNAVUT WATER BOARD  
NUNAVUT IMALIRIYIN KATIMAYINGI  
OFFICE DES EAUX DU NUNAVUT

---

File No.: 1BH-RFS0910/TR/H1

September 21, 2010

Marc Losier, G.S.C., Project Manager  
Mosher Engineering Limited/ Inukshuk Construction Limited  
1869 Upper Water Street, Anchorage House Suite AH202  
Halifax, NS B3J 1S9  
Email: [marc@mosher.ca](mailto:marc@mosher.ca)

**RE: Licence 1BH-RFS0910, Type “B”--Approval of “Spill Contingency Plan, Fuel Facility Upgrade Project, Rankin Inlet, NU”, Required Under Part H, Item 1, of Licence Terms and Conditions**

Dear Mr. Losier:

The Nunavut Water Board (“NWB”) received, on February 19, 2010, the revised Plan entitled “Spill Contingency Plan, Fuel Facility Upgrade Project, Rankin Inlet NU.” On February 26, 2010, the NWB acknowledged receipt of the Plan and distributed it for a thirty-day comment period.

Staff reviewed the Plan and comments received then determined that the Plan fulfills the requirements of Part H, Item 1 of Licence 1BH-RFS0910. The NWB has, therefore, approved the plan under motion number 2010-15-L10. However, to address minor deficiencies and issues raised by the stakeholders, the NWB requires an addendum to the Plan within thirty (30) days following approval date of the Plan. The addendum shall include or address the following:

1. Include the revision date on the plan;
2. Replace the contact number listed for GN-DOE with 867-975-7700;
3. Include step-by-step procedures for addressing spills on land, in water, and on ice/snow;
4. Lists the content of spill kits;
5. Include the 24-hr contact number for the person responsible for activating the Plan;
6. Include an inventory of the equipment for spill cleanup; and
7. Include specifics for the land farm where contaminated soil associated with the project will be disposed of as well procedures for transportation of contaminated soil.

Should you have any questions, please feel free to contact the undersigned at 867-360-6338 ext. 25 or by email at [sjoseph@nunavutwaterboard.org](mailto:sjoseph@nunavutwaterboard.org).

Yours truly,

*Original signed by:*

Sean Joseph  
Technical Advisor

Cc: Distribution List – Kivalliq Region  
Wayne Thistle – CGS