



CONNECTION TO GROUNDING ROD IN TEST BOX

NOTE:

1. GROUND RODS SET IN A 100mm DRILLED HOLE IN ROCK SHALL BE BACKFILLED WITH GROUNDING ENHANCEMENT MATERIAL "GEM" AVAILABLE IN 25LB BAGS FROM ERICO PRODUCTS INC.



SECTION: ELECTRICAL	
SCALE: NONE	
DESIGN: J. MARTINZ	19 APR 06
DRAWN: F. REYES	19 APR 06
CHECK: R. UMENO	01 MAY 06
APPRVD: A.R. WACHMANN	01 MAY 06

**CUMBERLAND
RESOURCES**

PERMIT TO PRACTICE NISHI-KHON/SNC-LAVALIN LIMITED
Signature A.R. WACHMANN
Date MARCH 29 2001
PERMIT NUMBER: P 272
<small>The Association of Professional Engineers, Geologists and Geophysicists of the Northwest Territories</small>



**NISHI-KHON/
SNC-LAVALIN**

REV.	DATE	REVISION DESCRIPTION	PREP. BY	APP'D
PA	01 MAY 06	ISSUED FOR FIRE MARSHAL INITIAL REVIEW	FR	RU
REVISIONS				

MEADOWBANK GOLD PROJECT
ELECTRICAL DESIGN STANDARDS
GROUNDING INSTALLATION DETAIL
GROUND ROD IN TEST BOX

PROJECT NUMBER 017202	DRAWING NUMBER 2000-47D1-0004	REV. PA
---------------------------------	---	-------------------

\$DATE\$
 \$TIME\$
 \$FILES\$