



Department of Health and Social Services
P.O. Box 83
Cambridge Bay, Nunavut
X0E 0C0

July 27, 2000

Lorna Porter
A/Licensing Administrator
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NT



Re: McGregor Lake

I have reviewed the renewal water permit application for McGregor Lake submitted by Muskox Holdings and offer the following comments.

1. According to the application document, grey water is deposited into a natural depression behind the kitchen unit. Please note that the Public Health Act requires that the effluent be discharged at least 30 metres from the camp, and any nearby body of water; and
2. The camp drinking water must be treated prior to consumption either by chlorination, ultraviolet radiation, or boiling.

*confirmed
w/ filed
Sept 13/00
JP*

Should you have any questions regarding this matter, please do not hesitate to contact me at (867) 983-7345.

Robert Phillips, CPHI(C)
Environmental Health Officer

