



Department of Health and Social Services
P.O. Box 83
Cambridge Bay, Nunavut
X0E 0C0

June 5, 2000

Nunavut Water Board
P.O. Box 119
Gjoa Haven, NT
X0E 1J0

Re: NWB2PIS

I have reviewed the water licence application from Qikiqtaaluk Corporation relative to public health and have the following comments...

- The Camp Sanitation Regulations made under authority of the Nunavut Public Health Act require that the drinking water be treated. This can be accomplished either by boiling, chlorination or ultraviolet. Passing surface water through a ceramic filter will not render it bacteriologically safe for drinking; and
- The set back distance for the greywater containment pond must be a minimum of 30 meters from any water supply, lake, stream or other water course.

Should you have any questions regarding this matter, please do not hesitate to contact me at (867) 983-7345.

Robert Phillips, CPHI(C)
Senior Environmental Health Officer

NUNAVUT WATER BOARD	
JUN 05 2000	
PUBLIC REGISTRY	

INTERNAL	
PC	<i>JK</i>
LA	<i>June 6 2000</i>
CM	
TA	
SS	
ED	
CEO	
BRD	