




Department of Health and Social Services
P.O. Box 83
Cambridge Bay, Nunavut
X0E 0C0

July 27, 2000

Lorna Porter
A/Licensing Administrator
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NT



INTERNAL	
PC	
LA	July 28/00
OM	
TA	
BS	
ED	
CEO	
BRO	

Re: NWB File No: NWB6WET

I have reviewed the water permit application submitted by Wet Coast Capital Inc for First Pass Mining Exploration and offer the following comments.

1. The camp drinking water must be treated prior to consumption either by chlorination, ultraviolet radiation, or boiling;
2. The grey water effluent must be discharged at least 30 metres from the camp; and
3. The disposal of solid waste, and human waste was not described in the application document. This information must be provided.

Should you have any questions regarding this matter, please do not hesitate to contact me at (867) 983-7345.

Robert Phillips, CPHI(C)
Environmental health Officer