



1. ALL DIMENSIONS SHOWN ARE IN METRES, UNLESS NOTED OTHERWISE.
2. FOR FILL DEPTH > 600mm AND DEPENDING ON FILL EXTENT, USE TYPE 12 I.E. RUN OF QUARRY (600mm MINUS).
3. THE FOUNDATIONS SHOWN ON THESE DETAILS ARE PRELIMINARY AND SHOULD BE VALIDATED AFTER FINALIZING BUILDINGS/STRUCTURES.
4. FOR BUILDINGS WITH NO TRUCK ACCESS RAMP REQUIREMENTS, SLOPE FINISH GRADE FROM EDGE OF BUILDING PAD TO SURROUNDING GRADE AT 3H:1V AS INDICATED ON THE DRAWING COVERING THE SPECIFIC BUILDING, OTHERWISE SLOPE AWAY TO THE SURROUNDING GRADE AT 2% MAX.
5. CUT/EXCAVATED MATERIAL USED AS FILL SHALL BE FREE FROM FROZEN MATERIAL, ICE AND ORGANIC MATERIAL AND SHALL BE COMPACTED AS APPROVED BY COMPANY'S REPRESENTATIVE.

c:\prj\projectwise\mcdo64322\dms74793\H349000-1000-10-041-0001.dgn
15/05/2013 4:22:39 PM