



Nunavut Government
Department of Health and Social Services

Kitikmeot Regional Office

Box 83, Cambridge Bay, Nunavut X0B 0C0 Tel: (867) 983-4086 Fax: (867) 983-4088

July 12, 2001

Andrea Carter
A/Licensing Administrator
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU

Re: File No. NWB2EOK

I have reviewed the water licence application from Ashton Mining relative to public health and have the following comments to offer...

- Raw water taken from the lake for the purposes of drinking, dishwashing and cooking must be treated by chlorination, ozonation, ultra-violet radiation, or boiling as per the Public Health Act of Nunavut;
- The sumps for the disposal of grey and black water must be located at least 30 meters from any water course and campsite.

Should you have any questions regarding this matter, please do not hesitate to contact me at (867) 983-4086.

Robert Thelma

Robert Phillips, CPHI(C)
Environmental Health Officer

INTERNAL	
PC	X
LA	
OM	
BIRD	

13 2001

Public Registry