



NWB Tools

Richard Dwyer <richard.dwyer@nwb-oen.ca>

Back River Project Modification Request for water licence 2AM-BRP1831

John Roesch <JRoesch@lands.kitia.ca>

Mon, Jun 17, 2024 at 9:50 AM

To: Richard Dwyer <richard.dwyer@nwb-oen.ca>

Hello Richard, the KIA has reviewed the MLA Phase 3 Tank 5 Modification Request. The KIA has only one comment that a 100-year return period was used in culvert sizing, and we didn't see which culverts are being referred to and where they are located. The KIA wants to know if the 100-year return period had considered climate change, which wasn't clear to us.

Other than this comment, the expansion for Tank 5 is reasonable to the KIA.

Thank you.

John

[Quoted text hidden]

To unsubscribe from this group and stop receiving emails from it, send an email to distro-2am-brp+unsubscribe@nwb-oen.ca.



240531 2AM-BRP1831 MLA Phase 3 Tank 5 Modificaiton Request - Final-IMLE.pdf
5944K