

REQUEST FOR INFORMATION


RFI NUMBER	NL-RFI-029
ISSUE DATE (YY/MM/DD)	February 23, 2011
PRIORITY	H <input type="checkbox"/> M <input checked="" type="checkbox"/> X <input type="checkbox"/> L <input type="checkbox"/>
REQ'D RESPONSE DATE	March 2, 2011

Hope Bay Mining Project

Subject:	Spillway Culvert Length	Project Zone/Area:	Doris North/Hope Bay
Company:	Nuna Logistics Ltd. (Nuna)	Station/Location:	Sedimentation and Pollution Control Ponds
Attention:	Doug Fielding/Jerry Graham/Calvin Goldschmidt	Discipline:	Civil


AFE:		Specification Number:	SRK Technical Specifications Rev. E
Related Drawings:	HB+D-CIV-CIV-OND-0080 Rev 0	Related Documents:	
	or DN-DMC-014		

Related WBS Code	3DAA6030	WBS Code Description:	Doris North- Sedimentation and Pollution Control Ponds

Information Request/Description of Issue/Approval Required:	
Upon review of the above drawing we are finding that there is no reference to the actual Culvert piping dimensions listed on the IFC drawing. Please advise on overall length of Culvert piping required for each of the four Spillway Culvert pipes.	
Proposed Corrective Action:	
Originator: Bradford Watkin QA/QC Manager	 Print: Sign: Date: FEB 23, 2011

Cost Impact	<input type="checkbox"/> No <input checked="" type="checkbox"/> Yes	Potential cost impact should the purchase of additional materials be required.
Detailed Estimate attached	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes	
Schedule Impact	<input checked="" type="checkbox"/> No <input type="checkbox"/> Yes	
Source for Communication	<input type="checkbox"/> Owner Change <input type="checkbox"/> Vendor Change	<input checked="" type="checkbox"/> Clarification/Info <input type="checkbox"/> Designer Change
		<input type="checkbox"/> Constructor Change <input type="checkbox"/> Other
Note: RFI's are not authorized change documents and cannot be used to direct a change in contract requirements. If Newmont's response on the RFI has cost and/or schedule effect, it is the contractor's responsibility to immediately advise Newmont. Work undertaken without Newmont written authorization is at the contractor's risk and expense		

☐ Corrective Action Approved
 ☐ Correct as Follows:

Response:
Lengths of the culvert piping can be measured off details on DN-DMC-14. Alternatively dimensions can be obtained from the ACAD files available for download from the SRK SharePoint website. Minimum required culvert lengths are ~25.5 m for the Sedimentation Pond Spillway and ~24 m for the Pollution Control Pond Spillway (additional allowance for field deviation from design lines could be expected).
Responsible Newmont Representative:  Print: John Kuznetsov; FIELD ENGINEER Sign: Date: MARCH 1ST/11