

REQUEST FOR INFORMATION

RFI NUMBER	NL-RFI-074
ISSUE DATE (YY/MM/DD)	October 2nd, 2011
PRIORITY	H <input checked="" type="checkbox"/> M <input type="checkbox"/> L <input type="checkbox"/>
REQ'D RESPONSE DATE	October 5th, 2011

Hope Bay Mining Project

Subject:	Doris North New Windy Camp	Project Zone/Area:	Doris North
Company:	Nuna Logistics Ltd. (Nuna)	Station/Location:	New Windy Camp
Attention:	Ishan Fechter, Kevin Whieldon	Discipline:	Civil

AFE:		Specification Number:	
Related Drawings:	HB+W-CIV-CIV-OND-0021	Related Documents:	
	New Windy Camp Pad Bedrock Excavation		

Related WBS Code		WBS Code Description:	

Information Request/Description of Issue/Approval Required:

Nuna is requesting clarification on the excavated subgrade surface of the Windy Camp Pad. Further grubbing will be required below the finish design grade to expose the bedrock surface.

Proposed Corrective Action:

Nuna is proposing that the rock excavation will be taken to the design grade as specified on the IFC drawing HB+W-CIV-CIV-OND-0021. Any areas identified as having till present below said grade shall be addressed on a case by case basis in the field by an SRK rep to ensure acceptable stability.

Originator: **Mike Price** October 2nd, 2011

Print:

Sign:

Date:

Cost Impact	<input type="checkbox"/> No	<input checked="" type="checkbox"/> Yes	Per description above.
Detailed Estimate attached	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes	
Schedule Impact	<input checked="" type="checkbox"/> No	<input type="checkbox"/> Yes	
Source for Communication	<input type="checkbox"/> Owner Change	<input checked="" type="checkbox"/> Clarification/Info	<input type="checkbox"/> Constructor Change
	<input type="checkbox"/> Vendor Change	<input type="checkbox"/> Designer Change	<input type="checkbox"/> Other

Note: RFI's are not authorized change documents and cannot be used to direct a change in contract requirements. If Newmont's response on the RFI has cost and/or schedule effect, it is the contractor's responsibility to immediately advise Newmont. Work undertaken without Newmont written authorization is at the contractor's risk and expense

☐ Corrective Action Approved

☐ Correct as Follows:

Response:

The as-built drawings for the New Windy Camp must show the competent bedrock surface. This will require the surveyors to pick-up the competent bedrock surface prior to engineer fill placement. As long as the on-site engineer and surveyor can confirm competent bedrock conditions, residual blast rock in the uneven bedrock surface can remain and be used as part of the back fill

Responsible Newmont Representative:

Lowell Wade

Print:



Sign:

October 7, 2011

Date: