

**EMISSION COMPLIANCE SURVEY
MONITORING REPORT
(Doris Camp Incinerator)
(July 2012 Survey)**

**Prepared for
Newmont Mining Ltd.
Nunavut/Vancouver, B.C.**

**Prepared by
A. LANFRANCO & ASSOCIATES INC.
Surrey, B.C.**

September 2012

Certification

The monitoring of the incinerator was conducted by three certified stack test technicians.


The field crew consisted of,

Mr. S. Harrington (certified), Mr. J. Burch (certified) and Mr. L. Agassiz (certified)

The report was prepared by Mr. A. Lanfranco and Mr. S. Harrington using reporting principles and guidelines generally acceptable to Environment Canada and US EPA. Final report review was conducted by Mr. S. Harrington.

The field crew certifies that the test methods used were Environment Canada or EPA reference methods for the parameters investigated.

Alan Lanfranco


Report reviewed by:



Shawn Harrington

TABLE OF CONTENTS

	Page
SUMMARY	i
1.0 INTRODUCTION	1
2.0 PROCESS DESCRIPTION/TEST OPERATIONS	2
3.0 METHODOLOGY	3
3.1 Preparation Techniques	3
3.2 Sampling Techniques	5
3.3 Analytical and Sample Recovery Techniques	8
3.3.1 Organic Sample Analysis	9
3.3.2 Particulate/Hg Sample Recovery/Analysis	9
3.4 Quality Assurance/Quality Control Techniques	11
4.0 RESULTS	12
4.1 QA/QC Results	16
5.0 DISCUSSION Of RESULTS	17
APPENDICES	
Appendix 1 - Computer Outputs of Measured and Calculated Data	
Appendix 2 - Analytical Data	
Appendix 3 - QA/QC Results	
Appendix 4 - Field Data Sheets and Process Data	
Appendix 5 - Calibration Data	

LIST OF TABLES

Table 1	Doris Camp Incinerator Emission Results
Table 2	Detailed PCDD/PCDF Emission Results
Table 3	Incinerator Stack Particulate Gravimetric Results
Table 4	Process Summary

LIST OF FIGURES

Figure 1	Semi-Volatile (Dioxin/Furan) Organics Sampling Train
Figure 2	Particulate/Hg Sampling Train
Figure 3	Dioxin/Furan Sample Recovery Schematic
Figure 4	Extraction Schematic for Stack Samples
Figure 5	Schematic of Analytical Methodology for PCDD/PCDF

SUMMARY

The following table presents the triplicate test averages for the listed parameters from the Newmont, Doris Camp incinerator stack on July 17, 18 and 19, 2012.

PARAMETER	NEWMONT DORIS CAMP INCINERATOR RESULTS	CWS EMISSION LIMITS
Particulate (mg/Rm ³ @ 11% O ₂)	11.4	N/A
Particulate (kg/hr)	0.017	N/A
Hg (ug/Rm ³ @ 11% O ₂)	1.2	20
Hg (g/hr)	0.0017	N/A
PCDD/PCDF (ng/Rm ³ TEQ @ 11% O ₂)	0.029	0.080
Flowrate (Rm ³ /min)	20.0 (19.9 for D/F tests)	N/A

N/A = not applicable

See Tables 1 and 2 for individual results

Note : values presented in boldface are results which have CWS permitted limits.

Concentrations and flowrates are expressed at standard conditions of 25°C and 101.3 "KPa (dry). Rm³ = reference cubic meter

1.0 INTRODUCTION

Newmont Mining Ltd. retained A. Lanfranco and Associates Inc. of Surrey, B.C., Canada to conduct an emission monitoring survey at the refuse incinerator located at Doris Camp, Hope Bay, Nunavut. The purpose of the survey was to measure and report emission levels of particulate, dioxins/furans (PCDD/PCDF), and mercury from the incinerator stack during the firing of a normal mixture of camp refuse and some biosolids.

The monitoring is the third emission monitoring of the incinerator in response to the annual emission survey requirements of the Canada Wide Standards (CWS). The CWS require, by 2006, emission measurements of dioxin/furan and mercury.

This report documents the methods used and results determined for triplicate stack samples from the Doris Camp incinerator stack collected on July 17 to July 19, 2012.

The report also presents QA/QC results for spiked samples and all blank samples.

2.0 PROCESS DESCRIPTION/TEST OPERATIONS

Doris Camp

The incinerator operated at Hope Bay, Doris Camp is a Westland Incinerator, Model CY 100 CA-D-O two stage incinerator. The incinerator utilizes a primary combustion chamber and secondary afterburner section, and is equipped with a six meter (nominal) refractory lined smokestack.

Prior to waste introduction, the secondary chamber was pre-heated to approximately 900 °C, and the primary chamber was pre-heated to 600°C. Once the primary and secondary chambers reached the set-point operating temperatures, waste was manually introduced to the primary chamber via the main charge door. Approximately 160 kg of waste, including a mixture of wet and dry waste in several bags were loaded for each test. The new operating procedure requires the 164 kg charge of waste to be incinerated during a six hour time period.

The day to day test schedule was:

<u>Date</u>	<u>Feed Rate (nominal)</u>	<u>Test Matrix</u>
July 17, 2012	161 kg/hr	one dioxin/furan test, then one Hg test
July 18, 2012	179 kg/hr	one dioxin/furan test, then one Hg test
July 19, 2012	159 kg/hr	one dioxin/furan test, then one Hg test

note: O₂/CO₂, temperatures and velocities measured throughout the test program with Env. Canada reference techniques.

Waste Feed Charging Schedule and Test Start Times

In general, the incinerator was charged and the system was allowed to stabilize for about ten to fifteen minutes prior to sample commencement. Once charged initially, the incinerator was not recharged during the emission survey. In other words, samples were collected during the six hour incineration process. Details of the operating conditions are summarized in Appendix 4.

3.0 METHODOLOGY

The sampling and analytical methods used throughout this survey conform to the procedures outlined in the Environment Canada emission monitoring reference method manuals. Specifically, the methods used were:

<u>Parameter</u>	<u>Reference Method</u>
Particulate Matter/Mercury	EPS Method 8 with EPA Method 29 (metals)
Sample and velocity traverse points	EPS Method 8 A
Velocity and flowrate	EPS Method 8 B
Gas molecular weight (O ₂ /CO ₂)	EPS Method 8 C
Fluegas Moisture	EPS Method 8 D
Dioxin/furan	EPS Method 1/RM/2 with 1/RM/3 analysis

3.1 Preparation Techniques

The preparation, cleaning, and proofing of the sampling equipment and materials is an integral part of the quality assurance/quality control (QA/QC) component of each stack survey. Following are details of the cleaning and proofing of relevant sample train components.

Organic (Dioxin) Train Glassware

1. Washed twice with industrial strength cleaner/detergent
2. Rinsed with generous amounts of deionized H₂O
3. Rinsed three times with methylene chloride
4. Rinsed three times with hexane
5. Rinsed three times with acetone
6. Oven baked at 300°C overnight
7. Rinsed three times with hexane (saved for proofing)
8. Rinsed three times with acetone (saved for proofing)

Amberlite XAD-2

1. Rinsed and extracted with deionized H₂O
2. Soxhlet extraction with methanol, methylene chloride and toluene (22 hrs each)
3. Nitrogen purge
4. Oven dried @ 50°C
5. Approx. 40 gram aliquot saved for proofing
6. Individual sample traps packed and spiked with surrogate regime

Organic filters

1. Soxhlet extraction (16 hrs) with toluene
2. Nitrogen drying
3. Save 1 filter for proofing

Metal Train Glassware

1. Hot detergent wash with brushing
2. Rinse with 0.1 N HNO₃
3. Copious rinsing with deionized H₂O
4. Oven drying at 105°C

Metal Train Filters

1. Overnight extraction with 1:1 nitric acid
2. Overnight rinsing with deionized H₂O
3. Drying for 2 hrs @ 105°C, desiccation and weighing
4. Save 1 filter for blank

Other Glassware

1. Hot detergent wash with brushing
2. Copious deionized H₂O rinses

3.2 Sampling Techniques

Following are brief descriptions of the reference method sampling techniques utilized to collect the various samples. The techniques employed for isokinetic sampling of particulate/metals and dioxin/furan from this source were consistent and complied with the previously referenced stack testing methods.

EPS Method 8a - Sampling Site and Traverse Points

The stack sampling location for the Doris Camp incinerator stack was located about seven diameters downstream and greater than two diameters upstream of the nearest flow disturbances. From these criteria, and measured stack diameters of 18.0 inches, and Figure A-1 of EPS Method A, a 12 point sampling regime, where 6 points along 2 - 90° traverses were sampled for each isokinetic stack test. Test point locations for the Doris Camp incinerator stack are presented in the following table.

Point	Distance from Wall
1	0.8 (1.0)
2	2.6
3	5.3
4	12.7
5	15.4
6	17.2 (17.0)

EPS Method 8b - Stack Gas Velocity and Volumetric Flowrate

At each traverse point a series of measurements including stack temperature, velocity pressure, static pressure, and sampling rate were recorded. Velocity and static pressures were measured with a calibrated S-type pitot tube mounted alongside the sample probe. Stack temperatures were measured with a calibrated K-type chromel-alumel thermocouple with a control console mounted digital readout. Cyclonic flow angles were measured using the null velocity technique.

EPS Method 8c - Molecular Weight by Gas Analysis

Stack gas molecular weight was determined by a series of grab samples which were analyzed on site for O₂ and CO₂ by Fyrite analyzers. A minimum of four to a maximum of eight grab samples were collected per test and the results averaged for insertion in the computer programs for final result calculations and corrections to 11% O₂. As a QA/QC component, calibrated portable O₂ analyzers were also used for oxygen analysis.

EPS Method 8d - Moisture Content

Stack gas moisture content was determined from the measured condensed water vapour which was collected in the impinger (cold box) section of the sampling trains, and the gas volume sampled corrected to standard conditions of 25°C and 101.3 KPa (dry).

The contaminants investigated during this survey were collected with two independent sampling trains as follows:

EPS 1/RM/2 - Dioxin/Furan

This sample train was assembled and leak checked at the laboratory the night prior to testing. Prior to sampling initiation, the stack train was assembled as shown in Figure 1 and leak checked to code specifications. The probe (quartz or glass lined) and filter module were heated to 120 +/- 15°C and crushed ice was placed around the impingers. Iced water was circulated in the condenser and in a cooling jacket around the XAD cartridge. Once the sampling system achieved the appropriate temperatures the probe tip was positioned at point No.1, isokinetic sampling was performed using the Ko orifice constant sampling procedure. A set of recordings was taken every four minutes until four sets of readings for each sample point of traverse one was achieved. The sample pump was shut off and the sample module with attached probe was withdrawn from the stack. The system was repositioned at point No. 1 of the next traverse and an additional 96 (6 points for 16 minutes each) minutes of sampling commenced. This regime was continued until both sample ports had been sampled. The total sample volume for each PCDD/PCDF test was 3.5 to 3.6 Rm³ for the three tests.

At the conclusion of the final traverse sampling the train was final leak checked and the probe was disassembled from the hot box/sample module.

Any open ends of the sampling module and probe assembly were immediately sealed with pre-cleaned aluminium foil or teflon tape, and leak checks were conducted with only teflon tape touching the open ends.

At the conclusion of each test the sample module and probe were lowered from the stack location and were in transport to the laboratory without delay. Approximately twenty minutes elapsed from sample conclusion to sample delivery at the sample recovery "laboratory".




Figure 1 – Semi-Volatile (Dioxin/Furan) Sampling Train

EPS Method 8/EPA 29 - Particulate, Hg

This train was a normal Method 29 train (Fig. 2) except special (low metal) microquartz glass filters were utilized and the impinger components were:

Incinerator Stack Impingers

100 ml 5% HNO_3 in 10% H_2O_2
100 ml 5% HNO_3 in 10% H_2O_2
Empty
100 ml 4% KMnO_4 in 10% H_2SO_4
100 ml 4% KMnO_4 in 10% H_2SO_4
100 ml distilled H_2O
200 g silica gel

The train was operated isokinetically, sampling a total of 6 points on 2 - 90° traverses for five minutes each, resulting in final sample volumes of about 1.3 Rm^3 . Data recordings were conducted at five minute intervals. The train utilized a three foot quartz probe and nozzle.




Figure 2: EPA Method 29 Particulate/Hg Sampling Train

3.3 Analytical and Sample Recovery Techniques

Following sampling for PCDD/PCDF, the sample train was sealed and transported to the field laboratory for sample recovery. At the laboratory the sample train was disassembled and six components were identified for each train. The recovery of each sample is described below:

1. Sample Filter: The exposed sample filter was removed from its holder with clean tweezers, placed on a sheet of aluminium foil, folded inside the foil and sealed in a glass petri dish. This was labelled component 1 of each test.
2. Front/Back Half Washings: This included a thorough acetone/hexane rinsing and brushing of the sample nozzle, probe liner, and connecting glassware prior to the filter. These washings were collected in a pre-cleaned one litre amber sample bottle with a teflon lined lid. This was labelled component 2 of each test. The back half of the filter holder and glassware connecting the filter holder to the condenser were rinsed and soaked with acetone and hexane with the solvents added to the component 2 sample bottle.
3. Amberlite XAD-2 Resin Trap: The resin trap was sealed with teflon tape, covered with aluminium foil and placed kept at about 4 °C prior to shipment to the analytical laboratory. This was labelled component 3 of each test.
4. Impinger Condensate: The condensate contained in the condensate trap, plus water and condensate from the impingers was measured for volume and collected in precleaned amber bottles. These samples were labelled component 4 for each test.
5. Soak: The glassware connecting the filter to the XAD module was soaked with hexane and acetone sequentially, three times, with all “soaks” and rinses collected in 1 litre amber sample bottles.
6. Final Rinse: All glassware was rinsed with hexane and acetone, sequentially three times into amber sample bottles.

All samples were labelled appropriately and placed in a cold room at 4°C until analysis was initiated. Each bottle containing solvent was marked with the liquid level and the lid was sealed.

3.3.1 Organic Sample Analysis

The organic analysis of the sample train components involved an extremely complex series of procedures as detailed in the analytical manuals.

Following is a description, in very simplified terms, of the basic procedures used to process the sample train components.

Initially the sample components are separated into liquid (containers 2,4,5,6) or solid phases (containers 1 and 3) Figure 3. Solid samples are extracted with various solvents (usually toluene), sometimes under acid conditions. The liquid samples are extracted and concentrated with a rotary evaporator, with the final concentrate added to the filter and XAD components. At this point, an internal standard solution is added to the sample for QA/QC recovery determinations. The extraction and concentrating of the various train components are shown in Figure 4.

The toluene rinse has internal standards added, with subsequent concentration by rotary evaporation. The extract volumes are fractionated, cleaned-up and analyzed by high resolution GC/MS analytical instrumentation (Figure 5).

3.3.2 Particulate/Hg Sample Recovery/Analysis


The particulate sample filters were removed from the cooled filter housing with teflon coated tweezers, with material retained on the gasket recovered with a nylon brush and added to the filter. The filter was folded and placed in an identified plastic petri dish or envelope labelled Container 1 with date, time and Run no.

Sample clean-up of the probe and front half glassware from the Hg/particulate train was conducted with sequential rinses and brushings with acetone collected in Container 2.

Impingers 1 and 2 were measured for volume and transferred with about 100 ml of deionised water to a polyethylene sample container. Impingers 3, 4, and 5 were transferred to another polyethylene container using 100 ml potassium permanganate and water rinses. HCl rinses of the permanganate impingers were not conducted as visible deposits were effectively removed by the earlier rinsings.

Silica gel from the final impinger was transferred to its original container for final weighing.

Blank filters and solutions for each component of the particulate Hg test were collected and labelled appropriately.



Container or Sample	Component(s)	Recovery Procedure
1	1, 2, 3, 4	Wash and brush 3 times each with hexane (H) and acetone (A). Rinse 3 times each with H and A.
2	5	Remove carefully from holder. Place on pre-cleaned foil. Fold in half. Place in pre-cleaned glass petri dish.
3	6, 7	Soak 5 minutes each with H and A. Rinse 3 times each with H and A.
4	8	Cap ends and wrap in foil.
5	9, 12	Empty contents into container and rinse each 3 times with HPLC water.
6	6 to 15 except 8	Rinse 3 times each with H and A.

Mark liquid levels on all bottles.

All sample containers are pre-cleaned amber glass bottles with pre-cleaned Teflon lid liners.

FIGURE 3. SEMI-VOLATILE ORGANICS RECOVERY PROCEDURES




Fig 4 - Extraction schematic diagram for stack samples and components




Fig. 5 Schematic of analytical methodology for Dioxin and Furan

Gravimetric Analysis

At A. Lanfranco and Associates Langley, B.C. laboratory, the sample filters were desiccated to constant weight and weighed as per EPA Method 5. Probe and front-half acetone rinsings were evaporated at about 70^o C in tared, precleaned 250 ml glass beakers, with subsequent weighing to constant weight. Blank filters and acetone were carried through the gravimetric process.

Hg Analysis

Following the gravimetric analysis, the filters and wash residues, along with the back half liquid samples were forwarded to Exova Laboratories in Surrey, B.C. for analysis of Hg. The samples and appropriate blanks were digested with acids and analyzed for Hg by ICAP procedures. Impingers 1,2,3, 4 and 5, for Hg, were analyzed at Exova using flameless atomic absorption.

3.4 Quality Assurance / Quality Control (QA/QC) Techniques

The QA/QC component of this survey was designed to exceed the requirements normally instituted by the regulatory agency. Additionally, QA/QC of this survey was accomplished by the following mechanisms.

1. Pre and Post test leak checks
2. Calibration of volume measuring and monitoring instrumentation
3. Proofing of organic glassware and supplies (archived proofs)
4. Analysis of all blank solutions and materials
5. Spiking and recovery analysis of organic trains
6. Use of acid cleaned microquartz filters
7. Duplicate analysis of selected samples
8. Reference material analysis with samples
9. Labelling and record-keeping
10. Surrogate spiking of dioxin trains using EPA protocols

A "Blank" test was conducted, with that sampled analysed in the same manner as test samples.

4.0 RESULTS

Most of the stack testing results were calculated using a "STACK" computer program developed for EPA and Canadian requirements. Standard conditions used in the program are 25 °C and 29.92" Hg (dry basis)

Corrections to 11% O₂ were calculated by multiplying the determined stack concentrations by;

$$\frac{20.9-11.0}{20.9-\text{measured O}_2}$$

Table 1 presents the detailed triplicate test data for Particulate, Hg, and flowrate, as well as supporting data such as temperatures, O₂/CO₂ and stack gas moistures.

PCDD/PCDF results are presented in Table 2. Table 2 presents PCDD/PCDF data in terms of actual amounts detected and toxic equivalents. In addition, all dioxin/furan results were recovery corrected according to surrogate recovery efficiencies determined for each organic analysis. Surrogates added and the recoveries determined are listed in the analytical data presented in the Appendices.

Table 3 presents particulate gravimetric results, and Table 4 presents process data.

Please note that data from the Hg and dioxin tests vary slightly for O₂, temperature and flowrates due to the timing of each test.

TABLE 1 DORIS CAMP INCINERATOR EMISSION RESULTS

Parameter	Test 1	Test 2	Test 3	Average
Test Date	July 17/12	July 18/12	July 19/12	
Test Time	15:10 - 16:12	12:45 - 13:47	11:15 - 12:17	
Duration (minutes)	60	60	60	60
Particulate (mg/Rm ³)	16.6	12.8	13.2	14.2
Particulate (mg/Rm ³ @ 11% O ₂)	14.0	10.2	10.1	11.4
Particulate (Kg/hr)	0.021	0.015	0.016	0.017
Particulate (Kg/day)	0.5	0.4	0.4	0.4
Hg (ug/Rm ³ @ 11% O ₂)	2.86	0.49	0.13	1.16
Flowrate (Rm ³ /min)	20.7	19.4	20.1	20.0
Flowrate (acm/min)	103.5	96.1	100.6	100.0
Temperature (°C)	1051	1045	1051	1049
O ₂ (vol % dry)	9.1	8.5	7.9	8.5
CO ₂ (vol % dry)	11.9	12.6	13.0	12.5
H ₂ O (vol %)	10.7	9.8	10.7	10.4
Isokinetic Variation (%)	101.6	100.2	101.7	101

standard conditions of 25 degrees C and 101.3kPa

TABLE 2 Detailed PCDD/PCDF Emission Results

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator stack

Component	TEF	Test 1 (July 17/12)		Test 2 (July 18/12)		Test 3 (July 19/12)	
		Analyzed (ng)	TEQ (ng)	Analyzed (ng)	TEQ (ng)	Analyzed (ng)	TEQ (ng)
2378 TCDD	1.0000	0.0039	0.0039	0.0000	0.0000	0.0000	0.0000
12378 PCDD	0.5000	0.0140	0.0070	0.0280	0.0140	0.0340	0.0170
123478 HxCDD	0.1000	0.0130	0.0013	0.0350	0.0035	0.0330	0.0033
123678 HxCDD	0.1000	0.0320	0.0032	0.0580	0.0058	0.0680	0.0068
123789 HxCDD	0.1000	0.0200	0.0020	0.0410	0.0041	0.0470	0.0047
1234678 HpCDD	0.0100	0.2600	0.0026	0.7600	0.0076	0.8200	0.0082
OCDD	0.0010	0.6100	0.0006	1.8000	0.0018	2.2000	0.0022
2378 TCDF	0.1000	0.0067	0.0007	0.0120	0.0012	0.0120	0.0012
12378 PCDF	0.0500	0.0015	0.0001	0.0360	0.0018	0.0330	0.0017
23478 PCDF	0.5000	0.0520	0.0260	0.1100	0.0550	0.1300	0.0650
123478 HxCDF	0.1000	0.0400	0.0040	0.1000	0.0100	0.1300	0.0130
123678 HxCDF	0.1000	0.0420	0.0042	0.1300	0.0130	0.1400	0.0140
234678 HxCDF	0.1000	0.0760	0.0076	0.2100	0.0210	0.3700	0.0370
123789 HxCDF	0.1000	0.0000	0.0000	0.0360	0.0036	0.0930	0.0093
1234678 HpCDF	0.0100	0.2700	0.0027	0.6900	0.0069	1.2000	0.0120
1234789 HpCDF	0.0100	0.0140	0.0001	0.0540	0.0005	0.1500	0.0015
OCDF	0.0010	0.0280	0.0000	0.1300	0.0001	0.6200	0.0006
Summed PCDD & PCDF TEQ (ng)			0.066		0.150		0.197
Sample Volume (Rm3)			3.597		3.472		3.513
PCDD & PCDF TEQ	ng/Rm3		0.018		0.043		0.056
PCDD & PCDF TEQ	ng/Rm3 (@11% O2)		0.014		0.034		0.040
PCDD & PCDF TEQ	grams/day		0.000001		0.000001		0.000002
Particulate	mg/dscm (@ 11% O2)		14.0		10.2		10.1
Flowrate (Rm3/min)			20.5		19.6		19.6
Oxygen (Vol. %)			8.0		8.3		7.2
Carbon Dioxide (Vol. %)			11.6		11.8		12.8
Carbon Monoxide (ppm)			1 to 5		1 to 5		1 to 3
Moisture (Vol. %)			10.4		11.6		11.5
Temperature (oC)			1027		1032		1039
Isokinetic Variation (%)			99.4		101		101

Table 3 Incinerator Stack Particulate Gravimetric Results

Test No.	Filter Particulate (mg)	Probe and Washings (mg)	Total Particulate (mg)
1	4.4	17.1	21.5
2	3.3	12.0	15.3
3	4.9	11.7	16.6

Table 4 Process Summary

Nominal for all Tests	
Primary Temp.	600 °C
Secondary Temp	> 900 °C
Load Type	about 111 kg food waste, 20 kg of paper, and 29 kg Stp initial charge
Load Size (approx)	160 kg
Load Rate	27 kg/hr (nominal)

Detailed process data (recorded by Westland personnel) is presented in Appendix 4.

4.1 QA/QC Results

Pre and Post Test Leak Checks

Each test is required to be leak checked prior to, and following the test. The leak checks must show less than 0.02 cfm. All tests passed the code leak check requirements. Evidence of the leak checks is shown on each data sheet of appendix 4.

Equipment Calibrations

All emission monitoring equipment used for the Doris camp incinerator emission monitoring was calibrated to Environment Canada specifications. Dry gas meters, pitot tubes and temperature measuring devices were calibrated within four months of the test date. See appendix 5

Proofing of Dioxin Glassware and Supplies

Although not required by Nunavut/GNWT, it is our practice to verify that the glassware and sorbent used in dioxin tests is free of contamination. Proofs of the glassware and XAD are implied by the very low Blank sample results of appendix 3.

Analysis of Blank Materials and Reagents

All blank materials and reagents yielded very low or non-detectable levels of target species.

Spiking and Recovery of Dioxin/Furan Surrogates

The recovery of the five labelled surrogates ranged from 70 to 108. These recoveries comply with EPA Method 23 requirements of 70 to 130%. In addition, all data was recovery corrected for each congener. Recoveries of all internal standards ranged from 79 to 126%, complying with EPS 1/RM/2 and Method 23 requirements of 40 to 130% recovery.

Spiking and Recovery Assessments of Inorganic Samples

Blanks of all reagents used for sample collection were spiked to known contaminant concentrations and analyzed with the source samples. Normally a high and low spike was conducted. The various recoveries are reported on the analytical data in appendix 2. In summary the results are:

	<u>Spike 1</u>	<u>Spike 2</u>	<u>Spike 3</u>
Hg	88.4 % recovery	116 % recovery	85 % recovery

Chain of Custody

All samples were in the possession of the stack test team until relinquishing to the courier/shipping companies used. The samples were inspected on arrival, and shipping containers were observed to be sealed on arrival, with no apparent tampering or sample loss in shipment.

5.0 DISCUSSION OF RESULTS

This survey was an investigation of specific emitted contaminants during the firing of waste materials normally disposed of in the Doris Camp incinerator. The survey included monitoring of contaminants required by Canada Wide Standards (CWS), namely dioxin/furan and mercury.

The incinerator tested, consisted of Primary and Secondary (afterburner) chambers. The combustion chambers use diesel fuel as the primary fuel.

Compliance Status

Based on the CWS and the “Guidelines for the Management of Biomedical Waste in the Northwest Territories”, the test results showed that the emissions from the Doris Camp incinerator were in compliance for Hg, as well as in compliance for dioxin/furan.

The average Hg emissions were $1.2 \text{ ug/Rm}^3 @ 11\% \text{ O}_2$, compared to an emission standard of $20 \text{ ug/Rm}^3 @ 11\% \text{ O}_2$. The average dioxin/furan emissions were $0.029 \text{ ng/Rm}^3 @ 11\% \text{ O}_2$, compared to an emission standard of $0.080 \text{ ng/Rm}^3 @ 11\% \text{ O}_2$.

Mercury

Mercury was found at levels significantly above method detection limits, yielding confident quantification of Hg at the levels measured. The Hg emission results suggest that the waste feed Hg content was very low, however.

Dioxin/Furan

The dioxin/furan emission concentrations from the Doris Camp incinerator for this survey were much lower than the 2009 and 2011 data, and were very low in comparison to much historical data from uncontrolled camp refuse incinerators.

General

Research into dioxin emissions from combustion sources has generally shown that dioxin is formed in two manners. The first mechanism is known as the "Precursor mechanism" where there is incomplete combustion and dioxin is formed by reactions of chlorine and organic aromatic compounds. The second mechanism is known as "DeNovo Synthesis", where dioxin formation reactions occur post-combustor, in the air pollution control systems at temperatures between 200 and 450 °C.

Another well documented condition leading to higher than expected D/F emissions is known as the "memory effect". The "memory effect" phenomenon occurs when prior operating conditions and residual emitted materials effect the subsequent test periods. In the case of batch systems, like camp incinerators, the type and amounts of waste material used in several previous burn loads (before the compliance test) could significantly impact the results of the first series of compliance tests. In this case, memory effects were apparently not a factor influencing dioxin emission levels.

The QA/QC program was successful in showing excellent analytical accuracy, in proving the avoidance of any significant sample contamination, and in maintaining leak free sampling procedures. The analysis of the dioxin/furan samples indicated complete recovery by virtue of excellent surrogate recoveries for the compounds of interest. The recovery of the five labelled surrogates ranged from 70 to 108%. These recoveries comply with EPA Method 23 requirements of 70 to 130%. In addition, all data was recovery corrected for each congener. Recoveries of all internal standards ranged from 79 to 126% complying with EPS 1/RM/2 and EPA Method 23 requirements of 40 to 130% recovery.

There were no problems encountered in sample collection or analysis and validation of the field study is provided, in large part, by the analytical QA/QC program and the use of calibrated test equipment by qualified monitoring professionals. The test results, therefore, are reported with confidence and are considered an accurate representation of emission characteristics for the process conditions maintained on the test dates.

APPENDIX 1

COMPUTER OUTPUTS OF MEASURED

AND CALCULATED DATA

Client:	Newmont, Hope Bay	Date:	July 17/12
Jobsite:	Doris Camp	Run:	1 PCDD/PCDF
Source:	Incinerator stack	Run Time:	11:40 - 14:58

Concentration:	0.00 mg/dscm	0.0000 gr/dscf
	0.00 mg/Acm	0.0000 gr/Acf
Emission Rate:	0.00 mg/dscm (@ 11% O2)	0.0000 gr/dscf (@ 11% O2)
	0.00 Kg/hr	0.000 lb/hr
Sample Gas Volume:	3.5970 dscm	127.027 dscf
Total Sample Time:	192.0 minutes	
Average Isokineticity:	99.4 %	
Flue Gas Characteristics		
Moisture:	10.44 %	1880.9 oF
Temperature	1027.1 oC	
Flow	20.5 dscm/min	722 dscf/min
	0.34 dscm/sec	12.0 dscf/sec
Velocity	100.2 Acm/min	3538 Acf/min
	10.170 m/sec	33.37 f/sec
Gas Analysis	7.99 % O2	11.60 % CO2
	30.176 Mol. Wt (g/gmole) Dry	28.904 Mol. Wt (g/gmole) Wet

*** Standard Conditions:**

Metric:	25 deg C, 101.325 kPa
Imperial:	77 deg F, 29.92 in.Hg

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator stack

July 17/12
1 PCDD/PCDF
11:40 - 14:58

Date:
Run:
Run Time:

Control Unit (Y)	0.9989	Collection:		Gas Analysis (Vol. %):		Condensate Collection:	
Nozzle Diameter (in.)	0.5467	Filter (grams) 0.0000		CO2		Impinger 1 (grams)	
Pitot Factor	0.8421	Washings (grams) 0.0000		Trav 1 12.20		Impinger 2 (grams)	
Baro. Press. (in. Hg)	29.75	Impinger (grams) 0.0000		Trav 2 11.00		Impinger 3 (grams)	
Static Press. (in. Hg)	0.04	Total (grams) 0.0000				Impinger 4 (grams)	
Stack Height (ft)	50						
Stack Diameter (in.)	18.0						
Stack Area (sq.ft.)	1.767						
Minutes Per Reading	4.0			Average = 11.60		Total Gain (grams)	
Minutes Per Point	16.0					308.6	

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ΔP (in. H2O)	Orifice ΔH (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	XAD Exit (oF)	Stack (oF)	Wall Dist. (in.)	Isokin. (%)
1	1	0.0	635.559	0.100	1.78	81	81	4		1826	0.8	100.1
		4.0	638.628	0.110	1.78	81	81	4	48	1916	0.8	99.3
		8.0	641.761	0.100	1.88	84	81	4	50	1890	0.8	98.9
		12.0	644.761	0.100	1.72	85	81	4	50	1890	0.8	100.4
		16.0	647.808	0.100	1.72	86	82	4	50	1873	2.6	99.7
2	2	20.0	650.850	0.100	1.72	86	82	4	50	1896	2.6	99.6
		24.0	653.879	0.100	1.74	87	84	4	51	1904	2.6	99.7
		28.0	656.914	0.100	1.72	88	86	4	51	1837	2.6	99.4
		32.0	659.670	0.080	1.72	90	86	4	51	1823	5.3	99.4
		36.0	662.440	0.080	1.42	92	86	4	51	1828	5.3	99.5
3	3	40.0	665.030	0.070	1.43	91	86	4	51	1830	5.3	99.3
		44.0	667.800	0.080	1.25	92	88	4	52	1896	5.3	99.5
		48.0	670.540	0.080	1.43	93	89	4	52	1891	12.7	99.5
		52.0	673.110	0.070	1.40	94	90	4	52	1844	12.7	99.3
		56.0	675.520	0.060	1.23	96	92	4	52	1840	12.7	99.4
4	4	60.0	677.940	0.060	1.07	97	93	4	52	1819	12.7	99.1
		64.0	680.560	0.070	1.08	98	93	4	52	1832	15.4	99.5
		68.0	682.990	0.060	1.27	99	94	4	53	1840	15.4	99.4
		72.0	685.420	0.060	1.08	100	95	4	53	1830	15.4	99.0
		76.0	687.850	0.060	1.08	101	96	4	53	1842	15.4	99.2
5	5	80.0	690.280	0.060	1.09	101	97	4	53	1887	17.2	99.2
		84.0	692.690	0.060	1.09	102	97	4	55	1911	17.2	99.3
		88.0	695.090	0.060	1.06	102	97	4	55	1905	17.2	99.2
		92.0	697.490	0.060	1.06	102	97	4	55	1853	17.2	99.2
		96.0	699.920	0.060	1.08	103	98	4				
6	6	0.0	699.920									
		4.0	702.350	0.060	1.08	102	97	4	56	1847	0.8	99.2
		8.0	704.770	0.060	1.08	101	97	4	56	1858	0.8	99.1
		12.0	707.370	0.070	1.25	101	97	4	56	1881	0.8	99.1
		16.0	709.990	0.070	1.26	102	97	5	56	1864	0.8	99.4
7	7	20.0	712.610	0.070	1.26	102	97	5	56	1865	2.6	99.5
		24.0	715.210	0.070	1.24	102	97	5	56	1895	2.6	99.3
		28.0	718.000	0.080	1.43	102	97	5	55	1873	2.6	99.3
		32.0	720.770	0.080	1.41	100	97	5	55	1903	2.6	99.4
		36.0	723.850	0.100	1.76	98	95	5	55	1913	5.3	99.5
8	8	40.0	726.960	0.100	1.79	97	94	6	55	1862	5.3	99.6
		44.0	729.870	0.090	1.57	96	94	6	54	1913	5.3	99.3
		48.0	732.760	0.090	1.56	95	92	6	54	1929	5.3	99.2
		52.0	735.640	0.090	1.55	95	92	6	54	1945	12.7	99.2

A. Lanfranco and Associates Inc. - Emission Report

[illegible]

Client:
Jobsite:
Source:

Newmont, Hope Bay
Doris Camp
Incinerator stack

Date:
Run:
Run Time:

July 18/12
2 PCDD/PCDF
09:06 - 12:22

Concentration:

0.00 mg/dscm
0.00 mg/Acm

Emission Rate:

0.0000 gr/dscf
0.0000 gr/Acf

Concentration:

0.00 mg/dscm (@ 11% O2)
0.00 Kg/hr

Emission Rate:

0.0000 gr/dscf (@ 11% O2)
0.000 lb/hr

Sample Gas Volume:
Total Sample Time:

3.4722 dscm
192.0 minutes

Average Isokineticity:

100.6 %

Flue Gas Characteristics

Moisture:

11.63 %

Temperature

1032.0 oC

Flow

19.6 dscm/min
0.33 dscm/sec
98.2 Acm/min

Velocity

9.969 m/sec

Gas Analysis

8.25 % O2

Sample Gas Volume:
Total Sample Time:

122.622 dscf

Average Isokineticity:

100.6 %

Flue Gas Characteristics

Moisture:

1889.6 oF

Temperature

691 dscf/min
11.5 dscf/sec
3468 Acf/min

Flow

32.71 f/sec

Velocity

11.79 % CO2

Gas Analysis

28.795 Mol. Wt (g/mole) Wet

*** Standard Conditions:**

Metric:
Imperial:

25 deg C, 101.325 kPa
77 deg F, 29.92 in.Hg

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator stack

July 18/12
2 PCDD/PCDF
09:06 - 12:22

Control Unit (Y) 0.9989
Nozzle Diameter (in.) 0.5467
Pitot Factor 0.8421
Baro. Press. (in. Hg) 29.55
Static Height (ft) 0.04
50
Stack Diameter (in.) 18.0
Stack Area (sq.ft.) 1.767
Minutes Per Reading 4.0
Minutes Per Point 16.0

Collection:

Filter (grams) 0.0000
Washings (grams) 0.0000
Impinger (grams) 0.0000
Total (grams) 0.0000

Gas Analysis (Vol. %):

CO2 O2
Trav 1 12.40 7.70
Trav 2 11.17 8.80

Condensate Collection:

Impinger 1 (grams) 250.0
Impinger 2 (grams) 72.0
Impinger 3 (grams) 0.0
Impinger 4 (grams) 14.1

Average = 11.79 8.25
Total Gain (grams) 336.1

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Office ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Dry Gas Temperature Outlet (oF)	Vacuum (in. Hg.)	XAD Exit (oF)	Stack (oF)	Wall Dist. (in.)	Isokin. (%)
1	1	0.0	816.328	0.080	1.42	71	71	3		1816	0.8	101.6
		4.0	819.050	0.100	1.69	72	70	3	49	1936	0.8	101.5
		8.0	822.010	0.100	1.74	72	710	3	49	1863	0.8	63.4
		12.0	825.020	0.100	1.55	73	70	3	49	1895	0.8	101.6
		16.0	827.860	0.090	1.70	73	70	4	50	1922	2.6	101.4
2	2	20.0	830.830	0.100	1.58	74	70	4	50	1849	2.6	101.2
		24.0	833.690	0.090	1.57	74	70	4	50	1863	2.6	101.6
		28.0	836.550	0.090	1.57	74	70	4	50	1852	2.6	101.7
		32.0	839.420	0.090	1.57	74	70	4	50	1859	5.3	101.5
3	3	36.0	842.280	0.100	1.75	75	71	5	50	1853	5.3	101.4
		40.0	845.300	0.080	1.35	75	71	5	50	1945	5.3	101.3
		44.0	847.950	0.080	1.35	75	71	5	50	1958	5.3	101.2
		48.0	850.590	0.080	1.35	75	71	6	50	1943	12.7	101.3
4	4	52.0	853.240	0.080	1.36	75	72	6	50	1918	12.7	101.4
		56.0	855.910	0.060	1.04	75	72	6	50	1898	12.7	101.2
		60.0	858.230	0.060	1.04	76	72	6	50	1863	12.7	101.2
		64.0	860.570	0.060	1.20	76	72	6	51	1908	15.4	101.6
5	5	68.0	863.080	0.060	1.04	76	72	6	51	1849	15.4	101.4
		72.0	865.430	0.060	1.02	76	72	6	50	1922	15.4	101.2
		76.0	867.740	0.060	1.05	76	72	6	50	1860	15.4	101.2
		80.0	870.080	0.060	1.05	77	73	6	50	1853	17.2	101.3
6	6	84.0	872.430	0.060	1.05	77	73	6	50	1857	17.2	101.4
		88.0	874.780	0.060	1.05	77	73	6	50	1849	17.2	101.2
		92.0	877.130	0.060	1.03	77	74	6	52	1914	17.2	101.2
		96.0	879.450	0.060	1.03	77	74	6				
2	1	0.0	879.450	0.080	1.38	78	74	7	52	1909	0.8	101.5
		4.0	882.140	0.080	1.38	78	74	7	52	1865	0.8	101.3
		8.0	884.850	0.090	1.55	78	74	7	52	1905	0.8	101.3
		12.0	887.700	0.090	1.56	78	74	7	51	1889	0.8	99.6
		16.0	890.510	0.090	1.58	78	75	7	51	1860	2.6	103.5
2	2	20.0	893.450	0.090	1.56	78	75	8	51	1896	2.6	101.4
		24.0	896.310	0.090	1.55	77	75	8	51	1915	2.6	101.6
		28.0	899.160	0.090	1.39	78	75	8	51	1898	2.6	101.5
		32.0	901.860	0.080	1.38	78	75	8	50	1918	5.3	101.6
3	3	36.0	904.550	0.080	1.38	78	75	8	50	1920	5.3	101.6
		40.0	907.240	0.080	1.56	78	75	8	50	1895	5.3	101.4
		44.0	910.100	0.080	1.40	77	74	8	50	1886	5.3	101.5
		48.0	912.800	0.080	1.04	77	74	8	50	1896	12.7	101.2
	4	52.0	915.130	0.060	1.04	77	74	8	50			

A. Lanfranco and Associates Inc. - Emission Report

		56.0	917.470	0.060	1.05	77	74	8		50	1872	12.7	101.2
		60.0	919.800	0.060	1.04	77	74	8		50	1893	12.7	101.2
		64.0	922.140	0.060	1.04	77	74	8		50	1879	12.7	101.3
5		68.0	924.470	0.060	1.04	77	74	8		50	1902	15.4	101.4
		72.0	926.980	0.070	1.21	76	74	8		50	1903	15.4	101.3
		76.0	929.500	0.070	1.21	76	74	8		50	1885	15.4	101.3
		80.0	931.830	0.060	1.04	76	74	8		51	1894	15.4	101.3
6		84.0	934.170	0.060	1.04	76	74	8		51	1880	17.2	101.4
		88.0	936.500	0.060	1.04	76	74	8		51	1886	17.2	101.1
		92.0	938.840	0.060	1.04	76	74	8		51	1880	17.2	101.4
		96.0	941.155	0.060	1.02	76	74	8		51	1932	17.2	101.4
		Average:		0.075	1.304	76.0	86.1	6.4		50.4	1889.6		100.6

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator stack

Date: July 19/12
Run: 3 PCDD/PCDF
Run Time: 07:48 - 11:04

Concentration:
0.00 mg/dscm
0.00 mg/Acm
0.0000 gr/dscf
0.0000 gr/Acf

Emission Rate:
0.00 mg/dscm (@ 11% O2)
0.00 Kg/hr
0.0000 gr/dscf (@ 11% O2)
0.000 lb/hr

Sample Gas Volume: 124.045 dscf
Total Sample Time: 192.0 minutes

Average Isokineticity: 101.0 %

Flue Gas Characteristics

Moisture: 11.53 %
Temperature 1038.9 oC
Flow 1902.1 oF
694 dscf/min
11.6 dscf/sec
3475 Acf/min
Velocity 32.77 f/sec
Gas Analysis 12.84 % CO2
28.917 Mol. Wt (g/gmole) Wet
30.340 Mol. Wt (g/gmole) Dry

*** Standard Conditions:**
Metric: 25 deg C, 101.325 kPa
Imperial: 77 deg F, 29.92 in.Hg

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator stack

July 19/12
3 PCDD/PCDF
07:48 - 11:04

Control Unit (Y) 0.9989
Nozzle Diameter (in.) 0.5467
Pitot Factor 0.8421
Baro. Press. (in. Hg) 29.70
Static Press. (in. Hg) 0.04
Stack Height (ft) 50
Stack Diameter (in.) 18.0
Stack Area (sq.ft.) 1.767
Minutes Per Reading 4.0
Minutes Per Point 16.0

Collection:

Filter (grams) 0.0000
Washings (grams) 0.0000
Impinger (grams) 0.0000
Total (grams) 0.0000

Gas Analysis (Vol. %):

CO2 13.17 O2 6.80

Trav 1 12.50 7.50

Condensate Collection:

Impinger 1 (grams) 250.0
Impinger 2 (grams) 72.0
Impinger 3 (grams) 0.0
Impinger 4 (grams) 14.7

Average = 12.84 7.15

Total Gain (grams) 336.7

Traverse	Point	Time (min.)	Dry Gas Meter (ft3)	Pitot ^P (in. H2O)	Orifice ^H (in. H2O)	Dry Gas Temperature Inlet (oF)	Outlet (oF)	Vacuum (in. Hg.)	XAD Exit (oF)	Stack (oF)	Wall Dist. (in.)	Isokin. (%)
1	1	0.0	985.534	0.090	1.52	70	69	3	48	1920	0.8	100.9
		4.0	988.320	0.090	1.52	71	69	3	47	1846	0.8	99.4
		8.0	991.110	0.090	1.57	71	69	3	48	1910	0.8	102.6
		12.0	993.950	0.090	1.57	72	68	3	46	1930	0.8	101.2
2	2	16.0	996.740	0.090	1.52	72	68	3	46	1900	2.6	101.3
		20.0	999.550	0.090	1.53	72	69	3	46	1910	2.6	101.1
		24.0	1002.350	0.090	1.53	73	69	3	46	1908	2.6	100.9
		28.0	1004.990	0.080	1.36	74	69	4	46	1859	2.6	100.9
3	3	32.0	1007.660	0.080	1.36	74	70	4	47	1939	5.3	101.0
		36.0	1010.290	0.080	1.35	74	70	4	47	1858	5.3	101.1
		40.0	1012.970	0.080	1.35	74	70	4	47	1915	5.3	101.2
		44.0	1015.780	0.090	1.39	74	70	4	48	1842	5.3	101.0
4	4	48.0	1018.630	0.080	1.53	75	71	4	48	1930	12.7	101.0
		52.0	1021.270	0.080	1.58	75	71	4	48	1887	12.7	101.2
		56.0	1023.940	0.080	1.35	75	71	4	48	1915	12.7	100.9
		60.0	1026.590	0.080	1.38	76	71	4	48	1909	12.7	101.2
5	5	64.0	1029.250	0.080	1.36	76	71	4	47	1868	15.4	101.1
		68.0	1031.760	0.070	1.37	76	72	4	47	1908	15.4	101.1
		72.0	1034.250	0.070	1.22	76	72	4	47	1889	15.4	101.1
		76.0	1036.750	0.070	1.20	76	72	4	47	1898	15.4	100.9
6	6	80.0	1039.240	0.070	1.21	76	72	4	47	1858	17.2	101.2
		84.0	1041.760	0.070	1.20	76	72	4	47	1950	17.2	101.2
		88.0	1044.230	0.070	1.18	76	72	4	47	1921	17.2	101.1
		92.0	1046.530	0.060	1.02	76	72	4	47	1867	17.2	100.8
		96.0	1048.850	0.060	1.04	76	72	4	47			
2	1	0.0	1048.850					4	45	1882	0.8	101.1
		4.0	1051.350	0.070	1.21	74	72	4	45	1948	0.8	101.1
		8.0	1053.990	0.080	1.35	76	73	4	45	1885	0.8	101.1
		12.0	1056.670	0.080	1.38	77	73	4	45	1929	0.8	100.9
2	2	16.0	1059.320	0.080	1.36	77	73	4	45	1930	2.6	101.0
		20.0	1061.970	0.080	1.36	77	73	4	45	1892	2.6	101.3
		24.0	1064.650	0.080	1.38	77	73	4	46	1899	2.6	101.1
		28.0	1067.320	0.080	1.38	77	73	4	46	1922	2.6	101.2
3	3	32.0	1069.810	0.070	1.19	77	73	4	48	1901	5.3	101.2
		36.0	1072.310	0.070	1.20	77	73	4	48	1898	5.3	102.3
		40.0	1074.840	0.070	1.20	77	73	4	48	1889	5.3	99.7
		44.0	1077.310	0.070	1.21	77	73	4	48	1958	5.3	101.2
	4	48.0	1079.950	0.080	1.34	77	73	4	48	1912	12.7	101.3
		52.0	1082.620	0.080	1.37	77	73	4	48			

A. Lanfranco and Associates Inc. - Emission Report

		56.0	1085.110	0.070	1.20	77	73	4			48	1902	12.7	100.8
		60.0	1087.600	0.070	1.20	78	74	4			48	1929	12.7	101.2
		64.0	1090.100	0.070	1.20	78	74	4			47	1895	12.7	100.9
5		68.0	1092.610	0.070	1.20	78	74	4			47	1881	15.4	101.0
		72.0	1095.080	0.070	1.18	78	74	4			47	1952	15.4	100.8
		76.0	1097.580	0.070	1.21	77	74	4			47	1888	15.4	101.2
		80.0	1100.060	0.070	1.18	78	74	4			47	1966	15.4	101.1
6		84.0	1102.560	0.070	1.20	78	74	4			47	1909	17.2	101.1
		88.0	1104.860	0.060	1.02	77	74	4			48	1925	17.2	100.9
		92.0	1107.180	0.060	1.03	77	74	4			48	1896	17.2	101.2
		96.0	1109.486	0.060	1.03	77	74	4			48	1776	17.2	98.0
			Average:	0.076	1.301	75.7	71.9	3.9			47.0	1902.1		101.0

[illegible]

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator Stack

Date: July 17/12
Run: 1 Partic/ Hg
Run Time: 15:10 - 16:12

Particulate Concentration:	16.6 mg/dscm 3.3 mg/Acm	0.0073 gr/dscf 0.0015 gr/Acf
	14.0 mg/dscm (@ 11% O2)	0.0061 gr/dscf (@ 11% O2)
Emission Rate:	0.02 Kg/hr	0.045 lb/hr
Sample Gas Volume:	1.2933 dscm	45.674 dscf
Total Sample Time:	60.0 minutes	
Average Isokineticity:	101.6 %	
Flue Gas Characteristics		
Moisture:	10.73 %	
Temperature	1050.9 oC	1923.6 oF
Flow	20.7 dscm/min 0.34 dscm/sec 103.5 Acm/min	731 dscf/min 12.2 dscf/sec 3656 Acf/min
Velocity	10.509 m/sec	34.48 f/sec
Gas Analysis	9.12 % O2	11.90 % CO2
	30.269 Mol. Wt (g/gmole) Dry	28.952 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator Stack

Date: July 17/12
Run: 1 Partic/ Hg
Run Time: 15:10 - 16:12

Control Unit (Y) 0.9989
Nozzle Diameter (in.) 0.5763
Pitot Factor 0.8421
Baro. Press. (in. Hg) 29.75
Static Press. (in. H₂O) 0.04
Stack Height (ft) 50
Stack Diameter (in.) 18.0
Stack Area (sq.ft.) 1.767
Minutes Per Reading 5.0
Minutes Per Point 5.0

Gas Analysis (Vol. %):

	CO ₂	O ₂
Traverse 1	12.80	8.33
traverse 2	11.00	9.90
Average =	<u>11.90</u>	<u>9.12</u>

Condensate Collection:

Impinger 1 (grams)	78.0
Impinger 2 (grams)	22.0
Impinger 3 (grams)	3.0
Impinger 4 (grams)	2.0
Impinger 5 (grams)	1.0
Impinger 6 (grams)	8.4
Total Gain (grams)	<u>114.4</u>

Collection:

Filter (grams)	0.0044
Washings (grams)	0.0171
Impinger (grams)	0.0000
Total (grams)	<u>0.0215</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft ³)	Pitot ^P (in. H ₂ O)	Orifice ^H (in. H ₂ O)	Dry Gas Temperature		Stack	Wall	Isokin.
						Inlet (oF)	Outlet (oF)	(oF)	Dist. (in.)	(%)
		0.0	768.331							
1	1	5.0	772.700	0.100	2.25	96	95	1911	0.8	102.3
	2	10.0	777.070	0.100	2.25	98	94	1904	2.6	102.1
	3	15.0	780.950	0.080	1.81	97	94	1893	5.3	101.1
	4	20.0	785.060	0.090	2.03	96	93	1904	12.7	101.4
	5	25.0	788.690	0.070	1.55	94	90	1932	15.4	102.5
	6	30.0	792.050	0.060	1.34	93	89	1914	17.2	102.2
		0.0	792.050							
2	1	5.0	796.090	0.090	1.95	90	87	1966	0.8	102.0
	2	10.0	800.100	0.090	1.95	89	86	1946	2.6	101.1
	3	15.0	803.900	0.080	1.76	89	85	1913	5.3	100.9
	4	20.0	807.920	0.090	1.96	89	85	1933	12.7	101.1
	5	25.0	811.700	0.080	1.73	88	84	1950	15.4	101.3
	6	30.0	815.260	0.070	1.53	88	83	1917	17.2	101.4
			Average:	0.083	1.843	92.3	88.8	1923.6		101.6

Client:	Newmont, Hope Bay	Date:	July 18/12
Jobsite:	Doris Camp	Run:	2 Partic/Hg
Source:	Incinerator Stack	Run Time:	12:45 - 13:47

Particulate Concentration:	12.8 mg/dscm 2.6 mg/Acm	0.0056 gr/dscf 0.0011 gr/Acf
	10.2 mg/dscm (@ 11% O2)	0.0045 gr/dscf (@ 11% O2)
Emission Rate:	0.01 Kg/hr	0.033 lb/hr
Sample Gas Volume:	1.1932 dscm	42.138 dscf
Total Sample Time:	60.0 minutes	
Average Isokineticity:	100.2 %	
Flue Gas Characteristics		
Moisture:	9.80 %	
Temperature	1045.0 oC	1913.1 oF
Flow	19.4 dscm/min 0.32 dscm/sec 96.1 Acm/min	684 dscf/min 11.4 dscf/sec 3392 Acf/min
Velocity	9.752 m/sec	31.99 f/sec
Gas Analysis	8.45 % O2	12.58 % CO2
	30.351 Mol. Wt (g/gmole) Dry	29.140 Mol. Wt (g/gmole) Wet

*** Standard Conditions:**

Metric:	25 deg C, 101.325 kPa
Imperial:	77 deg F, 29.92 in.Hg

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator Stack

Date: July 18/12
Run: 2 Partic/Hg
Run Time: 12:45 - 13:47

Control Unit (Y) 0.9989
Nozzle Diameter (in.) 0.5763
Pitot Factor 0.8421
Baro. Press. (in. Hg) 29.55
Static Press. (in. H₂O) 0.04
Stack Height (ft) 50
Stack Diameter (in.) 18.0
Stack Area (sq.ft.) 1.767
Minutes Per Reading 5.0
Minutes Per Point 5.0

Gas Analysis (Vol. %):

	CO ₂	O ₂
Traverse 1	12.66	8.33
Traverse 2	12.50	8.57
Average =	<u>12.58</u>	<u>8.450</u>

Condensate Collection:

Impinger 1 (grams)	66.0
Impinger 2 (grams)	20.0
Impinger 3 (grams)	0.0
Impinger 4 (grams)	0.0
Impinger 5 (grams)	0.0
Impinger 6 (grams)	9.4
Total Gain (grams)	<u>95.4</u>

Collection:

Filter (grams)	0.0033
Washings (grams)	0.0120
Impinger (grams)	0.0000
Total (grams)	<u>0.0153</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft ³)	Pitot ^P (in. H ₂ O)	Orifice ^H (in. H ₂ O)	Dry Gas Temperature		Stack (°F)	Wall Dist. (in.)	Isokin. (%)
						Inlet (°F)	Outlet (°F)			
1		0.0	942.159							
	1	5.0	946.140	0.090	1.97	78	77	1897	0.8	100.1
	2	10.0	949.900	0.080	1.75	80	77	1911	2.6	100.3
	3	15.0	953.540	0.075	1.62	81	77	1930	5.3	100.6
	4	20.0	957.070	0.070	1.53	81	77	1908	12.7	100.5
	5	25.0	960.540	0.070	1.51	80	76	1940	15.4	99.6
	6	30.0	963.800	0.060	1.31	80	76	1901	17.2	100.2
2		0.0	963.800							
	1	5.0	967.700	0.085	1.87	81	76	1888	0.8	100.5
	2	10.0	971.480	0.080	1.74	82	77	1919	2.6	100.8
	3	15.0	975.000	0.070	1.53	82	77	1908	5.3	100.1
	4	20.0	978.520	0.070	1.53	83	78	1904	12.7	99.8
	5	25.0	981.880	0.065	1.40	83	79	1947	15.4	99.7
	6	30.0	984.880	0.050	1.10	84	79	1904	17.2	100.4
			Average:	0.072	1.572	81.3	77.2	1913.1		100.2

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator Stack

Date: July 19/12
Run: 3 Partic/ Hg
Run Time: 11:15 - 12:17

Particulate Concentration:	13.2 mg/dscm 2.6 mg/Acm	0.0058 gr/dscf 0.0012 gr/Acf
	10.1 mg/dscm (@ 11% O2)	0.0044 gr/dscf (@ 11% O2)
Emission Rate:	0.02 Kg/hr	0.035 lb/hr
Sample Gas Volume:	1.2548 dscm	44.313 dscf
Total Sample Time:	60.0 minutes	
Average Isokineticity:	101.7 %	
Flue Gas Characteristics		
Moisture:	10.71 %	
Temperature	1051.5 oC	1924.7 oF
Flow	20.1 dscm/min 0.33 dscm/sec 100.6 Acm/min	709 dscf/min 11.8 dscf/sec 3552 Acf/min
Velocity	10.210 m/sec	33.50 f/sec
Gas Analysis	7.90 % O2	13.00 % CO2
	30.396 Mol. Wt (g/gmole) Dry	29.069 Mol. Wt (g/gmole) Wet

*** Standard Conditions:** Metric: 25 deg C, 101.325 kPa
 Imperial: 77 deg F, 29.92 in.Hg

Client: Newmont, Hope Bay
Jobsite: Doris Camp
Source: Incinerator Stack

Date: July 19/12
Run: 3 Partic/ Hg
Run Time: 11:15 - 12:17

Control Unit (Y) 0.9989
Nozzle Diameter (in.) 0.5763
Pitot Factor 0.8421
Baro. Press. (in. Hg) 29.70
Static Press. (in. H₂O) 0.04
Stack Height (ft) 50
Stack Diameter (in.) 18.0
Stack Area (sq.ft.) 1.767
Minutes Per Reading 5.0
Minutes Per Point 5.0

Gas Analysis (Vol. %):

	CO ₂	O ₂
Traverse 1	13.00	7.90
Traverse 2	13.00	7.90
Average = <u>13.00</u>		<u>7.90</u>

Condensate Collection:

Impinger 1 (grams)	76.0
Impinger 2 (grams)	20.0
Impinger 3 (grams)	3.0
Impinger 4 (grams)	2.0
Impinger 5 (grams)	1.0
Impinger 6 (grams)	8.7
Total Gain (grams)	<u>110.7</u>

Collection:

Filter (grams)	0.0049
Washings (grams)	0.0117
Impinger (grams)	0.0000
Total (grams)	<u>0.0166</u>

Traverse	Point	Time (min.)	Dry Gas Meter (ft ³)	Pitot ^P (in. H ₂ O)	Orifice ^H (in. H ₂ O)	Dry Gas Temperature		Stack	Wall Dist.	Isokin.
						Inlet (oF)	Outlet (oF)	(oF)	(in.)	(%)
1		0.0	110.118							
	1	5.0	114.300	0.100	2.14	77	74	1940	0.8	102.2
	2	10.0	118.370	0.095	2.06	79	75	1912	2.6	101.2
	3	15.0	122.130	0.080	1.74	80	75	1904	5.3	101.5
	4	20.0	125.740	0.075	1.59	80	75	1964	12.7	101.9
	5	25.0	129.260	0.070	1.52	80	75	1918	15.4	101.8
	6	30.0	132.790	0.070	1.53	80	75	1898	17.2	101.7
2		0.0	132.790							
	1	5.0	136.780	0.090	1.96	80	75	1909	0.8	101.7
	2	10.0	140.620	0.085	1.81	81	76	1968	2.6	101.8
	3	15.0	144.240	0.075	1.61	81	76	1942	5.3	101.5
	4	20.0	147.760	0.070	1.52	81	76	1923	12.7	101.8
	5	25.0	151.290	0.070	1.53	81	76	1902	15.4	101.6
	6	30.0	154.680	0.065	1.41	81	76	1916	17.2	101.5
			Average:	0.079	1.702	80.1	75.3	1924.7		101.7

APPENDIX 2
ANALYTICAL DATA

SAMPLE RECEIPT FORM / CHEMICAL ANALYSIS FORM

FILE #: PR121371

CLIENT: A. Lanfranco & Assoc.
#101 – 9488 189 Street
Surrey, BC
V4N 4W7
Phone – 604-881-2582
Fax - 604-881-2581

RECEIVED BY: M. de Lemos

DATE/TIME: August 1, 2012 (3:45 p.m.)

CONDITION: intact, 4°C

LABELLING: all bottles, filters and XAD columns labelled

# of Samples	Sample Type	Sample (Client Codes)	Lab Codes
5	XAD, filter, rinses	Hope Bay, Doris Camp Incinerator – Blank	PR121371
5	XAD, filter, rinses	Hope Bay, Doris Camp Incinerator – Run 1	PR121372
5	XAD, filter, rinses	Hope Bay, Doris Camp Incinerator – Run 2	PR121373
5	XAD, filter, rinses	Hope Bay, Doris Camp Incinerator – Run 3	PR121374

STORAGE: XAD and filter stored at 4 °C, others stored in dark at ambient temperature

ANALYTES: HRGC/HRMS analysis for polychlorinated dibenzo(p)dioxins and dibenzofurans (PCDD/F)

SPECIAL INSTRUCTIONS: None.

METHODOLOGY


Reference Method: PCDD/F: SOP LAB01; Environment Canada 1-RM-3; EPA Method 23


Data summarized in Data Report Attached

Report sent to: Al Lanfranco

Date: August 28, 2012

Comments: Results relate only to items tested.


Patrick Pond, CTO



METHOD 23/1-RM-3 DATA REPORT

Page 3 of 8

Client: A. Lanfranco & Assoc
Client ID: Hope Bay - Run 1
PRL ID: PR121372

Sample Date: 17-Jul-12
Date Extracted: 21-Aug-12
Date Analysed: 25-Aug-12
Filter Wt.: 0.53 g

DIOXINS			
Congeners	pg	DL	# of peaks
2,3,7,8-TCDD	3.9	2	
Total TCDD	14	2	2
1,2,3,7,8-PeCDD	14	4	
Total PeCDD	110	4	2
1,2,3,4,7,8-HxCDD	13	4	
1,2,3,6,7,8-HxCDD	32	4	
1,2,3,7,8,9-HxCDD	20	4	
Total HxCDD	590	4	3
1,2,3,4,6,7,8-HpCDD	260	4	
Total HpCDD	630	4	2
OCDD	610	15	1
Total Dioxin TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
3.9	3.9
7	7
1.3	1.3
3.2	3.2
2	2
2.6	2.6
0.61	0.61
21	21

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
3.9	3.9
14	14
1.3	1.3
3.2	3.2
2	2
2.6	2.6
0.061	0.061
27	27

FURANS			
Congeners	pg	DL	# of peaks
2,3,7,8-TCDF	6.7	2	
Total TCDF	150	2	8
1,2,3,7,8-PeCDF	15	4	
2,3,4,7,8-PeCDF	52	4	
Total PeCDF	630	4	5
1,2,3,4,7,8-HxCDF	40	4	
1,2,3,6,7,8-HxCDF	42	4	
1,2,3,7,8,9-HxCDF	ND	4	
2,3,4,6,7,8-HxCDF	76	4	
Total HxCDF	450	4	6
1,2,3,4,6,7,8-HpCDF	270	4	
1,2,3,4,7,8,9-HpCDF	14	4	
Total HpCDF	300	4	2
OCDF	28	15	1
Total Furan TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
0.67	0.67
0.75	0.75
26	26
4	4
4.2	4.2
ND	0.2
7.6	7.6
2.7	2.7
0.14	0.14
0.028	0.028
46	46

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
0.67	0.67
0.75	0.75
26	26
4	4
4.2	4.2
ND	0.2
7.6	7.6
2.7	2.7
0.14	0.14
0.0028	0.0028
46	46

Total PCDD/PCDF Toxic Equivalent (pg)

67	67
----	----

73	73
----	----

Surrogate Recoveries (%)


³⁷ Cl ₄ -2,3,7,8-TCDD	91
¹³ C ₁₂ -2,3,4,7,8-PeCDF	94
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	93
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	85
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	76

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	99
¹³ C ₁₂ -1,2,3,7,8-PeCDD	102
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	96
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	110
¹³ C ₁₂ -OCDD	126
¹³ C ₁₂ -2,3,7,8-TCDF	89
¹³ C ₁₂ -1,2,3,7,8-PeCDF	91
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	95
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	99

Patrick Pond
Patrick Pond



METHOD 23/1-RM-3 DATA REPORT

Page 4 of 8

Client: A. Lanfranco & Assoc
Client ID: Hope Bay - Run 2
PRL ID: PR121373

Sample Date: 18-Jul-12
Date Extracted: 21-Aug-12
Date Analysed: 25-Aug-12
Filter Wt.: 0.47 g

DIOXINS			
Congeners	pg	DL	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	22	2	3
1,2,3,7,8-PeCDD	28	4	
Total PeCDD	160	4	5
1,2,3,4,7,8-HxCDD	35	4	
1,2,3,6,7,8-HxCDD	58	4	
1,2,3,7,8,9-HxCDD	41	4	
Total HxCDD	840	4	3
1,2,3,4,6,7,8-HpCDD	760	4	
Total HpCDD	1700	4	2
OCDD	1800	15	1
Total Dioxin TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	1
14	14
3.5	3.5
5.8	5.8
4.1	4.1
7.6	7.6
1.8	1.8
37	38

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	1
28	28
3.5	3.5
5.8	5.8
4.1	4.1
7.6	7.6
0.18	0.18
49	50

FURANS			
Congeners	pg	DL	# of peaks
2,3,7,8-TCDF	12	2	
Total TCDF	530	2	12
1,2,3,7,8-PeCDF	36	4	
2,3,4,7,8-PeCDF	110	4	
Total PeCDF	1200	4	5
1,2,3,4,7,8-HxCDF	100	4	
1,2,3,6,7,8-HxCDF	130	4	
1,2,3,7,8,9-HxCDF	36	4	
2,3,4,6,7,8-HxCDF	210	4	
Total HxCDF	1100	4	6
1,2,3,4,6,7,8-HpCDF	690	4	
1,2,3,4,7,8,9-HpCDF	54	4	
Total HpCDF	760	4	2
OCDF	130	15	1
Total Furan TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
1.2	1.2
1.8	1.8
55	55
10	10
13	13
3.6	3.6
21	21
6.9	6.9
0.54	0.54
0.13	0.13
113	113

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
1.2	1.2
1.8	1.8
55	55
10	10
13	13
3.6	3.6
21	21
6.9	6.9
0.54	0.54
0.013	0.013
113	113

Total PCDD/PCDF Toxic Equivalent (pg)

150	151
-----	-----

162	163
-----	-----

Surrogate Recoveries (%)


³⁷ Cl ₄ -2,3,7,8-TCDD	100
¹³ C ₁₂ -2,3,4,7,8-PeCDF	91
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	82
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	79
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	70

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	88
¹³ C ₁₂ -1,2,3,7,8-PeCDD	103
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	99
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	97
¹³ C ₁₂ -OCDD	114
¹³ C ₁₂ -2,3,7,8-TCDF	79
¹³ C ₁₂ -1,2,3,7,8-PeCDF	101
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	101
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	87

Patrick Pond
Patrick Pond



Pacific Rim Laboratories Inc. #103, 19575-55A Avenue, Surrey, BC V3S 8P8 CANADA

Tel: + 604.532.8711 Fax: + 604.532.8712 Email: info@pacificrimlabs.com

www.pacificrimlabs.com

Form Name: DOC22 Data Report DX 13 Feb 07 DCH

METHOD 23/1-RM-3 DATA REPORT

Page 5 of 8

Client: A. Lanfranco & Assoc
Client ID: Hope Bay - Run 3
PRL ID: PR121374

Sample Date: 18-Jul-12
Date Extracted: 21-Aug-12
Date Analysed: 25-Aug-12
Filter Wt.: 0.47 g

DIOXINS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	47	2	6
1,2,3,7,8-PeCDD	34	4	
Total PeCDD	150	4	4
1,2,3,4,7,8-HxCDD	33	4	
1,2,3,6,7,8-HxCDD	68	4	
1,2,3,7,8,9-HxCDD	47	4	
Total HxCDD	840	4	3
1,2,3,4,6,7,8-HpCDD	820	4	
Total HpCDD	1800	4	2
OCDD	2200	15	1
Total Dioxin TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	1
17	17
3.3	3.3
6.8	6.8
4.7	4.7
8.2	8.2
2.2	2.2
42	43

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	1
34	34
3.3	3.3
6.8	6.8
4.7	4.7
8.2	8.2
0.22	0.22
57	58

FURANS			
Congeners	pg	DL pg	# of peaks
2,3,7,8-TCDF	12	2	
Total TCDF	350	2	8
1,2,3,7,8-PeCDF	33	4	
2,3,4,7,8-PeCDF	130	4	
Total PeCDF	1300	4	3
1,2,3,4,7,8-HxCDF	130	4	
1,2,3,6,7,8-HxCDF	140	4	
1,2,3,7,8,9-HxCDF	93	4	
2,3,4,6,7,8-HxCDF	370	4	
Total HxCDF	1600	4	7
1,2,3,4,6,7,8-HpCDF	1200	4	
1,2,3,4,7,8,9-HpCDF	150	4	
Total HpCDF	2100	4	3
OCDF	620	15	1
Total Furan TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
1.2	1.2
1.65	1.65
65	65
13	13
14	14
9.3	9.3
37	37
12	12
1.5	1.5
0.62	0.62
155	155

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
1.2	1.2
1.65	1.65
65	65
13	13
14	14
9.3	9.3
37	37
12	12
1.5	1.5
0.062	0.062
155	155

Total PCDD/PCDF Toxic Equivalent (pg)

197 198

212 213

Surrogate Recoveries (%)


³⁷ Cl ₄ -2,3,7,8-TCDD	108
¹³ C ₁₂ -2,3,4,7,8-PeCDF	106
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	97
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	95
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	82

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	114
¹³ C ₁₂ -1,2,3,7,8-PeCDD	103
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	96
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	92
¹³ C ₁₂ -OCDD	117
¹³ C ₁₂ -2,3,7,8-TCDF	91
¹³ C ₁₂ -1,2,3,7,8-PeCDF	98
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	94
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	99

Patrick Pond
Patrick Pond



Exova
#104, 19575-55 A Ave.
Surrey, British Columbia
V3S 8P8, Canada
T: +1 (604) 514-3322
F: +1 (604) 514-3323
E: Surrey@exova.com
W: www.exova.com



Report Transmission Cover Page

Bill To: A. Lanfranco & Associates	Project:	Lot ID: 885609
Report To: A. Lanfranco & Associates	ID: Hope Bay Doris Camp	Control Number: A216646
#101, 9488 - 189 Street	Name:	Date Received: Aug 2, 2012
Surrey, BC, Canada	Location:	Date Reported: Aug 23, 2012
V4N 4W7	LSD:	Report Number: 1756187
Attn: Al LanFranco	P.O.:	
Sampled By:	Acct code:	
Company:		

Contact & Affiliation	Address	Delivery Commitments
Al LanFranco	#101, 9488 - 189 Street	On [Lot Verification] send
A. Lanfranco & Associates Inc.	Surrey, British Columbia V4N 4W7	(COA) by Email - Multiple Reports
	Phone: (604) 881-2582	On [Report Approval] send
	Fax: (604) 881-2581	(COC, Test Report) by Email - Merge Reports
	Email: lanfranco@telus.net	On [Lot Approval and Final Test Report Approval] send
		(Invoice) by Post M
		On [Lot Creation] send
		(COR) by Email - Single Report
Mark Lanfranco	#101, 9488 - 189 Street	On [Report Approval] send
A. Lanfranco & Associates Inc.	Surrey, British Columbia V4N 4W7	(COC, Test Report) by Email - Merge Reports
	Phone: (604) 881-2582	
	Fax: (604) 881-2581	
	Email: mark.lanfranco@alanfranco.com	

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential.
If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited.
If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Exova
#104, 19575-55 A Ave.
Surrey, British Columbia
V3S 8P8, Canada

T: +1 (604) 514-3322
F: +1 (604) 514-3323
E: Surrey@exova.com
W: www.exova.com

Exova




Analytical Report

Bill To: A. Lanfranco & Associates
Report To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Al LanFranco
Sampled By:
Company:

Project:
ID: Hope Bay Doris Camp
Name:
Location:
LSD:
P.O.:
Acct code:

Lot ID: **885609**
Control Number: A216646
Date Received: Aug 2, 2012
Date Reported: Aug 23, 2012
Report Number: 1756187

	Reference Number	885609-1	885609-2	885609-3	
	Sample Date		Jul 17, 2012	Jul 18, 2012	
	Sample Time		NA	NA	
	Sample Location				
	Sample Description	Metals - Blank & Beaker M9 A.L. Stack Samples	Metals - Run 1 & Beaker MB3 Stack Samples	Metals - Run 2 & Beaker MA11 Stack Samples	
	Matrix				
Analyte	Units	Results	Results	Results	Nominal Detection Limit
Air Quality Metals					
Mercury	Strong Acid Extractable ug	0.002	0.040	0.064	0.005



Analytical Report

Bill To: A. Lanfranco & Associates	Project:	Lot ID: 885609
Report To: A. Lanfranco & Associates	ID: Hope Bay Doris Camp	Control Number: A216646
#101, 9488 - 189 Street	Name:	Date Received: Aug 2, 2012
Surrey, BC, Canada	Location:	Date Reported: Aug 23, 2012
V4N 4W7	LSD:	Report Number: 1756187
Attn: Al LanFranco	P.O.:	
Sampled By:	Acct code:	
Company:		

		Reference Number	885609-4	885609-5	885609-6	
		Sample Date	Jul 19, 2012			
		Sample Time	NA			
		Sample Location				
		Sample Description	Metals - Run 3 & Beaker MW Stack Samples	Lab Blank	Hg - Blank	
		Matrix		Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Air Quality Metals						
Mercury	Strong Acid Extractable	ug	0.022	<0.002		0.005
Volume	Sample	mL			1330	
Volume	aliquot volume	mL			25	
Volume	Final	mL			40.0	
Mercury	As Tested	ug/L			<0.05	0.05
Dilution Factor	As Tested				1.00	
Mercury	Total	ug/sample			<0.11	



Analytical Report

Bill To: A. Lanfranco & Associates
Report To: A. Lanfranco & Associates
#101, 9488 - 189 Street
Surrey, BC, Canada
V4N 4W7
Attn: Al LanFranco
Sampled By:
Company:

Project:
ID: Hope Bay Doris Camp
Name:
Location:
LSD:
P.O.:
Acct code:

Lot ID: **885609**
Control Number: A216646
Date Received: Aug 2, 2012
Date Reported: Aug 23, 2012
Report Number: 1756187

		Reference Number	885609-7	885609-8	885609-9	
		Sample Date				
		Sample Time				
		Sample Location				
		Sample Description	Hg - Run 1	Hg - Run 2	Hg - Run 3 /	
		Matrix	Stack Samples	Stack Samples	Stack Samples	
Analyte		Units	Results	Results	Results	Nominal Detection Limit
Air Quality Metals						
Volume	Sample	mL	1770	1770	1750	
Volume	aliquot volume	mL	25	25	25	
Volume	Final	mL	40.0	40.0	40.0	
Mercury	As Tested	ug/L	1.57	0.26	0.08	0.05
Dilution Factor	As Tested		1.00	1.00	1.00	
Mercury	Total	ug/sample	4.4	0.74	0.22	

Approved by: 
Mathieu Simoneau
Operations Manager

Methodology and Notes

Bill To:	A. Lanfranco & Associates	Project:		Lot ID:	885609
Report To:	A. Lanfranco & Associates	ID:	Hope Bay Doris Camp	Control Number:	A216646
	#101, 9488 - 189 Street	Name:		Date Received:	Aug 2, 2012
	Surrey, BC, Canada	Location:		Date Reported:	Aug 23, 2012
	V4N 4W7	LSD:		Report Number:	1756187
Attn:	Al LanFranco	P.O.:			
Sampled By:		Acct code:			
Company:					

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Mercury in Air (Surrey)	APHA	* Cold Vapour Atomic Absorption Spectrometric Method, 3112 B	21-Aug-12	Exova Surrey
Metals (Strong Acid Leachable) in air	APHA	* Cold Vapour Atomic Absorption Spectrometric Method, 3112 B	15-Aug-12	Exova Surrey

** Reference Method Modified*

References

APHA Standard Methods for the Examination of Water and Wastewater

Comments:

Please direct any inquiries regarding this report to our Client Services group.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.

APPENDIX 3

QA/QC RESULTS

METHOD 23/1-RM-3 DATA REPORT

Page 2 of 8

Client: A. Lanfranco & Assoc
Client ID: Hope Bay - BLANK
PRL ID: PR121371

Sample Date: 18-Jul-12
Date Extracted: 21-Aug-12
Date Analysed: 25-Aug-12
Filter Wt.: 0.41 g

DIOXINS			
Congeners	pg	DL	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	ND	2	0
1,2,3,7,8-PeCDD	ND	4	
Total PeCDD	ND	4	0
1,2,3,4,7,8-HxCDD	ND	4	
1,2,3,6,7,8-HxCDD	ND	4	
1,2,3,7,8,9-HxCDD	ND	4	
Total HxCDD	ND	4	0
1,2,3,4,6,7,8-HpCDD	ND	4	
Total HpCDD	ND	4	0
OCDD	ND	15	0
Total Dioxin TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	1
ND	1
ND	0.2
ND	0.2
ND	0.2
ND	0.02
ND	0.0075
0.00	2.63

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	1
ND	2
ND	0.2
ND	0.2
ND	0.2
ND	0.02
ND	0.0075
0.00	3.62

FURANS			
Congeners	pg	DL	# of peaks
2,3,7,8-TCDF	ND	2	
Total TCDF	ND	2	0
1,2,3,7,8-PeCDF	ND	4	
2,3,4,7,8-PeCDF	ND	4	
Total PeCDF	ND	4	0
1,2,3,4,7,8-HxCDF	ND	4	
1,2,3,6,7,8-HxCDF	ND	4	
1,2,3,7,8,9-HxCDF	ND	4	
2,3,4,6,7,8-HxCDF	ND	4	
Total HxCDF	ND	4	0
1,2,3,4,6,7,8-HpCDF	ND	4	
1,2,3,4,7,8,9-HpCDF	ND	4	
Total HpCDF	ND	4	0
OCDF	ND	15	0
Total Furan TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	0.1
ND	0.1
ND	1
ND	0.2
ND	0.2
ND	0.2
ND	0.2
ND	0.02
ND	0.02
ND	0.0075
0.00	2.05

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	0.1
ND	0.1
ND	1
ND	0.2
ND	0.2
ND	0.2
ND	0.2
ND	0.02
ND	0.02
ND	0.0075
0.00	2.04

Total PCDD/PCDF Toxic Equivalent (pg)

0.00	4.68
------	------

0.00	5.66
------	------

Surrogate Recoveries (%)


³⁷ Cl ₄ -2,3,7,8-TCDD	88
¹³ C ₁₂ -2,3,4,7,8-PeCDF	100
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	75
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	72
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	73

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	101
¹³ C ₁₂ -1,2,3,7,8-PeCDD	127
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	112
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	88
¹³ C ₁₂ -OCDD	129
¹³ C ₁₂ -2,3,7,8-TCDF	83
¹³ C ₁₂ -1,2,3,7,8-PeCDF	100
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	116
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	90

Patrick Pond
Patrick Pond



METHOD 23/1-RM-3 QC REPORT - BLANK

Page 6 of 8

Client: A. Lanfranco & Assoc
Client ID: Blank
PRL ID: DF120497B

Sample Date: n/a
Date Extracted: 21-Aug-12
Date Analysed: 25-Aug-12

DIOXINS			
Congeners	pg	DL	# of peaks
2,3,7,8-TCDD	ND	2	
Total TCDD	ND	2	0
1,2,3,7,8-PeCDD	ND	4	
Total PeCDD	ND	4	0
1,2,3,4,7,8-HxCDD	ND	4	
1,2,3,6,7,8-HxCDD	ND	4	
1,2,3,7,8,9-HxCDD	ND	4	
Total HxCDD	ND	4	0
1,2,3,4,6,7,8-HpCDD	ND	4	
Total HpCDD	ND	4	0
OCDD	ND	15	0
Total Dioxin TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	1
ND	1
ND	0.2
ND	0.2
ND	0.2
ND	0.02
ND	0.0075
0.00	2.63

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	1
ND	2
ND	0.2
ND	0.2
ND	0.2
ND	0.02
ND	0.00075
0.00	3.62

FURANS			
Congeners	pg	DL	# of peaks
2,3,7,8-TCDF	ND	2	
Total TCDF	ND	2	0
1,2,3,7,8-PeCDF	ND	4	
2,3,4,7,8-PeCDF	ND	4	
Total PeCDF	ND	4	0
1,2,3,4,7,8-HxCDF	ND	4	
1,2,3,6,7,8-HxCDF	ND	4	
1,2,3,7,8,9-HxCDF	ND	4	
2,3,4,6,7,8-HxCDF	ND	4	
Total HxCDF	ND	4	0
1,2,3,4,6,7,8-HpCDF	ND	4	
1,2,3,4,7,8,9-HpCDF	ND	4	
Total HpCDF	ND	4	0
OCDF	ND	15	0
Total Furan TEQ			

I-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	0.1
ND	0.1
ND	1
ND	0.2
ND	0.2
ND	0.2
ND	0.2
ND	0.02
ND	0.02
ND	0.0075
0.00	2.05

WHO-TEQs	
(ND=0)	(ND=½DL)
pg	pg
ND	0.1
ND	0.1
ND	1
ND	0.2
ND	0.2
ND	0.2
ND	0.2
ND	0.02
ND	0.02
ND	0.00075
0.00	2.04

Total PCDD/PCDF Toxic Equivalent (pg)

0.00	4.68
------	------


0.00	5.66
------	------

ND - none detected

Internal Standards (%)

¹³ C ₁₂ -2,3,7,8-TCDD	69
¹³ C ₁₂ -1,2,3,7,8-PeCDD	76
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	68
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	63
¹³ C ₁₂ -OCDD	79
¹³ C ₁₂ -2,3,7,8-TCDF	63
¹³ C ₁₂ -1,2,3,7,8-PeCDF	61
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	52
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	65

Patrick Pond
Patrick Pond



QC REPORT - SPIKE

Client: A. Lanfranco & Assoc
 Client ID: MATRIX SPIKE
 PRL ID: DF120497S


Contact: Al Lanfranco
 Date Extracted: 21-Aug-12
 Date Analysed: 25-Aug-12

DIOXINS						Int. Std Recoveries %
Congeners	LOF	Recovery	Acceptable Recovery		Pass/Fail	
	pg	%	Min	Max		
2,3,7,8-TCDD	200	97	80	120	Pass	79
1,2,3,7,8-PeCDD	1000	90	80	120	Pass	76
1,2,3,4,7,8-HxCDD	1000	91	80	120	Pass	-
1,2,3,6,7,8-HxCDD	1000	113	80	120	Pass	77
1,2,3,7,8,9-HxCDD	1000	108	80	120	Pass	-
1,2,3,4,6,7,8-HpCDD	1000	95	80	120	Pass	81
OCDD	2000	105	80	120	Pass	86

FURANS						Int. Std Recoveries %
Congeners	LOF	Recovery	Acceptable Recovery		Pass/Fail	
	pg	%	Min	Max		
2,3,7,8-TCDF	200	102	80	120	Pass	70
1,2,3,7,8-PeCDF	1000	105	80	120	Pass	69
2,3,4,7,8-PeCDF	1000	101	80	120	Pass	-
1,2,3,4,7,8-HxCDF	1000	87	80	120	Pass	-
1,2,3,6,7,8-HxCDF	1000	113	80	120	Pass	69
1,2,3,7,8,9-HxCDF	1000	92	80	120	Pass	-
2,3,4,6,7,8-HxCDF	1000	101	80	120	Pass	-
1,2,3,4,6,7,8-HpCDF	1000	106	80	120	Pass	72
1,2,3,4,7,8,9-HpCDF	1000	80	80	120	Pass	-
OCDF	2000	82	80	120	Pass	-

LOF - Level of Fortification


 Patrick Pond



Acronyms used in reporting dioxins and furans:TCDD = Tetrachlorodibenzo-*p*-dioxin

TCDF = Tetrachlorodibenzofuran

PeCDD = Pentachlorodibenzo-*p*-dioxin

PeCDF = Pentachlorodibenzofuran

HxCDD = Hexachlorodibenzo-*p*-dioxin

HxCDF = Hexachlorodibenzofuran

HpCDD = Heptachlorodibenzo-*p*-dioxin

HpCDF = Heptachlorodibenzofuran

OCDD = Octachlorodibenzo-*p*-dioxin

OCDF = Octachlorodibenzofuran

Acceptable recoveries for surrogates**EPA Method 23**

	Min (%)	Max (%)
³⁷ Cl ₄ -2,3,7,8-TCDD	70	130
¹³ C ₁₂ -2,3,4,7,8-PeCDF	70	130
¹³ C ₁₂ -1,2,3,4,7,8-HxCDD	70	130
¹³ C ₁₂ -1,2,3,4,7,8-HxCDF	70	130
¹³ C ₁₂ -1,2,3,4,7,8,9-HpCDF	70	130

Acceptable recoveries for Internal Standards**EPA Method 23****Env. Can. 1-RM-3**

	Min (%)	Max (%)	Min (%)	Max (%)
¹³ C ₁₂ -2,3,7,8-TCDD	40	130	40	130
¹³ C ₁₂ -1,2,3,7,8-PeCDD	40	130	40	130
¹³ C ₁₂ -1,2,3,6,7,8-HxCDD	40	130	40	130
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDD	25	130	40	130
¹³ C ₁₂ -OCDD	25	130	40	130
¹³ C ₁₂ -2,3,7,8-TCDF	40	130	40	130
¹³ C ₁₂ -1,2,3,7,8-PeCDF	40	130		
¹³ C ₁₂ -1,2,3,6,7,8-HxCDF	40	130		
¹³ C ₁₂ -1,2,3,4,6,7,8-HpCDF	25	130		





Quality Control

Bill To: A. Lanfranco & Associates
 Report To: A. Lanfranco & Associates
 #101, 9488 - 189 Street
 Surrey, BC, Canada
 V4N 4W7
 Attn: Al LanFranco
 Sampled By:
 Company:

Project:
 ID: Hope Bay Doris Camp
 Name:
 Location:
 LSD:
 P.O.:
 Acct code:

Lot ID: **885609**
 Control Number: A216646
 Date Received: Aug 2, 2012
 Date Reported: Aug 23, 2012
 Report Number: 1756187

Air Quality Metals

Blanks	Units	Measured	Lower Limit	Upper Limit	Passed QC
Mercury	ug/L	0	-0.05	0.05	yes
Date Acquired: August 22, 2012					

Calibration Check	Units	% Recovery	Lower Limit	Upper Limit	Passed QC
Mercury	ug/L	88.40	80	120	yes
Date Acquired: August 15, 2012					

Certified Reference Material	Units	Measured	Target	Lower Limit	Upper Limit	Passed QC
Mercury	ug/sample	0.19	0.020	0.016	0.023	yes
Date Acquired: August 22, 2012						

Replicates	Units	Replicate 1	Replicate 2	% RSD Criteria	Absolute Criteria	Passed QC
Mercury	ug/L	0.26	0.28	30	0.05	yes
Date Acquired: August 22, 2012						

Matrix Spike	Units	% Recovery	Lower Limit	Upper Limit	Passed QC
Mercury	ug/L	116	85	115	yes
Date Acquired: August 22, 2012					



COC



Note: Proper completion of this form is required in order to proceed with analysis
See reverse for your nearest Exova location and proper sampling protocol

www.exova.com

Billing Address:		Copy of Report:		Copy of Report To:		Copy of Invoice:	
Company:				Company:			
Address:	A. LANFRANCO + ASSOC QA/QC Report			Address:		Send invoice to this address for approval	
Attention:		Report Result:		Attention:		Report Result:	
Phone:	Lanfranco @ telus.net	e-mail		Phone:		e-mail	
Fax:		Results Online		Fax:		Results Online	
Cell:		Fax		Cell:		Fax	
e-mail:	604-881-2582	Mail		e-mail:		Mail	

Information to be included on Report and Invoice Project ID: <i>Hope Bay Doris Camp</i> Project Name: Project Location: Legal Location: PO#: Proj. Acct. Code: Agreement ID:	PRIORITY Please contact laboratory prior to submitting any RUSH samples. Upon filling out this section, client accepts that surcharges will be applied to this analysis. If not all samples require RUSH, please indicate in special instructions.	Sample Custody (Please Print) Sampled by: Company: _____ Signature: _____
	Date Required: _____ Signature: _____	I authorize Exova to proceed with the work indicated on this form: RECEIVED Date: _____ Initial: _____ Received by: <i>Aurko</i> Sample Temp. _____ Waybill #: _____ Date: _____ Company: _____ Time: _____

Special Instructions / Comments

Special Instructions / Comments
Please Report $\mu\text{g/l}$ per sample
*Combine 2 Bottles for each Analysis!!

Please indicate which regulations you are required to meet:

☐ Health Canada Drinking Water Quality

Alberta Tier 1

Other:

[illegible]

NOTE: All hazardous samples must be labeled according to WHMIS guidelines.

Page of

APPENDIX 4
FIELD DATA SHEETS
and PROCESS DATA

capacity = 0-5% Initial Charge

5469

PLANT		NEW MONT - DOERS CAMP		PROBE TIP DIAMETER, IN.		IMPINGER		INITIAL		FINAL		TOTAL GAIN	
RUN No		Dioxin 1		PROBE LENGTH, FT / Cp		VOLUMES		(mL)		(mL)		(mL)	
LOCATION		INCINERATOR STACK		FILTER NUMBER		Imp. # 1		0		250		280	
DATE		July 19 2012		STATIC PRESSURE, IN. H ₂ O		Imp. # 2		100		144		44	
OPERATOR		John Burch		STACK DIAMETER		Imp. # 3		0					
CONTROL UNIT		0.9929 / 0.7310		STACK HEIGHT		Imp. # 4		3EL					
BAROMETRIC PRESSURE, IN. Hg		29.75		INITIAL LEAK TEST									
ASSUMED MOISTURE, Bw		12%		FINAL LEAK TEST									
Point	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature °F		Impinger Exit	Temperature °F Stack	CO ₂ Vol. %	O ₂ Vol. %
					Inlet °F	Outlet °F		Box	Probe				
①	LEAK	635.386	KAD										
	11:40	635.559	48	1.78	81	81	4	250	57AC	50	1826		
	40	638.029	48	1.78	81	81	4	250	57AC		1826		
	80	641.761	48	1.88	84	81	4	250			1916		
②	16:00	644.783	50	1.72	85	81	4	228	242		1890		
	20:00	647.808	50	1.72	86	81	4	226	242		1890		
	24:00	650.850	50	1.74	87	82	4	224	246		1873	12.0	8.0
	28:00	653.879	50	1.72	88	82	4	223	246		1896		
③	32:00	656.914	51	1.72	90	84	4	221	248		1904		
	36:00	659.607	51	1.42	92	86	4	221	248		1857		
	40:00	662.441	51	1.43	91	86	4	224	248		1823		
	44:00	665.613	51	1.25	92	86	4	225	247		1828		
④	48:00	667.800	51	1.43	93	88	4	225	252		1830		
	52:00	670.54	52	1.40	94	87	4	226	252		1896		
	56:00	673.11	52	1.23	96	90	4	226	252		1891		
	60:00	675.52	52	1.07	97	92	4	228	250		1844	11.5	8.5
⑤	64:00	677.74	52	1.08	98	93	4	228	250		1840		
	68:00	680.56	52	1.27	99	93	4	230	254		1819		
	72:00	683.79	52	1.08	100	94	4	230	252		1832		
	76:00	685.42	53	1.08	101	95	4	230	252		1840		
⑥	80:00	687.85	53	1.09	101	96	4	232	255		1830		
	84:00	690.48	53	1.09	101	97	4	240	255		1842		
	88:00	692.67	53	1.06	102	97	4	240	253		1887		
	92:00	695.07	53	1.05	102	97	4	242	253		1911	13.0	7.0
	96:00	697.49	53	1.06	102	97	4	238	250		1905	12.2	6.48
		697.72	53	1.08	103	98	4	238	246		1853		

NOVA 1.8 1.7 8.8 1.8 5.4 6.8 8.7 4.4 3.1 9.1 6.8 4.3

5-H-

PLANT		NEWMONT - DOER'S CAMP		PROBE TIP DIAMETER, IN.		IMPINGER		INITIAL		FINAL		TOTAL GAIN	
RUN No		DIXON-1 (CONT)		PROBE LENGTH, FT / Cp		VOLUMES		(mL)		(mL)		(mL)	
LOCATION		MCINEEGOR STAK		FILTER NUMBER		Imp. # 1							
DATE		July 19 2012		STATIC PRESSURE, IN. H ₂ O		Imp. # 2							
OPERATOR		John Buech		STACK DIAMETER		Imp. # 3							
CONTROL UNIT / Y				STACK HEIGHT		Imp. # 4							
BAROMETRIC PRESSURE, IN. Hg				INITIAL LEAK TEST									
ASSUMED MOISTURE, Bw				FINAL LEAK TEST									
Point	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature °F		Impinger Exit	Temperature °F Stack	Fyrites	
					Inlet °F	Outlet °F		Box	Probe			CO ₂ Vol. %	O ₂ Vol. %
①	4.0	697.92	56	1.08	102	97	4	232	252	50	1847		
	8.0	702.35	56	1.08	101	97	4	238	251		1858		
	12.0	707.37	56	1.25	101	97	4	236	251		1881		
	16.0	709.91	56	1.26	102	97	5	236	254		1864	14.0	6.0
②	20.0	712.61	56	1.24	102	97	5	236	255		1865		
	24.0	715.21	56	1.24	102	97	5	232	252		1895		
	28.0	718.00	55	1.43	102	97	5	230	249		1873		
	32.0	730.77	55	1.41	100	97	5	230	249		1903		
③	36.0	723.85	55	1.76	98	95	5	230	248		1913		
	40.0	726.76	55	1.79	97	94	5	226	248		1862		
	44.0	729.87	54	1.57	96	94	6	226	244		1913	9.0	11.0
	48.0	732.76	54	1.56	95	92	6	225	246		1929		
④	52.0	735.64	54	1.55	95	92	6	228	248		1945		
	56.0	738.55	54	1.58	94	91	6	232	256		1891		
	60.0	741.47	54	1.58	94	91	6	234	256		1886		
	64.0	744.35	54	1.54	95	91	6	233	256		1947		
⑤	68.0	747.27	55	1.58	97	93	6	237	260		1898	10.0	10.0
	72.0	750.21	55	1.60	98	94	6	240	258		1878	11.0	9.0
	76.0	753.12	55	1.56	98	94	6	240	258		1930		
	80.0	756.05	56	1.58	98	94	6	240	260		1897		
⑥	84.0	758.78	56	1.38	98	94	6	237	256		1943		
	88.0	761.54	56	1.40	99	95	6	236	251		1908		
	92.0	764.28	56	1.38	99	95	6	232	254		1940		
	96.0	767.04	56	1.40	100	96	6	231	250		1912		
14:58													
LEAK													

No. 4
 0.2
 4.0
 4.7
 10.5
 9.7
 10.7
 4.5
 10.0
 10.7
 4.4
 4.5
 10.5

5H₂

PLANT	Newmont - Jones Camp			PROBE TIP DIAMETER, IN.	0.5467			IMPINGER	INITIAL	FINAL	TOTAL GAIN
RUN No	Doxin 2			PROBE LENGTH, FT / Cp	0.8421			VOLUMES	(mL)	(mL)	(mL)
LOCATION	INCINERATOR			FILTER NUMBER				Imp. # 1	0	250	250
DATE	July 18, 2012			STATIC PRESSURE, IN. H ₂ O	0.04			Imp. # 2	100	172	72
OPERATOR	John Burch			STACK DIAMETER	18.0			Imp. # 3	0		
CONTROL UNIT / Y	0.9289 / 0.7312			STACK HEIGHT	50.0			Imp. # 4	654		
BAROMETRIC PRESSURE, IN. Hg				29.55							
ASSUMED MOISTURE, Bw				11 %							
INITIAL LEAK TEST				.010 @ 15"							
FINAL LEAK TEST											

Point	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp. °F		Pump Vac. IN. Hg Gauge	Temperature °F		Temperature °F		Fyrites	
					Inlet °F	Outlet °F		Box	Probe	Impinger Exit	Stack	CO ₂ Vol. %	O ₂ Vol. %
①	9:06 (0.40)	816.328	XAD	1.42	71	71	3	230	250	30	1816		
	8.0	822.01	49	1.67	72	70	3	232	250		1936		
	12.0	825.02	49	1.74	72	70	3	232	248		1863		
	16.0	827.86	49	1.55	73	70	3	234	248		1895	10.0	60.0
	20.0	830.83	50	1.70	73	70	4	234	249		1922		
②	24.0	833.69	50	1.58	74	70	4	231	254		1849		
	28.0	836.55	50	1.57	74	70	4	231	255		1863		
	32.0	839.42	50	1.57	74	70	4	230	255		1853	14.0	6.0
	36.0	842.28	50	1.57	74	70	4	228	256		1853		
	40.0	845.30	50	1.75	75	71	5	226	256		1945		
③	44.0	847.95	50	1.35	75	71	5	226	256		1968		
	48.0	850.57	50	1.35	75	71	5	228	254		1943		
	52.0	853.24	50	1.36	75	72	6	226	255		1918	14.0	6.0
	56.0	855.91	50	1.04	75	72	6	224	256		1898		
	60.0	858.23	50	1.04	75	72	6	224	255		1863		
④	64.0	860.57	50	1.20	76	72	6	222	255		1908		
	68.0	863.08	51	1.04	76	72	6	222	255		1845	13.0	7.0
	72.0	865.43	51	1.04	76	72	6	222	255		1922		
	76.0	867.74	51	1.02	76	72	6	220	262		1860		
	80.0	870.08	50	1.05	76	72	6	220	262		1853		
⑤	84.0	872.43	50	1.05	77	73	6	221	260		1853		
	88.0	874.78	50	1.05	77	73	6	221	259		1857	11.0	7.0
	92.0	877.13	50	1.05	77	73	6	218	259		1849	12.4	7.7
	96.0	879.45	52	1.03	77	74	6	218	258		1914		

NOVA
0.2
1.5
1.1
7.7
2.6
9.2
4.0
3.5
9.5
3.8
6.0
8.5
4.8

PLANT *Newmont - Dore's Camp*

RUN No	D1041N 2- CORR
--------	----------------

LOCATION	WATER
----------	-------

DATE July 18, 2012

OPERATOR

CONTROL UNIT / Y

BAROMETRIC PRESSURE. IN. Hg.

ASSUMED MOISTURE B.W.	
-----------------------	--

[illegible]

54

PLANT NEWMONT - DOWS CAMP

PROBE TIP DIAMETER, IN.	0.5467	3X	IMPINGER	INITIAL	FINAL	TOTAL GAIN
PROBE LENGTH, FT/Cp	0.8421		VOLUMES	(mL)	(mL)	(mL)
FILTER NUMBER			Imp. # 1	0	250	
			Imp. # 2	100	172	
			Imp. # 3	0		
			Imp. # 4			
STATIC PRESSURE, IN. H ₂ O	0.04					
STACK DIAMETER	18.0					
STACK HEIGHT	50.0					
INITIAL LEAK TEST	0.06 @ 15"					
FINAL LEAK TEST	0.10 @ 15"					
BAROMETRIC PRESSURE, IN. Hg	29.70					
ASSUMED MOISTURE, Bw	11%					

Point	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp.		Pump Vac. IN. Hg Gauge	Temperature °F		Temperature °F	Impinger Exit	Fyrites	
					Inlet °F	Outlet °F		Box	Probe	Stack		CO ₂ Vol. %	O ₂ Vol. %
①	07:48	985.10	XAD	1.52	70	70	3	230	252	1944	50		
	4.0	985.534	55	1.52	70	69	3	232	256	1920		16.0	4.0
	8.0	991.11	47	1.57	71	69	3	232	256	1846			
	12.0	993.55	48	1.57	71	69	3	234	256	1910			
	16.0	996.74	46	1.52	72	68	3	230	252	1930			
②	20.0	998.55	46	1.53	72	68	3	230	252	1900		14.0	6.0
	24.0	1002.35	46	1.53	72	69	3	228	250	1910			
	28.0	4.99	46	1.36	73	69	4	228	250	1908			
	32.0	7.66	46	1.35	74	69	4	226	248	1859		12.0	8.0
	36.0	10.29	47	1.35	74	70	4	221	248	1858		9.0	11.0
③	40.0	12.97	47	1.35	74	70	4	221	246	1915			
	44.0	15.78	47	1.33	74	70	4	221	244	1842			
	48.0	18.63	48	1.38	75	70	4	248	246	1930			
	52.0	21.27	48	1.35	75	71	4	240	252	1882		12.0	8.0
	56.0	23.94	48	1.38	75	71	4	249	256	1915			
④	60.0	26.59	48	1.36	76	71	4	252	256	1868			
	64.0	29.25	48	1.37	76	71	4	252	258	1809			
	68.0	31.76	47	1.22	76	72	4	254	258	1868			
	72.0	34.25	47	1.20	76	72	4	254	255	1889			
	76.0	36.75	47	1.21	76	72	4	250	256	1898			
⑤	80.0	39.24	47	1.20	76	72	4	252	256	1858			
	84.0	41.76	47	1.22	76	72	4	256	256	1950		16.0	4.0
	88.0	44.23	47	1.18	76	72	4	248	258	1921		13.7	6.8
	92.0	46.53	47	1.02	76	72	4	240	260	1867			
	96.0	48.85	47	1.04	76	72	4	236	260				

NOVA
0.2
2.5
4.3
4.6
4.8
6.2
5.0
5.5
8.2
3.3
10.0
0.1
0.8
3.2
3.8
2.0
2.7
3.7
10.2
4.6

J.H.

PLANT	Newmont		Hope Bay		PROBE TIP DIAMETER, IN.		0.5763		IMPINGER		INITIAL		FINAL		TOTAL GAIN	
RUN No	2		P/M Metals		PROBE LENGTH, FT / Cp		3'		VOLUMES		(mL)		(mL)		(mL)	
LOCATION	Nacis Camp Incinerator				FILTER NUMBER				Imp. # 1		100		100		66	
DATE	July 18, 2012								Imp. # 2		100		120		20	
OPERATOR	L.A.								Imp. # 3		-		-		0	
CONTROL UNIT	Y 310 621C		0.9989		STATIC PRESSURE, IN. H ₂ O		0.04		Imp. # 4		100		100		0	
BAROMETRIC PRESSURE, IN. Hg	29.55		K ₂ = 0.736		STACK DIAMETER		18"									
ASSUMED MOISTURE, Bw	10%				STACK HEIGHT											
INITIAL LEAK TEST	0.004 @ 15"				INITIAL LEAK TEST											
FINAL LEAK TEST	0.005 @ 15"				FINAL LEAK TEST											
Point	Clock Time	Dry Gas Meter Ft ³	Pitot IN. H ₂ O ΔP	Orifice ΔH IN. H ₂ O	Dry Gas Temp. Inlet -°F	Dry Gas Temp. Outlet °F	Pump Vac. IN. Hg Gauge	Box	Probe	Impinger Exit	Stack	CO ₂ Vol. %	O ₂ Vol. %	Fyrites		
1	12:45	942.159	0.090	1.97	78	77	2	252	253	52	1897					
2		946.14	0.090	1.75	80	77	2	256	251	52	1911					
3		949.90	0.073	1.63	81	77	2	254	252	52	1930					
4		953.54	0.070	1.53	81	77	2	255	253	51	1908					
5		957.07	0.070	1.31	80	76	2	253	254	51	1940					
6		960.54	0.060	1.31	80	76	2	252	257		1901					
1		963.80														
2		967.70	0.083	1.87	81	76	2	254	255	51	1888					
3		971.48	0.090	1.74	82	77	2	252	254	51	1919					
4		975.00	0.070	1.53	82	77	2	253	252	52	1908					
5		978.52	0.072	1.53	83	78	2	253	254	52	1904					
6		981.88	0.065	1.40	83	79	2	252	251	52	1947					
13:47		984.88	0.050	1.10	84	79		251	250		1904					

Nova
 0.2
 10.1
 4.8
 10.1
 10.4
 10.2
 5.1

Nova
0^a
6.2

10.3
~~4.9~~
10.2

10.3
4.8
6.1
10.4

Nova
0 ^a
6.2
10.3
4.9
10.2
10.3
4.8
6.1
10.4

Name of Operator (Print clearly): HARRY

Date: July 17/12

Operator's Signature: [Signature]

FIRST BATCH OF THE DAY

Batch Preparation / Weighing

# of BAGS	Paper & Cardboard (lbs.)	# of BAGS	Kitchen Waste (lbs.)	# of BAGS	STP (lbs.)
6	45	12	245	4	65

- ☒ Total Amount of Waste added 355 (lbs.) Time: 9:50
- ☒ Set burner timer to 12 hrs and **Press Start button**. Time: 10:00
- ☒ Confirm all **3** burner blowers are working. (check for vibration)
- ☒ **Secondary chamber burner** fired (Climb up and Check for green light on burner). Time: 10:10
- ☒ **2 Primary chamber burners** fired (check for green light on burners). Time: 11:12
- ☒ **Flame port blower** fired.
- ☒ Black smoke noticed (Yes / No) NO. (check every 5 minutes for half an hour)
- ☐ Rake every hour for first burn of the day. Note below in comment section.

Take reading of Temperature of primary and secondary Chambers every **HALF HOUR** after primary was fired.

Time	Primary chamber temperature	Secondary chamber temperature	Comments / RAKING?
11:30	530	1185	
12:00	619	1169	
12:30	600	1150	
1:00	596	1120	
1:30	610	1119	

- ☒ Primary chamber temperature was set to 0 C at 5:00

Any Other Observations:

Name of Operator (Print clearly): HARJOT BRAR

Date: July 18/19

Operator's Signature: [Signature]

FIRST BATCH OF THE DAY

Batch Preparation / Weighing

# of BAGS	Paper & Cardboard (lbs.)	# of BAGS	Kitchen Waste (lbs.)	# of BAGS	STP (lbs.)
8	63	14	253	5	79

☒ Total Amount of Waste added 385 (lbs.) Time: 7:00

☒ Set burner timer to 12 hrs and **Press Start button**. Time: 7:25

☐ Confirm all **3** burner blowers are working. (check for vibration)

☐ **Secondary chamber burner** fired (Climb up and Check for green light on burner). Time: 7:35

☒ **2 Primary chamber burners** fired (check for green light on burners). Time: 8:45

☒ **Flame port blower** fired.

☐ Black smoke noticed (Yes / No) No. (check every 5 minutes for half an hour)

☐ Rake every hour for first burn of the day. Note below in comment section.

Take reading of Temperature of primary and secondary Chambers every **HALF HOUR** after primary was fired.

Time	Primary chamber temperature	Secondary chamber temperature	Comments / RAKING?
9:15	600	1190	
9:45	595	1190	
10:15	607	1158	
10:45	601	1115	
11:15	6012	1137	
11:45	594	1084	
1:50	600	1119	Raked

☐ Primary chamber temperature was set to 0 C at 3:00

Any Other Observations:

Operator's Worksheet

Name of Operator (Print clearly): HANSON BRAR

Date: July 19/12

Operator's Signature: H. Brar

FIRST BATCH OF THE DAY

Batch Preparation / Weighing

# of BAGS	Paper & Cardboard (lbs.)	# of BAGS	Kitchen Waste (lbs.)	# of BAGS	STP (lbs.)
<u>20</u>	<u>48</u>	<u>13</u>	<u>247</u>	<u>5</u>	<u>62</u>

☒ Total Amount of Waste added 357 (lbs.) Time: 5:55

☒ Set burner timer to 12 hrs and **Press Start button**. Time: 5:57

☒ Confirm all **3** burner blowers are working. (check for vibration)

☒ **Secondary chamber burner** fired (Climb up and Check for green light on burner). Time: 6:07

☐ **2 Primary chamber burners** fired (check for green light on burners). Time: 7:27

☒ **Flame port blower** fired.

☐ Black smoke noticed (Yes / No) No. (check every 5 minutes for half an hour)

☐ Rake every hour for first burn of the day. Note below in comment section.

Take reading of Temperature of primary and secondary Chambers every **HALF HOUR** after primary was fired.

Time	Primary chamber temperature	Secondary chamber temperature	Comments / RAKING?
<u>8:00</u>	<u>580</u>	<u>1125</u>	
<u>8:30</u>	<u>613</u>	<u>1137</u>	
<u>9:00</u>	<u>614</u>	<u>1117</u>	
<u>9:30</u>	<u>590</u>	<u>1109</u>	
<u>10:00</u>	<u>609</u>	<u>1105</u>	
<u>10:30</u>	<u>587</u>	<u>1092</u>	
<u>11:30</u>	<u>600</u>	<u>1115</u>	

☐ Primary chamber temperature was set to 0 C at _____.

Any Other Observations:

APPENDIX 5
CALIBRATION DATA

S - TYPE PITOT CALIBRATION FORM

Date: June 27 2012
 Technician: CL
 Pitot I.D.: A.L. C - 39
 Nozzle I.D.: None

Approx. Wind Vel.	Pitot Vel. Pressure	S-Type Pitot Vel. Press.			Pitot Coefficient
Ft/sec.	Δ Pref.	Cref. SQRT(Δ Pref.)	Δ Ps	SQRT(Δ Ps)	Cp
10.00	0.050	0.22137	0.070	0.26458	0.83670
20.00	0.230	0.47479	0.320	0.56569	0.83931
30.00	0.350	0.58569	0.480	0.69282	0.84537
40.00	0.820	0.89648	1.120	1.05830	0.84710

AVERAGE Cp = 0.8421

Calibration Equation: $C_p = C_{ref} \cdot \text{SQRT}(\Delta P_{ref}/\Delta P_s)$

Cref. = 0.99

Where:


Δ Pref. = velocity pressure measured by reference pitot

Cref. = coefficient of reference pitot

Δ Ps = velocity pressure measured by S - type pitot

Cp = coefficient of S - type pitot

AUTHORIZATION


 Calibration Section

EPA Method 5
Meter Box Calibration
English Meter Box Units, English K' Factor

Model #: N31
Serial #: 31D 621C

Date: 06-Jan-12
Barometric Pressure: 30.23 (in. Hg)
Theoretical Critical Vacuum: 14.26 (in. Hg)

!!!!!!!
IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³/3*(deg R)^{0.5}/((in.Hg)^{0.5}*(min)).
!!!!!!!

----- DRY GAS METER READINGS -----										-CRITICAL ORIFICE READINGS-				
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps. Inlet (deg F)	Initial Temps. Outlet (deg F)	Final Temps. Inlet (deg F)	Final Temps. Outlet (deg F)	Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	Initial (deg F)	Final (deg F)	Average (deg F)
0.28	15.00	652.800	657.596	4.796	72.0	71.0	73.0	73.0	40	0.2408	21.0	64.0	63.0	63.5
0.74	16.00	642.000	649.572	7.572	74.0	72.0	73.0	72.0	48	0.3560	18.0	64.0	65.0	64.5
1.14	15.00	630.403	639.518	9.115	72.0	69.0	74.0	71.0	55	0.4806	16.0	63.0	63.0	63.0
1.90	13.00	616.800	626.470	9.670	65.0	61.0	71.0	66.0	63	0.5956	13.5	64.0	63.0	63.5

***** RESULTS *****														
-- DRY GAS METER --					ORIFICE					-- DRY GAS METER --				
VOLUME CORRECTED	VOLUME Vm(std)	VOLUME Corrected	VOLUME Vc(std)	VOLUME NOMINAL Vn	CALIBRATION FACTOR Y					CALIBRATION FACTOR dh@				
(cu ft)	(liters)	(cu ft)	(liters)	(cu ft)	Value (number)	Variation (number)	Value (in H2O)	Variation (in H2O)	Ko (value)	Value (in H2O)	Variation (in H2O)	Value (mm H2O)	Variation (in H2O)	Ko (value)
4.808	136.2	4.772	135.2	4.685	0.993	-0.006	1.560	-0.177	0.774	1.560	-0.177	39.83	-0.177	0.774
7.593	215.0	7.519	212.9	7.395	0.990	-0.009	1.890	0.153	0.705	1.890	0.153	48.01	0.153	0.705
9.170	259.7	9.133	258.6	8.957	0.986	-0.003	1.741	0.004	0.732	1.741	0.004	44.22	0.004	0.732
10.057	284.8	10.230	288.7	10.043	1.017	0.018	1.759	0.021	0.713	1.759	0.021	44.67	0.021	0.713
Average Y----->					0.9989					Average dh@----->				
										1.74				
										44.1				
										Average Ko----->				
										0.731				


TEMPERATURE CALIBRATION			
Calibration Standard ----->	Omega Model CL23A S/N:T-218768		
Reference Temperature Set-Point (deg F)	Temperature Device Reading (deg F)	Results Variation (deg F)	Percent of Absolute
32	33	1	0.20%
100	101	1	0.18%
500	500	0	0.00%
800	799	-1	-0.08%
1000	1000	0	0.00%

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ± 0.02 .
For Orifice Calibration Factor dh@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is ± 0.2 .
For Temperature Device, the reading must be within 1.5% of certified calibration standard (absolute temperature) to be acceptable.

SIGNED: *Youn Hwang* for

Date: *Jan 6/12*

Calibration Certificate

Date: Feb.3, 2012
Technician: M. Lanfranco
Signature: 
Instrument:
Calibrated: NOVA (New)

Nox

Gas	Instrument Reading	Certified Value	% Calibration Error
Zero	2	0	n/a
1 Gas			
2 Gas			
3 Gas			
4 Gas	415	417	-0.4
5 Gas			
Low Nox			
High Nox			

Performance Specification: +/- 5% of Certified Gas Value

O2

Gas	Instrument Reading	Certified Value	% Calibration Error
Zero	0.1	0.0	n/a
O2/CO2	10.9	10.88	0.2
Ambient	20.9	20.9	0.0

Performance Specification: +/- 0.5% O2 AD

CO

Gas	Instrument Reading	Certified Value	% Calibration Error
Zero	2	0	n/a
1 Gas			
2 Gas			
3 Gas	448	468	-4.3
4 Gas			
5 Gas			

Performance Specification: +/- 5% of Certified Gas Value

(c) Average = average of D1, D2 and D3