

Hope Bay Mining Ltd.
Suite 300
889 Harbourside Drive
North Vancouver, BC
V7P 3S1
Phone 604 985 - 2572
Facsimile 604 980 - 0731
www.newmont.com

June 22, 2010

Technical Advisor – Mining Nunavut Water Board P.O. Box 119 Gjoa Haven, NU X0B 1J0

Re: May 2010 – Monthly Monitoring Report for Water License 2AM-DOH0713

Following is the monthly report for May 2010 as required under Doris Water License No/Type 2AM-DOH0713 Type "A". The license was issued on September 19, 2007 and will expire on September 30, 2013. The water license is specific for Mining and Milling and associated uses. The quantity of water usages shall not exceed 480,000 cubic meters annually.

This monthly report provides information on Part D (Conditions Applying to Construction) Item 19, Part E (Conditions applying to Water Use) Item 1, Part G (Conditions Applying to Waste Management and Waste Management Plans) Item 3 and 22 (e), and Part H (Conditions Applying to Modifications). The report also contains the relevant monitoring requirements as set out in Schedule J of the licence, plus additional requirements from INAC.

Other conditions stipulated in the license refer specially to mining and milling processes. These facilities have not been constructed at this time, due to the deferral of the Doris North Project by Hope Bay Mining Ltd. (HBML) and therefore, no monitoring has taken place to comply with conditions. The Nunavut Water Board (NWB) was notified of HBML's intent to start the construction associated with the Doris North mining and milling facilities on October 29, 2009. As construction activities begin, the required monitoring programs will be implemented.

1. Part D: Item 19 Conditions Applying to Construction

No surface runoff from construction occurred for sampling during the period.

2. Part E: Item 1. Conditions Applying to Water Use

a. Water Usage

During the month of May 2010, Doris Camp was in operation for the entire month with water extraction occurring from Doris Lake via SNP Station ST-7, or by direct extraction by water truck from Doris and Patch Lakes, to build ice road infrastructure to other locations within the project area. Water usage was in compliance with the licence for the month of May. Total water usage is detailed in Table 1.

Parameters	Doris Camp Domestic and Other Use	2АМ-DОН0713
Water Source	Doris Lake/Patch Lake	Compliance Values
Geographical Coordinates	On file	Part E: Item 1
Annual Cumulative	13,751.39	480,000 m ³ Annually
Monthly Cumulative	828.68	$40,000 \text{ m}^3 \text{ monthly}$
Volume Average (Daily)	26.73	1,333 m ³ daily
Maximum	37.09	1,333 m ³ daily
3.51 1	0.4 - 4.4	1 222 3 1 11

Table 1. Water Usage for Domestic Camp Use, and Other Uses* in m³, May 2010

b. Water Quality Monitoring: Schedule J and Special Requirements

Monthly compliance samples in accordance with Schedule J requirements of the licence were taken from monitoring station ST-7 on May 07/10 Sampling for cyanide is not presently being conducted at this monitoring station as no processes are occurring to generate cyanide at site. Results of the May monitoring are provided in Table 3.

Table 3. Monthly	y Compliance	Sample Results for	· SNP Monitoring	Station ST-7,	May 2010
------------------	--------------	--------------------	------------------	---------------	----------

Parameter/SNP Sites	ST-7	Doris: 2AM-DOH0713	
ALS Lab Reference #	L884422-1	Maximum Average	
ALS Lab Reference #	L004422-1	Concentration (mg/L)	
Field Sample Details	ST-7	Part G: Item 3	
Sample Date/Time	May 07/10 @ 7:00am	No Requirement Specified	
BOD	<2.0	-	
Fecal Coliforms	<1	-	
Total Oil and Grease	<1	-	
pН	7.57	-	
TSS	<3.0	-	
Ammonia-N	< 0.050	-	
Nitrate-N	< 0.050	-	
Nitrite-N	< 0.050	-	
Orthophosphate-P	< 0.010	-	
Total Phosphate (as P)	< 0.020	-	
Total Aluminium	< 0.010	-	
Total Arsenic	0.00058	-	
Total Cadmium	< 0.000050	-	
Total Copper	0.0022	-	
Total Chromium	< 0.0050	-	
Total Iron	0.021	-	
Total Mercury	< 0.00010	-	
Total Molybdenum	< 0.0050	-	
Total Nickel	< 0.0020	-	
Total Lead	< 0.00010	-	
Total Selenium	< 0.00040	-	
Total Silver	< 0.00010	-	
Total Thallium	< 0.00010	-	
Total Zinc	< 0.0040	-	

^{*} Other uses include core cutting saws, fire truck filling, and Ice Road construction

Results of the technical review in April 2009 by INAC with regards to the Doris Camp planned water system modifications included recommendations for monthly reporting of sample analysis of the blue-green algae in the raw water from Doris Lake. Results of this sampling for May are provided in Table 4.

Table 4. Sampling Results for Blue-green Algae, May 2010

Parameter/SNP Site	ST-7
ALS Lab Reference #	L884414-1
Field Sample Details	PWQ-DC # 1
Sample Date/Time	May 6/10 @ 1600 hrs
Blue-green Algae	89, 700 cells/mL

3. Part G: Item 3(b) Conditions Applying to Waste Management and Waste Management Plans.

During the month of May 2010, water samples were collected once at monitoring station ST-8. Station ST-9 could not be sampled due to frozen conditions.

Sampling point ST-8 is located within the Doris Camp Sewage Treatment Plant, which is located directly east of the main building complex. Effluent samples were collected from a tap on the discharge line to the tundra at a location installed after the addition of a UV disinfection system (ST-8A). The data reported for May at SNP ST-8A is within compliance values for all parameters with the exception of pH which was recorded at 5.92.

HBML acknowledges that discharge point ST-8 was originally intended to be a temporary discharge point that would be moved to the tailings storage facility after such a facility was constructed. HBML has deferred the construction of the tailings storage facility until a production decision is made by HBML. HBML proposes that the ST-8 discharge point remain until the tailings storage is constructed. To alleviate any risks associated with ponding and permafrost degradation HBML has proposed to build a rock diffuser during 2010. Designs will be prepared by a certified engineer and supplied prior to construction.

Table 5: Water Quality Data Summary for Monitoring Station ST-8A and ST-9, May 2010

Parameter/SNP Sites	ST-8A	ST-9	Doris: 2AM-DOH0713
ALS Lab Reference #	L884422-2		Maximum Average
ALS Lab Reference #	L004422-2		Concentration (mg/L)
Field Sample Details	ST-8A	ST-9	Part G: Item 3
Sample Date/Time	May 7/10 @ 07:00am	-	(b)
BOD_5	3.8	-	80 mg/L
TSS (mg/L)	<3.0	-	100 mg/L
Fecal Coliform	<1.0	-	10,000 CFU/100mL
pH (pH unit)	5.92	-	Between 6-9
Oil & Grease (Visibility)	No visible sheen	-	No Visible Sheen
Oil & Grease (mg/L)	<1.0	-	5

4. Part G: Item 22 (e) Conditions Applying to Waste Management and Waste Management Plans.

During the month of May 2010, no discharge of accumulated water occurred at monitoring station ST-6 in the Robert's Bay Fuel Storage and Containment Area.

No monitoring was conducted at ST-5 (bulk fuel storage facility) at Doris Camp as there was no accumulation of water and no discharges occurred.

Part G: Conditions applying to Waste Management and Waste Management Plans (Item 3b)

a. Part G: Item 3e (Treated Sewage Effluent Release in cubic meters)

Table 5 shows treated effluent released from the Doris Membrane Plant at SNP ST-8.

Table 5: Treated Sewage Effluent release in cubic meters (m³) through Doris Membrane Plant (ST-8), May 2010

Parameters	Doris Membrane Plant ST-8
Annual Cumulative	2,928 m ³
Monthly Cumulative	764 m ³
Volume Average (Daily)	24.65 m ³
Maximum	33 m^3
Minimum	19 m ³

During the month of May, sludge was pressed 18 times from the membrane plant resulting in the removal of approx. 2.04 m³ of sludge from the plant. Sludge pressed was sent for incineration.

5. Environmental Incident Reporting

A total of 3 environmental incidents were reported during the month of May. A summary of these incidents is provided below:

- May 07/10: Level 1 (Insignificant) The Doris membrane plant was non-compliant for pH (5.92) for one day. The operator made some adjustments to the aeration and brought the plant back into compliance.
- May 16/10: Level 1 (Insignificant) The Doris membrane plant sludge tank overflowed with some 190 litres being spilling onto the floor inside the plant building. Approximately 10 litres seeped through the doorway and unto the ground immediately outside the building. The cause of the spill was attributed to human error, as the operator failed to switch the valve between the equalizer tank and sludge tank. The spilled sludge was cleaned up and the processed through the facility.
- May 28/10: Level 1 (Insignificant) Approximately 1.0 m3 of grey water spilled as a result of a leaking shower stall drain pipe at Doris Camp (Dorm "B"). The problem with the pipe was corrected and returned to service. The contaminated insulation was removed and disposed of appropriately.

Should there be any questions regarding the monthly report for May 2010, please contact Chris Hanks, Director, Environment and Social Responsibility, Hope Bay Mining Limited on phone number: 1-720-917-4489 or email: Chris.Hanks@Newmont.com

T 7		
Volure	sincere	177
1 Ours	SHICCIC.	LV.

for

Chris Hanks

Director, Environment and Social Responsibility Hope Bay Mining Limited