



I need to provide spill report
info.

INDUSTRIAL WATER USE INSPECTION REPORT

DATE: July 15/04
LICENSEE: Tahera

COMPANY REP.: Kevin Osmund
LICENCE #: NWBSIFR0306

INTERNAL	
PC	<u>dp</u>
MA	
FO	
LA	
BS	
ST	
TA1	
TA2	
RC	
ED	
CH	
NRD	

WATER SUPPLY

Source: CARAT LAKE Quantity Used: NA Meter Rdg.: NA

Indicate: **A - Acceptable** **U - Unacceptable** **N/A - Not Applicable**

Intake Facilities _____ Storage Structures _____ Treatment Systems _____ Recycling _____
Flow Meas. Device _____ Conveyance Lines _____ Pumping Stations _____ Modifications _____

Comments: The camp is empty right now. Only 2 people. 25 to come in July 29/04.
All water is currently taken from CARAT Lake. Water use should be metered but
tracking of the number of times the 500 gallon tanks are filled would be a good idea.

WASTE DISPOSAL Waste transported south.

Tailings: Tailings Pond ☐ Natural Lake ☐ Underground ☐

Sewage: Sewage Treat. System ☐ Tailings Pond ☐ Natural Water Body ☐
Continuous Discharge ☐ Inter. Dischg. ☐

Solid Waste: Open Dump ☐ Landfill ☐ Burn & Bury ☐ Underground ☐

Indicate: **A - Acceptable** **U - Unacceptable** **N/A - Not Applicable**

Discharge Quality _____ Conveyance Lines _____ Disch. Meas. Dev. _____ Freeboard _____
Decant Structures _____ Pond Treatment _____ Dams, Dykes _____ Seepages _____
Dyke Inspections _____ Runoff Diversion _____ Erosion _____ Spills _____

Effluent Discharge Rate: NA Samples Collected: None

Comments: Combustible waste is burned with the ash and non-burnable waste collected
and shipped south. The waste is contained in burn barrels inside a bermed area along
with waste oil. The soil farm is (very) full and needs to be better constructed/repaired.
Sewage is incinerated.

GENERAL CONDITIONS

Indicate: **A - Acceptable** **U - Unacceptable** **N/A - Not Applicable**

Ore & Waste Rock Stockpiles _____ Records & Reporting _____ Surv. Net. Prog. _____
Geotechnical Inspection _____ Posting, Signage _____ Contingency Plan _____
Restoration Activities _____ New Construction _____ Fuel Storage _____
Mine Water Discharge _____ Chemical Storage _____ Annual Report _____

Comments: The fuel cache of 45 gallon A-50 drums has staining of the soil and a strong
odour of fuel. Spills need to be reported to the 24 hr spill line (867) 920-8130. The fuel
should be stored in a lined and bermed area to prevent contamination from spreading.

Violations of Act or Licence: Unreported spills are a violation of the NWNSRIA.

As noted in previous inspections the pump for the water source should have
secondary containment to prevent fuel spills from entering the lake. A spill kit should also be a hand

General Comments: The bulk fuel containers are not yet in use, not until possibly next
March when winter road opens. Line is exposed in a number of places around portal tank.
The camp is currently clean & well maintained although there are few occupants.
Hopefully the cleanliness will continue when more people arrive.

Page 2 attached ☐ Yes ☒ No

KEVIN OSMUND
Licensee Representative's Title

Scott Stewart
Inspector's Name

Kevin Osmund
Licensee Representative's Signature

Scott Stewart
Inspector's Signature

Nunavut Water Board
NOV 26 2004
Public Registry