


Alberta Innovates - Technology Futures ~ Fuels & Lubricants



250 Karl Clark Road, Edmonton, Alberta, Canada T6N 1E4
 Certified by the Standards Council of Canada as an Accredited Testing
 Organization complying with the requirements of ISO/IEC 17025 for
 specific tests registered with the Council



Report of Analysis

This report may only be reproduced in its entirety

Reported: 16-Sep-2016
 Revision: 2016-1

Page 1 of 3

Order Id: FL16_1199

Contract #:

PO#:

Report To:

Invoice To:

Discovery Mining Services
 Box 2248
 Yellowknife, NT X1A 2P7

Discovery Mining Services
 Box 2248
 Yellowknife, NT X1A 2P7

Attention: Mathieu Beaudoin

Attention: DMS Accounts Payable

E-mail: mathieu.beaudoin@discoverymining.ca

E-mail:

Fax:

Fax:

Laboratory Sample Number: FL16_1199-003

Sample Source

Sample Notes

Product: Diesel

Reference: LUP MTF# 04

1

Specification: CAN/CGSB-3.517-2015 B

Location:

Date Received: 13-Sep-2016

Tag Number:

Tank Number:

Specification Details

Analysis	Test Name	Specifications		Results	Units	Test Notes
		Minimum	Maximum			
Copper Corrosion - Classification	ASTM D130		No. 1	1a		
Water and Sediment	ASTM D1796 (modified)		0.02	<0.005	% (v/v)	2
Electrical Conductivity	ASTM D2624	25		>2000	pS/m	
Kinematic Viscosity	ASTM D445 @ 40°C	1.70	4.10	2.058	mm ² /s (cSt)	
Ash Content	ASTM D482		0.010	0.005	Mass %	
Carbon Residue, 10% Bottoms	ASTM D524		0.2	0.14	%	
Cetane Number	ASTM D613	40.0		43.0		
Total Sulfur	ASTM D7039		15	367	mg/kg	3
Wear Scar Diameter	ASTM D7688		460	440	um	
Distillation 90% Recovered (corr)	ASTM D86		360.0	308.7	°C	
Corrected Flash Point	ASTM D93	40.0		53.0	°C	
Acid Number	ASTM D974		0.10	<0.02	mg KOH/g	


Tested Parameters (Note: Parameters in Specification Detail will also appear in complete listing)

Analysis	Test Name	Results	Units	Test Notes
Copper Corrosion - Test Duration	ASTM D130	3	hours	
Copper Corrosion - Test Temperature	ASTM D130	50	°C	
Copper Corrosion - Classification	ASTM D130	1a		
Water and Sediment	ASTM D1796 (modified)	<0.005	% (v/v)	2
Electrical Conductivity	ASTM D2624	>2000	pS/m	
Temperature of Sample	ASTM D2624	19.8	°C	
Density @ 15°C	ASTM D4052	848.1	kg/m ³	
Kinematic Viscosity	ASTM D445 @ 40°C	2.058	mm ² /s (cSt)	
Ash Content	ASTM D482	0.005	Mass %	
Carbon Residue, 10% Bottoms	ASTM D524	0.14	%	
Cloud Point	ASTM D5773	-44.4	°C	
Cetane Number	ASTM D613	43.0		
Total Sulfur	ASTM D7039	367	mg/kg	3
Major Axis	ASTM D7688	0.46	mm	
Minor Axis	ASTM D7688	0.42	mm	
Wear Scar Diameter	ASTM D7688	440	um	
Distillation IBP	ASTM D86	153.6	°C	
Distillation 5% Recovered (corr)	ASTM D86	173.6	°C	
Distillation 10% Recovered (corr)	ASTM D86	180.8	°C	
Distillation 20% Recovered (corr)	ASTM D86	195.3	°C	
Distillation 30% Recovered (corr)	ASTM D86	212.5	°C	

Alberta Innovates - Technology Futures ~ Fuels & Lubricants



250 Karl Clark Road, Edmonton, Alberta, Canada T6N 1E4
Certified by the Standards Council of Canada as an Accredited Testing
Organization complying with the requirements of ISO/IEC 17025 for
specific tests registered with the Council



Report of Analysis

This report may only be reproduced in its entirety

Reported: 16-Sep-2016

Revision: 2016-1

Page 2 of 3

Order Id: FL16_1199

Contract #:

PO#:


Tested Parameters (Note: Parameters in Specification Detail will also appear in complete listing)

Analysis	Test Name	Results	Units	Test Notes
Distillation 40% Recovered (corr)	ASTM D86	228.9	°C	
Distillation 50% Recovered (corr)	ASTM D86	243.4	°C	
Distillation 60% Recovered (corr)	ASTM D86	257.1	°C	
Distillation 70% Recovered (corr)	ASTM D86	271.9	°C	
Distillation 80% Recovered (corr)	ASTM D86	288.2	°C	
Distillation 90% Recovered (corr)	ASTM D86	308.7	°C	
Distillation FBP	ASTM D86	340.5	°C	
Distillation Residue	ASTM D86	1.3	%	
Distillation Loss	ASTM D86	0.3	%	
Corrected Flash Point	ASTM D93	53.0	°C	
Acid Number	ASTM D974	<0.02	mg KOH/g	

Alberta Innovates - Technology Futures ~ Fuels & Lubricants



250 Karl Clark Road, Edmonton, Alberta, Canada T6N 1E4
Certified by the Standards Council of Canada as an Accredited Testing
Organization complying with the requirements of ISO/IEC 17025 for
specific tests registered with the Council



Order Id: FL16_1199

Contract #:

PO#:

Report of Analysis

This report may only be reproduced in its entirety

Reported: 16-Sep-2016

Revision: 2016-1

Page 3 of 3

Notes and Remarks

1. With the exception of total sulfur, the results obtained on your sample comply with the requirements Canadian General Standards Board (C.G.S.B.) specification for Diesel Fuel (CAN/CGSB-3.517-2015 Type B) for areas of Canada which do not require lower flow properties than displayed by the cloud point result.
2. CAN/CGSB-3.517-2015 states that the referee test method for water and sediment shall be ASTM D1796 (modified). The test is modified by substituting the centrifuge tube specified in ASTM D2273 for the centrifuge tube in ASTM D1796.
3. The Canadian General Standards Board (CGSB) specification for Diesel Fuel (CAN/CGSB-3.517-2015) states that the sulfur content shall not be greater than 15 mg/kg.

Approved by:

A handwritten signature in blue ink that reads 'Susan Brown'.

Susan Brown

Specification Analytical Coordinator

Results relate only to items tested.

Contact Information

Business Unit Manager: Dan Wispinski

Phone: (780) 450-5108

Email: dan.wispinski@albertainnovates.ca

FM 037-001