



11 August 2009

Ms. Phyllis Beaulieu  
Manager of Licensing  
Nunavut Water Board  
P.O. Box 119  
Gjoa Haven, NU X0B 1J0

Dear Ms. Beaulieu

**LUPIN MINE - SEWAGE LAKES DISCHARGE – MONIORING STATION LUP-14**

Please be advised that the discharge from the Sewage Lakes Disposal facility at the Lupin Mine will commence the week of August 10th-17<sup>th</sup>. Attached is a copy of the Certificate of Analysis for a sample of water obtained from the pond Monitoring Program monitoring station LUP-14 on July 27, 2009. Table 1 provides a summary of these results with respect to the regulated parameters.

Parameter	Limit	Result	Units
Total Arsenic	0.05	0.00807	mg/L
Total Copper	0.20	0.0019	mg/L
Total Lead	0.30	0.0075	mg/L
Total Nickel	0.50	<0.0040	mg/L
Total Suspended Solids	35	4.0	mg/L
BOD5	30	<2.0	mg/L
Faecal Colliform	1000	<1.0	CFU
Oil and Grease	Visual Sheen	None	None
pH	6.0-9.0	7.45	pH Units

**Table 1 – Chemical Analytical Test Results, Monitoring Station LUP-14, July 27, 2009**

Yours truly

A handwritten signature in black ink that reads 'Andrew Mitchell'.

**Andrew Mitchell**  
Development Manager

T 807 346 1692  
F 807 345 0284  
E [andrew.mitchell@mmgrouppltd.com](mailto:andrew.mitchell@mmgrouppltd.com)  
M 807 251 6722

cc Mr. Dave Honstein - Nunavut Water Board  
Ms. Melissa Joy – INAC  
Mr. Chad Harden - Environment Canada  
Mr. Martin McFarlane - MMG Resources Inc.

Encl. Certificate of Analysis