



11 August 2009

Ms. Phyllis Beaulieu
Manager of Licensing
Nunavut Water Board
P.O. Box 119
Gjoa Haven, NU X0B 1J0

Dear Ms. Beaulieu

LUPIN MINE - SEWAGE LAKES DISCHARGE – MONITORING STATION LUP-14

Please be advised that the discharge from the Sewage Lakes Disposal facility at the Lupin Mine will commence the week of August 10th-17th. Attached is a copy of the Certificate of Analysis for a sample of water obtained from the pond Monitoring Program monitoring station LUP-14 on July 27, 2009. Table 1 provides a summary of these results with respect to the regulated parameters.

Parameter	Limit	Result	Units
Total Arsenic	0.05	0.00807	mg/L
Total Copper	0.20	0.0019	mg/L
Total Lead	0.05	0.0017	mg/L
Total Nickel	0.30	0.0075	mg/L
Total Zinc	0.50	<0.0040	Mg/L
Total Suspended Solids	35	4.0	mg/L
BOD5	30	<2.0	mg/L
Faecal Coliform	1,000	<1.0	CFU
Oil and Grease	Visual Sheen	None	None
pH	6.0-9.0	7.45	pH Units

Table 1 – Chemical Analytical Test Results, Monitoring Station LUP-14, July 27, 2009

Yours truly

A handwritten signature in black ink that reads "Andrew Mitchell".

Andrew Mitchell
Development Manager

T 807 346 1692
F 807 345 0284
E andrew.mitchell@mmgroupltd.com
M 807 251 6722

cc Mr. Dave Honstein - Nunavut Water Board
Ms. Melissa Joy – INAC
Mr. Chad Harden - Environment Canada
Mr. Martin McFarlane - MMG Resources Inc.

Encl. Certificate of Analysis