

2015 Sewage Lakes Disposal Facility Water Quality Results Comparison		
Regulated Parameter	Licence Discharge limit	Sample Results (L1640708-1 LUP-14-150709)
Total Arsenic	0.05 mg/L	0.0207 mg/L
Total Copper	0.2 mg/L	0.00083 mg/L
Total Lead	0.05 mg/L	0.000204 mg/L
Total Nickel	0.3 mg/L	0.00448 mg/L
Total Zinc	0.5 mg/L	<0.0030 mg/L
TSS	35 mg/L	6.7 mg/L
BOD5	30 mg/L	2 mg/L
Faecal Coliforms	1000 units/100 ml	<1
Oil and Grease	No visible sheen	No visible sheen
pH	6.0 - 9.5	7.2