



NWB Tools

Phyllis Beaulieu &lt;phyllis.beaulieu@nwb-oen.ca&gt;

---

**[Licensing] Re: Lupin - Sewage Lagoon Sample Results**

1 message

**Eva Paul** <Eva.Paul@aandc-aadnc.gc.ca>

Thu, Jul 23, 2015 at 2:54 PM

To: klewis@elginmining.com

Cc: Erik Allain &lt;Erik.Allain@aandc-aadnc.gc.ca&gt;, pdowney@elginmining.com, licensing@nwb-oen.ca

Hi Karyn,

Sorry it's taken me a day to get the attachments you sent downloaded and read; the hazards of being on a mobile device. Although it's a step up from not having wireless at all, as I was without for the last couple of days. Thank you for the results, and the summary table that you attached. I don't see the lab result for Oil and Grease, although you've included it in the summary. Can you please send the report?

As you saw while we were at site on the 15th, the lower sewage dam was overtopping. I'm surprised you don't have arrangements made yet; it is still just as big a deal as it was last year when the emergency amendment was sought. Bigger, in fact, as this constitutes failure of a work. LMI needs to address this immediately. Discharge is authorized as soon as you can get there.

Eva

---

**From:** Karyn Lewis**Sent:** Wednesday, July 22, 2015 10:57 PM**To:** Eva Paul**Cc:** Patrick Downey; Licensing Department**Subject:** Lupin - Sewage Lagoon Sample Results

---

Eva,

Please find attached a copy of the lab results for samples from LMI's Sewage Lakes Disposal Facilities at the Lupin Mine. As the samples meet the limits for discharge as set out in paragraph 8 of Part E of our Type A Water Licence, and in accordance with your Direction, we are planning on discharging from the Sewage Lakes either later this week or early next week (as soon as we have confirmed a flight and crew). Once the date is confirmed, we will advise you.

Karyn Lewis

Lupin Mines Incorporated

[778-386-7340](tel:778-386-7340)