

DESIGN REPORT FOR A NEW 3.3ML FUEL TANK AND ITS CONTAINMENT FACILITIES

MEADOWBANK SITE, NUNAVUT



May 24, 2022 Revision: R0 Doc. N°: 61-680-132-REP-001 Tt Project N°: 711-47731





Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001		
Tt Project Nº: 711-477	31	
Area: 680		
Work Package: NA		
Date: 2022-05-24	Revision: R0	

REVISION FOLLOW-UP

REV.	DATE	DESCRIPTION	COMPAGNY	PREPARED BY	REVIEWED BY
			T . T .	S. Moreau	J. Alarie
RA	13-05-2022	Issue for Comments	Tetra Tech	Member Nº: L5021	Member Nº: L3203
KA	13-03-2022	issue for Comments	SNC-LAVALIN	I. Gagnon	NA
			SNC-LAVALIN	Member Nº: L3940	NA
			sue for Use I. Gagnon SNC-LAVALIN	S. Moreau	J. Alarie
D.0				Member N°: L5021	Member Nº: L3203
R0	24-05-2022	Issue for Use		_	NA
					NA

Client Doc. No: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS **CONTAINEMENT FACILITIES**

Tt Doc. Nº: 6134-680-132-REP-001 Tt Project N°: 711-47731 Area: 680 Work Package: NA

Revision: R0

Date: 2022-05-24

SIGNATURES

TETRA TECH For Civil works Prepared by: S.A. MOREAU LICENSEE NTINU PERMIT TO PRACTICE TETRA TECHIQE INC. 24-05-2022 Signature PERMIT NUMBER: P 1029 NT/NU Association of Professional Engineers and Geoscientists olène Moreau 137890 2022-05-24 Solène Moreau, P.Eng Civil Engineer NAPEG # L5021 Reviewed by: Josée Alarie J.M.I.F. ALARIE May 24, 202 NTINU Josée Alarie, P. Eng Civil Engineer NAPEG # L3203

SNC-LAVALIN For Mechanical/Electrical/Instrumentation and **Control works**

Prepared by:

Israël Gagnon, P.Eng Mechanical Engineer NAPEG # L3940

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001	
Tt Project Nº: 711-477	31
Area: 680	
Work Package: NA	
Date: 2022-05-24	Revision: R0

PRODUCTION TEAM

CLIENT – AGNICO EAGLE MINES LIMITED		
Civil Construction Lead	Jennifer Pyliuk, P. Eng.	
Mechanical Construction Lead	Normand Ménard	

FIRM – TETRA TECH	
Project Manager and Civil Engineer	Soléne Moreau, P. Eng.
Civil Engineer	Josée Alarie, P. Eng.

FIRM - SNC-LAVALIN	
Project Manager for Mechanical/ Electrical/ Instrumentation and Control Works	Israël Gagnon, P. Eng.
Electrical/Instrumentation and Control Engineer	Philippe Lemire, P. Eng.
Mechanical Engineer	Israël Gagnon, P. Eng Roxanne Lavoie





Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. Nº: 6134-680-132-REP-001	
Tt Project Nº: 711-4773	31
Area: 680	
Work Package: NA	
Date: 2022-05-24	Revision: R0

TABLE OF CONTENT

1	INTRODUCTION	1
1.1 1.2 1.3 1.4	PROJECT OVERVIEW PURPOSE OF THE REPORT SCHEDULE RESPONSIBILITY MATRIX	1 2 2 2
1.5	INCLUSIONS AND EXCLUSIONS 1.5.1 Inclusions 1.5.2 Exclusions	3 3 3
1.6 2	ENGINEERING DOCUMENTS CODE AND STANDARDS	3 4
2.1 2.2 2.3 3	COMPLIANCE FOR FIELD ERECTED FUEL TANK CODE ANALYSIS FOR FIELD ERECTED FUEL TANKS COMPLIANCE FOR SECONDARY CONTAINMENT DESIGN OF TANK, PIPING, INSTRUMENTATION AND CONTROL	4 4 5 5
3.1 3.2 3.3 3.4	DESCRIPTION OF SITE GENERAL ARRANGEMENT AND TANK COMMISSIONNING SYSTEM OPERATION MAINTENANCE/INSPECTION	5 6 6
4	DESIGN OF FUEL STORAGE TANK FARM	6
4.1 4.2 4.3	DESCRITPION AND CONSTRUCTION DRAWINGS GEOTECHNICAL DATA TANK FOUNDATION DESIGN	6 8 8
4.4	SECONDARY CONTAINMENT DIKE DESIGN	9
4.5	SECONDARY CONTAINMENT CAPACITY	10
4.6 4.7	SECONDARY CONTAINMENT IMPERVIOUSNESS SECONDARY CONTAINMENT DRAINAGE	12 12
4.8	DISTANCE RESTRICTIONS	12
4.9	INSPECTION AND COMMISSIONING	13
5	EARTH WORKS	14
5.1 5.2	CONSTRUCTION MATERIAL QUANTITIES CONSTRUCTION MATERIAL SPECIFICATIONS 5.2.1 Sand 5.2.2 Granular Fill (0-30mm) 5.2.3 Granular fill – (0-200 mm)	14 14 15 15

Client Doc. N°: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. Nº: 6134-680-132-REP-001		
Tt Project N°: 711-47731		
Area: 680		
Work Package: NA		
Date: 2022-05-24	Revision: R0	

APPENDICES

Appendix A – MECHANICAL/ELECTRICAL DRAWINGS (SNC-LAVALIN)

Appendix B – EARTHWORKS CONSTRUCTION DRAWINGS (TETRA TECH)

ACRONYMS AND ABBREVIATIONS

The definition of acronyms and abbreviations used in this report are listed below.

Acronyms/Abbreviations	Definition
API	American Petroleum Institute
ARD-ML	Acid Rock Drainage – Metal Leaching
AWSL	Above Sea Water Level
CCME	Canadian Council of Ministers of the Environment
CEC	Canadian Electrical Code
CL	Centerline
CSA	Canadian Standards Association
DRFS	Design Rationale for Fuel Storage and Distribution Facility
HDPE	High Density Polyethylene
NAPG	Non-Potential Acid Generating
NBCC	National Building Code of Canada
NFCC	National Fire Code of Canada
NFPA	National Fire Protection Association
NWB	Nunavut Water Board
R-125-95 NWT	Consolidated Mine Health and Safety Act

Client Doc. No: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001

Tt Project N°: 711-47731

Area: 680

Work Package: NA

Date: 2022-05-24 Revision: R0

INTRODUCTION

1.1 PROJECT OVERVIEW

Agnico Eagle Mines Ltd (Agnico Eagle) is proposing to erect a new 3.3ML fuel tank at their Meadowbank site in Nunavut. At the site, there is currently a tank farm enclosing a 5.6ML fuel tank, which has been in service since 2009. The new tank will be erected adjacent to the existing tank and the tank farm will be modified to enclose both tanks. The existing pumping station and ancillaries will be shared by the two tanks. New pipelines will be installed to connect the new tank to the existing pumping station.

The project is multi-disciplinary and involves earthworks, mechanical and electrical works.

Figure 1 and Figure 2 below indicate the geographical location of Meadowbank and the fuel farm location.



Fig.1: Meadowbank - Site location



Fig. 2: Meadowbank - Fuel Farm location

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001		
Tt Project Nº: 711-47731		
Area: 680		
Work Package: NA		
Date: 2022-05-24 Revision: R0		

1.2 PURPOSE OF THE REPORT

AGNICO EAGLE retained Tetra Tech and SNC-LAVALIN Inc. to design the 3.3ML field erected fuel storage tank, the secondary containment required for the new tank, the new piping, and the required modification to the existing installations to have a functional system.

This report is intended to present the design basis, codes and regulation overview, specific considerations, engineering design and construction details related to the project.

This report includes the final design and construction drawings for fuel storage facilities as specified under Nunavut Water Board (NWB) Water License 2AM-MEA1530.

1.3 SCHEDULE

Earthworks is planned to begin in July 2022 and the erection of the tank in Mid-August 2022. The commissioning of the new fuel storage tank is planned to be completed in 2022.

1.4 RESPONSIBILITY MATRIX

The table 1 below identifies the area of responsibility in this design report for both engineering consulting firms.

<u>Table 1 – Responsibility Matrix</u>

RESPONSIBILITY MATRIX		
SECTIONS	Tetra Tech	SNC-LAVALIN
SECTION 1 INTRODUCTION	x	x
SECTION 2 CODES AND STANDARDS	х	x
SECTION 3 DESIGN OF TANK, PIPING, INSTRUMENTATION AND CONTROL		X
SECTION 4 DESIGN OF TANK FARM	х	
SECTION 5 EARTHWORKS	х	

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. Nº: 6134-680-1	132-REP-001
Tt Project N°: 711-47731	
Area: 680	
Work Package: NA	
Date: 2022-05-24	Revision: R0

1.5 INCLUSIONS AND EXCLUSIONS

1.5.1 Inclusions

The following items are included in the design report:

- Field erection of one (1) new vertical fuel storage tank of 3.3 M liter;
- Accessories such as couplings, nozzles, stairs, steps, railings, fixed suction, and piping;
- Piping network;
- Testing, calibration and inspection requirements;
- Instrumentation and control;
- Tank foundation;
- Fuel farm secondary containment with liner system.

1.5.2 Exclusions

Any elements not mentioned in the Inclusions are considered excluded from the design report.

1.6 ENGINEERING DOCUMENTS

Table 2 - Engineering documents list

Engineering documents	
Mechanical General Arrangement (GA) drawings	
	Process and Instrumentation Diagram (PID) drawings
	Platework drawings
	Piping drawings
Structure	Structural steel drawings
Electrical	Power distribution drawings
	Grounding drawings
	Light and services drawings
Civil	Earth Works drawings

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001

Tt Project N°: 711-47731

Area: 680

Work Package: NA

Date: 2022-05-24

Revision: R0

CODE AND STANDARDS

2.1 COMPLIANCE FOR FIELD ERECTED FUEL TANK

The system complies with the latest editions of the Codes and Standards relating to this project (Federal, Territorial, Municipal, NBCC, NFCC, CEC, CSA, NFPA, and API) as well as the directives of the authorities having jurisdiction over this project. Specific codes and standards as: R-125-95 NWT and Nunavut Mine Health and Safety Regulations (Mine Health and Safety Act) and RRNWT 1990, c F-12 Fire Prevention Regulations shall apply.

Additionally, the design and field erected vertical fuel storage tanks shall conform to API Std. 650 Twelfth Edition - Welded Tanks for Oil Storage, including Errata 1 (2013), Errata 2 (2014), and Addendum 1 (2014) and applicable Appendices.

2.2 CODE ANALYSIS FOR FIELD ERECTED FUEL TANKS

The Field Erected Storage Tank System and pumping stations design are first based on the compliance with the Storage Tank Systems for Petroleum Products and Allied Petroleum Products Regulations (SOR/2008-197). Article 14 (1) of this regulation mentions that for the installation of a fuel storage system, the system has to comply with the applicable requirements set out in the CCME Code of Practice (CCME PN1326).

Looking into the CCME, the main design criteria is defined in Part 3 that applies to the design and installation of a new aboveground storage tank system and Part 5 that applies to the design and installation of new piping systems.

The Field Erected Storage Tank System design shall comply with requirements of CCME 3.6.1(1) for aboveground storage tanks, more specifically API Std 650 for vertical single wall tanks.

In accordance with section 3.3 and 3.4 of the CCME, storage tanks shall be equipped with an overfill protection to prevent from spill.

In accordance with CCME section 5.4, all underground piping has to be double walled and installed such that leaks will be collected into an accessible sump.

Reviewing the NFCC latest edition, the main design criteria are defined in Part 4 regarding the flammable and combustible liquids. More specifically, Section 4.1 which provides general information and requirements for fire protection and spill control of flammable and combustible liquid storage systems, Section 4.3 which provides the tank design and construction minimum requirements, Section 4.5 for piping and transfer systems and Section 4.6 for fuel dispensing stations.

Basically, most of the NFCC requirements for tank and piping systems are covered by CCME requirements but give some additional ones. For example, Table 4.3.2.1 defining the minimum requirements for the location of aboveground storage tanks; Point 4.3.2.2 defining the minimum requirements for spacing between tanks; or point 4.3.6.4.2) requesting that connections for filling or emptying storage tanks shall be kept closed to prevent leakage when not in use.

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt [Tt Doc. Nº: 6134-680-132-REP-001		
Tt Project Nº: 711-47731			
Area: 680			
Wo	Work Package: NA		
Date: 2022-05-24 Revision: R0			
•			

2.3 COMPLIANCE FOR SECONDARY CONTAINMENT

The secondary containment for the aboveground storage tanks shall conform to NFCC. The base and walls of a secondary containment shall be designed, constructed and maintained to withstand full hydrostatic head and provide a permeability of not more than 10-6 cm/s to the flammable liquids or combustible liquids contained in the storage tanks (Art. 4.3.7.2). The tank will be placed entirely within a dike area, with an impermeable barrier in the floor of the containment area and in the dike walls. The membrane is expected to provide the level of impermeability required and will be covered with a noncombustible material to prevent it from failing if the secondary containment is exposed to fire. More details are provided in Section 4.6. The secondary containment shall have a minimum volumetric capacity as stated in Art.4.3.7.3. The designed fuel farm will have a secondary containment that is greater than the volumetric capacity required per Art.4.3.7.3. (See Section 4.5 for details).

3 DESIGN OF TANK, PIPING, INSTRUMENTATION AND CONTROL

3.1 DESCRIPTION OF SITE GENERAL ARRANGEMENT AND TANK

This section describes the criteria used to design the field erected fuel storage tanks, to prepare general arrangements and to select equipment and/or materials.

The plan view of the fuel farm is shown on Figure 3 below.




Fig. 3 – Fuel Farm plan view



Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001

Tt Project N°: 711-47731

Area: 680

Work Package: NA

Date: 2022-05-24 Revision: R0

The existing pumping station will be used to fill both the actual and the new 3.3 ML tanks. Both tanks will be connected to the existing pumping stations. Those pumping stations will be used to fill both tanks from tanker trucks travelling between the Baker Lake fuel farm and the Meadowbank site. Existing distributing pumping stations will also be used for equipment refuelling as well as supply the power generator transfer tanks located near the power plant.

Construction drawings for the Meadowbank site fuel farm can be reviewed in Appendix A.

3.2 COMMISSIONNING

The fabrication, erection, inspection, testing, welding and labelling of vertical tanks will be to the latest edition of API Standard 650. Prior to putting a fuel storage tank in service, the tank will pass quality control checks as per API 650 requirements; finally, the tank will be cleaned, dried, strapped and closed to be ready for service.

3.3 SYSTEM OPERATION

For loading operation, the existing pumping station will transfer fuel from the tanker trucks to the selected storage tank. The storage tanks will be equipped with overfill alarm system for operator notification and to automatically stop the pumping operation. Mill operator will be able to select from which storage tank the distribution pumping stations on site will pump from.

3.4 MAINTENANCE/INSPECTION

A qualified maintenance team will inspect the system (mechanical equipment and piping) on a regular basis as per regulations and codes. The new distribution piping will be installed above ground which means any leaks can be detected during the periodic visual inspection.

Field erected storage tanks shall be inspected externally and internally as per CCME section 8.4 and API 653 standard.

4 DESIGN OF FUEL STORAGE TANK FARM

4.1 DESCRITPION AND CONSTRUCTION DRAWINGS

There is currently an existing fuel farm with one 5.6 ML fuel tank in service since 2009. An as-built report was issued in April 2009 by Agnico Eagle (*Reference: "Meadowbank Fuel Storage Installations - Final report following the construction"*, #VD2259-1A, April 2009).

The proposed 2022 work consists of adding a 3.3 ML fuel tank next to the existing tank and modifying the secondary containment area so that the two tanks will share the new containment space.

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

	Tt Doc. N°: 6134-680-132-REP-001	
	Tt Project Nº: 711-47731	
Area: 680		
	Work Package: NA	
	Date: 2022-05-24	Revision: R0

The proposed modifications to the secondary containment area consist of:

- > Building a new tank foundation for the 3.3ML fuel tank.
- > Building containment dikes around the new tank.
- > Building a lower channel connection in the berm that separates the two tanks so that the liquid can flow over through the channel in case of a spill and be contained in the proposed tank farm.
- > Installing a liner system in the new containment area to ensure imperviousness of the tank farm.
- > Grading the tank farm floor to ensure run-off drainage to a sump pit.

The detailed design of the proposed modifications to the tank farm is presented in the construction drawings attached in Appendix B.

The table 3 below presents the characteristics of the existing tank and the proposed new tank that will be enclosed in the modified fuel storage tank farm.

Table 3 – Description of the tanks

Characteristics	NEW 3.3 ML TANK 6168TNK035	EXISTING 5.6 ML TANK 680-TK-240
Product	DIESEL	DIESEL
Volume (liter)	3 362 000	5 675 500
Diameter (m)	21.039	24.384
Height (m)	9.667	12.192

Client Doc. No: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

	Tt Doc. N°: 6134-680-132-REP-001	
Tt Project Nº: 711-47731		31
Area: 680 Work Package: NA		
	Date: 2022-05-24	Revision: R0

The figure 4 below represents a 3D model of the tank farm.




Fig.4: Proposed tank farm 3D model

4.2 GEOTECHNICAL DATA

Probing for bedrock depth was carried out within the footprint of the proposed new tank by Agnico Eagle in April 2022 and the information provided to Tetra Tech. Eleven holes were drilled using an air rotary drilling. The overburden material encountered was mainly described as till, typically composed of brown sand with some gravel and some silt. Bed rock depth varied from 1.3 m to 3.0 m from the ground surface with an average of 2.1 m. Drawing 61-680-230-002 in Appendix B provides drill hole locations.

4.3 TANK FOUNDATION DESIGN

The new tank foundation will be composed of granular fill material placed on exposed competent bedrock surface.

Civil works for the preparation of the tank foundation pad consist mainly in excavation of all existing material to competent bedrock and placing and compacting the granular fill material. The rock surface will be exposed, cleaned, inspected by a qualified geotechnical professional prior to backfilling. A liner system will be installed under the tank.

The tank pad will be 300 mm (minimum) higher than the surrounding ground. A 1.2 m shoulder will surround the tank with a slope of 1V:120H away from the tank. The embankments of the foundation pad will not be steeper than 1V:2H.

The tank pad elevation at the center of the tank is 150.48 m (AWSL).

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001		
Tt Project Nº: 711-47731		
Area: 680		
Work Package: NA		
Date: 2022-05-24	Revision: R0	

Table 4 presents the design parameters of the tank pad.

Table 4 – Design parameters of the tank pad

Design parameters of the tank pad	Values
Geometry of the tank top pad	Circular
Geometry of the tank top pad	Diameter = 23.44 m
Shoulder width	1.2 m
Height of the tank pad above surrounding floor	Minimum 300 mm
Slope on shoulder	1V:120H
Slope on embankment	1V:2H
Tank pad elevation at the center of the tank	150.48 m (AWSL)

4.4 SECONDARY CONTAINMENT DIKE DESIGN

To contain a spill event of the new tank, a dike will be constructed around it. A channel connection will be built in the eastern berm located between the new and existing tanks to allow liquid to go to the existing dike (and vice-versa). That berm will be an intermediate berm in the final configuration of the tank farm.

The new berms of the dike will be made of granular fill material and the entire surface of the new dike will be rendered impervious by the incorporated liner system.

The design parameters for the new dike surrounding the new fuel tank are presented in Table 5.

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001

Tt Project N°: 711-47731

Area: 680

Work Package: NA

Date: 2022-05-24 Revision: R0

Table 5 - Design parameters for the new dike

Design parameters of the new dike	Values
Dike length (CL to CL)	154 m
Dike height	1.8 m max (Varies from 0.96 m to 1.72 m)
Dike flat top width	0.6 m
Dike embankment slope	1V:2H
Impervious area	1 602 m2
Top elevation of the dike (AWSL)	151.05 m
Elevation of the dike floor (AWSL)	Varies from 149.33 m to 150.09 m
Elevation of the liner in the berms (highest point)	150.90 m
Granular cover above the liner system	150 mm in the berm 200 mm at the floor dike
Channel width	3.5 m
Elevation at the channel plateau (bottom)	150.05 m

4.5 SECONDARY CONTAINMENT CAPACITY

The required capacity of the fuel farms is calculated based on the following codes and regulations:

- National Fire Code of Canada (NFCC);
- National Fire Protection Association (NFPA); and
- Design Rationale for Fuel Storage and Distribution Facility (DRFS).

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. Nº: 6134-680-	132-REP-001	
Tt Project N°: 711-47731		
Area: 680		
Work Package: NA		
Date: 2022-05-24 Revision: R0		

As per the NFCC (2015), Art. 4.3.7.3, the required capacity for the secondary containment of a fuel farm with more than one storage tank shall have a volumetric capacity of not less than the sum of:

- a) The capacity of the largest storage tank located in the contained space, and;
- b) 10% of the greater of:
 - i. The capacity specified in Clause (a), or;
 - ii. The aggregate capacity of all other storage tanks located in the contained space.

The containment volume was calculated with the aid of AutoCAD CIVIL 3D software. The calculation does not include the volume inside the tanks themselves.

The lowest point of the liner that sits atop in the global containment area is at elevation 150.90 m (AWSL).

The simulation shows that the required capacity of the tank farm to be in accordance with Code is obtained with a simulation at elevation 150.70 m, which implies there is a safety margin (freeboard) of at least 200 mm.

Based on the above mentioned, the secondary containment capacity requirements and the available capacity for the fuel farm are summarised in the following table.

Table 6 - Fuel Farm containment capacity

Final Fuel Farm	MEADOW	/BANK
	EXISTING	NEW
Enclosed Tanks	5.6 ML TANK	3.3 ML TANK
	680-TK-240	6168TNK035
Maximum Volume in the tank	5 675 700 L	3 662 000 L
Required	0.040	3
Containment Capacity	6 243 m³	
Available	7.004	3
Containment Capacity at elevation 150.90 m	7 394	m ^o
Is Available containment capacity > Required containment capacity	YES	8
Containment capacity at elevation 150.70 m	6 259	m3
(For free board evaluation)	(Free board = 2	200 mm min)

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001		
Tt Project N°: 711-47731		
Area: 680		
Work Package: NA		
Date: 2022-05-24 Revision: R0		

4.6 SECONDARY CONTAINMENT IMPERVIOUSNESS

As per NFCC (2015) Art. 4.3.7.2, the base and walls of the fuel farm secondary containment are designed and will be constructed and maintained to withstand full hydrostatic head and provide a permeability of not more than 10-6 cm/s to the flammable liquids or combustible liquids contained in the storage tanks. The diked area will be impervious in order to avoid any seepage into the environment. A 60 mil. HDPE geomembrane liner installed between two layers of non-woven geotextile, to protect its integrity, will provide adequate imperviousness. Since the membrane providing the level of impermeability is combustible, it will also be covered with a non-combustible material (a layer of granular material) for adequate protection if exposed to fire. Technical specifications for both geomembrane and geotextile are provided in Section 5 of this report.

4.7 SECONDARY CONTAINMENT DRAINAGE

The finished grade of the secondary containment is sloped away from the tank to drain the runoff water within the diked area and towards a drainage sump located inside the tank farm. The sump pit is made of the bottom part of 205L steel drum or equivalent with perforations. As per Agnico Eagle practices, due to the melting snow that accumulates over the winter and precipitations, contact water will be collected inside the secondary containment dike and then managed as per the Water License.

4.8 DISTANCE RESTRICTIONS

The minimum clearances that were considered in the design of the tank Farm are:

- The distance between multiple tanks must be the greatest of ¼ of the sum of the tanks diameters or 1 m (NFCC, Art. 4.3.2.2);
- The distance between the tank and the toe of the dike shall not be less than 1.5 m (NFCC, Art. 4.3.7.4);
- The distance between the tank and the centerline of the dike shall not be less than ½ the height of the tank (DRFS Art. 4.5);
- The distance between the property limit and the tank shall not be less than twice the diameter of the tank (NFPA 30, Table 22.4.1.1);
- The distance between the property limit and the exterior toe of the dike shall not be less than 3 m (NFPA 30, Art. 2.3.4.3);
- The tanks must be located 60 ft (18.3 m) away from the public roads and buildings (NFPA 30, Table 22.4.1.1).

Client Doc. N°: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001

Tt Project N°: 711-47731

Area: 680

Work Package: NA

Date: 2022-05-24

Revision: R0

Distance clearances are resumed in Table 7 below:

Table 7 – Distance clearances

Item	Required	NEW TANK 6168TNK035	COMPLIANCE
Distance Between Tanks	½ (D1 + D2) = 11.35 m D1=21.039 m, D2=24.38 m	35.20 m	Yes
Distance Between Tank and Toe of the Dike	1.50 m Min.	3.5 m min	Yes
Distance Between Tank and CL of the Dike	½ (Height of Tank) = 4.84 m H=9.677 m	8.33 m min	Yes
Distance Between Property Limit (that can be built upon) and Tank	Tanks with less than 3 000 000 gallons: 165 ft. = 50.29 m	> 200m	Yes
Distance Between Property Limit and Exterior Toe of the Dike	3.0 m Min.	>200m	Yes
Distance Between Tank and Public Roads	55 ft. = 16.76 m	>1km	Yes

4.9 INSPECTION AND COMMISSIONING

The manufacture and supply of the liner system for the fuel farm will comply with ASTM standard. The manufacturer will provide a certification stating that the material proposed has physical properties that meet the required values. The rolls of liner will be labelled, packaged, shipped, off-loaded, stored, and handled by appropriate means to prevent damage to the material.

The subgrade surface will be inspected by the Engineer to verify suitability prior to installation of the liner system. A minimum thickness of fill covering the liner will be maintained for operating equipment over the liner to prevent any damage. The installation of the liner system will be performed by a qualified installer. All seaming, patching, welding operations, and testing will be performed by a qualified technician. Joints/seams between liners panels will be field welded using the manufacturer's recommended procedures and equipment. Seaming will be performed using double wedge automatic fusion welding equipment and techniques. Extrusion welding will be used where double wedge fusion welding is not possible such as for patches, repairs, and short runs of seams. Any welds that have been rejected will be remedied to satisfactory requirements. All the field seams will be non-destructively tested using vacuum box, air pressure, or spark testing equipment.

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

	Tt Doc. N°: 6134-680-132-REP-001		
	Tt Project Nº: 711-47731		
	Area: 680		
Work Package: NA			
	Date: 2022-05-24 Revision: R0		

The backfill material will be placed in accordance with the drawings and specifications for the maximum lift thickness, compaction requirements and final grade levels. Particular attention should be taken when welding the new liner to the existing one at the channel to ensure the continuity of imperviousness in the entire tank farm. The tank farm including its liner system installation and testing documentation will be accepted by the Engineer prior to the filling of the storage tank.

5 EARTH WORKS

A quality control/assurance program is required during construction. We are not expecting any erosion and sediment control measure during construction.

5.1 CONSTRUCTION MATERIAL QUANTITIES

The table below presents the estimated in-place material quantities for the construction of the fuel farm.

Table 8 – Material quantities estimation

Item	TOTAL
Sand (m³)	25
Granular fill 0-30 (m³)	1 654
Granular fill 0-200 (m ³)	746
Granular fill 0-600 (m³)	1 371
540 g/m² non-woven geotextile (m²)	4 708
HDPE Geomembrane (m ²)	2 354
Total Excavation of Overburden Volume (m³)	3 421

5.2 CONSTRUCTION MATERIAL SPECIFICATIONS

All the material to be used is NPAG (Non-Potential Acid Generating) and determination is done as per Agnico Eagle ARD-ML (Acid Rock Drainage – Metal Leaching) Testing and Sampling Plan. The general requirements for the materials are specified below.

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

	Tt Doc. Nº: 6134-680-132-REP-001	
Tt Project Nº: 711-47731		31
	Area: 680	
	Work Package: NA	
	Date: 2022-05-24	Revision: R0

5.2.1 Sand

Granular sand shall consist of hard durable particles, be free of roots, topsoil and other deleterious materials and have a particle size distribution as presented in Table 9. Processing may be required to achieve the specified gradation if not naturally meeting the requirements.

Table 9 - Sand - Particle size distribution limits

Particle size (mm)	% Passing
10	100
5	95 – 100
0.08	0 - 10

5.2.2 Granular Fill (0-30mm)

Granular Fill (0-30 mm) shall consist of hard durable particles, be free of roots, topsoil and other organic material and have a particle size distribution as presented in Table 10. Processing will be required to achieve the specified gradation.

<u>Table 10 - Granular fill (0-30 mm) – Particle size distribution limits</u>

Particle size (mm)	% Passing
30	100
14	65 – 100
5	45 – 70
0.63	15 – 35
0.08	4 – 10

5.2.3 Granular fill - (0-200 mm)

Granular Fill (0-200 mm) shall consist of hard durable particles, be free of roots, topsoil and other deleterious material and have a particle size distribution as presented in Table 11. Processing will be required to achieve the specified gradation.

Table 11 - Granular fill (0-200 mm) - Particle size distribution limits

Particle size (mm)	% Passing
200	100
100	50 - 100
50	25 – 65
25	10 – 40
5	0 - 15



Client Doc. N°: 6134-680-132-REP-001 Client Project N°: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001	
Tt Project Nº: 711-47731	
Area: 680	
Work Package: NA	
Date: 2022-05-24	Revision: R0

5.2.4 Granular fill - 600 mm minus

Granular Fill (0-600 mm) can have a wide variation of gradation, with maximum particle size 600 mm. Rock fill particles shall be angular and shall be derived from hard, durable rock. Any oversized boulders should be removed before the rock fill is placed into the earth structures.

5.2.5 Geotextile

A non-woven geotextile will be placed between the granular material and the geomembrane. It will be comprised of needle punch polypropylene fabric made of 100% polypropylene staple fibers conforming to the properties in Table 12. The geotextile will be at minimum weight of 540 g/mm².

Table 12 - Geotextile specifications

Earth structure	Fuel farms	ASTM test method (or approved equal)
Grab Tensile (N / lbs)	1,690 / 380	D4632
Elongation (%)	50	D4632
Tear (N / lbs)	623 / 140	D4533
Puncture (N / lbs)	4,560 / 1,025	D4833
Weight (g/m² / oz/yd²)	542 / 16.0	D5261
UV Resistance	70	D4355

5.2.6 Geomembrane Liner

An impervious geomembrane liner material will be placed underneath the granular material at a depth of 0.15 m in order to contain the area in case of a spill. The liner will be a continuous membrane to ensure its imperviousness. The liner material will be a high-density polyethylene (HDPE) and will have the minimum property values indicated in Table 13.

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001

Tt Project N°: 711-47731

Area: 680

Work Package: NA

Revision: R0

Date: 2022-05-24

Table 13 - Geomembrane specifications

Test parameter	Required specifications	ASTM test method (or approved equal)
Minimum average thickness (mm/mil)	1.5/60	D5994
Density	0.94	D792
Tensile properties:		D638 Modified type UV Die 50 mm/minute
Stress @ Yield (kN/m/ppi)	16/90	
Stress @ Break (kN/m/ppi)	22/126	
Strain @ Yield (%)	12	
Strain @ Break (%)	100	
Tear resistance (N/lbs)	187/42	D1004
Low temperature (C/F)	-60/-76	D746 Procedure B
Dimensional stability (%)	+/-2.0	D1204
Puncture resistance (N/lbs)	400/90	FTMS N. 1O1B Method 2065
Carbon black (min.)	2	D1603
Carbon black dispersion	Category 1 or 2	D5596

Client Doc. N°: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT


NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES


Tt Doc. N°: 6134-680-132-REP-001		132-REP-001
Tt Project N°: 711-47731		31
Area: 680		
Work Package: NA		
	Date: 2022-05-24	Revision: R0

APPENDIX A - MECHANICAL/ELECTRICAL DRAWINGS (SNC-LAVALIN)

61-100-J-0210-1	205 - P&ID Sheet 1 Diesel Fuel Storage / Supply
61-100-J-0210-2	205 - P&ID Sheet 2 Diesel Fuel Storage / Supply
61-680-210-002	210 - General Arrangement Plan View Fuel Tank Farm
61-680-270-001	270 - General Arrangement Piping Plan View Fuel Tank Farm
61-680-270-002	270 - General Arrangement Piping Details Fuel Tank Farm
61-680-270-003	270 - General Arrangement Piping Details Fuel Tank Farm
61-680-270-004	270 - General Arrangement Piping Piping Support Type 1 Fuel Tank Farm
61-680-270-005	270 - General Arrangement Piping Piping Support Type 2 & 3 Fuel Tank Farm
61-680-270-006	270 - General Arrangement Piping Details Fuel Tank Farm
61-680-260-001	Platework Plan & Elevation 3M Liters Diesel Tank Tank #2 – 6168TNK035

61-680-260-002	Platework Details 3M Liters Diesel Tank Tank #2 – 6168TNK035
61-680-275-001	FUEL STORAGE & DISTRIBUTION 6168TNK035 GROUNDING
61-680-285-001	FUEL STORAGE & DISTRIBUTION 6168TNK035 LIGHTING & SERVICES
680-J-1002	PP FUEL XFER PUMP PACKAGE I/O PANEL 680-IOP-013 MODULE WIRING
680-J-1003	PP FUEL XFER PUMP PACKAGE I/O PANEL 680-IOP-013 TB WIRING
61-680-280-001	280 – INSTRUMENTATION & CONTROL 680-IOP-013 – FUEL TANK #2 LEVEL LOOP WIRING DIAGRAM
61-680-280-002	280 – INSTRUMENTATION & CONTROL 680-IOP-013 – FUEL TANK #2 INLET FLOW LOOP WIRING DIAGRAM
61-680-280-003	280 – INSTRUMENTATION & CONTROL 680-IOP-013 – FUEL TANK #2 OUTLET #1 FLOW LOOP WIRING DIAGRAM
61-680-280-004	280 – INSTRUMENTATION & CONTROL 680-IOP-013 – FUEL TANK #2 OUTLET #2 FLOW LOOP WIRING DIAGRAM










NO. DESSIN DRAWING NO. 61-680-260-001

TANK #2 - 6:68TNK035 - DIESEL













NO. DESSIN 61-680-270-002_R1









NO. DESSIN 61-680-270-005_R0 -U-BOLT FOR STD. #100 PIPE Ø1 1/4"-7 UNC MAT.: GALVANIZED STEEL TYP. 8X 0 0 NOTES GÉNÉRALES / GENERAL NOTES POUR CONSTRUCTION FOR CONSTRUCTION ISOMETRIC VIEW - SUPPORT TYPE-2
SCALE: 1:8
OTY: 9 ELEVATION VIEW
SCALE: 1:8 > 81 ELEVATION VIEW
SCALE: 1:8 ISOMETRIC VIEW - SUPPORT TYPE-3 •)) SNC+LAVALEN

Rosyn-Horarda (Quittee Tal.: 819 764-5181 Fac www.snds/edi.com Φ `₩ Project #: 688597-0000 50 TYP. CHROMOTOR C-CONTINUE CEL LA PROPRIÉT EL ANDIO GALLE LITÉ ET DOT DES RETURNES SAN BARROS, SANS AUTORASON (CARROS) À AUTOR ET TONE VILLANDA ANTIS QUE CALLE POR LANGUELLE CHROMOTOR DE CARROS CALLE ANDIO GALLE CÂND. Φ 150 | 100 | non-moments. C-ADDG ONE USE

TO SEPARATE AND THE ADDG ONE USE

TO SEPARATE AND THE ADDG ONE CIT. AD BOT AS ADDRESS AND ADDGES STREET


OF OTHER DESCRIPT, TO SECUL SIN HER ADD ONE CIT. AD BOT AS ADDRESS AND ADDRESS.

AND THE ADDRESS ADDRESS ADDRESS AND ADDRESS ADD 1 50 TYP. DESSINS EN RÉFÉRENCE / REFERENCE DRAWING * TYP.\>______ FUE. STORAGE CENERAL ARRANSEMENT 61-680-210-002


ODERRAL ARRANSEMENT - PLAN VERI 61-680-270-001


ODERRAL ARRANSEMENT - DETAILS 61-680-270-002


FUEL STORAGE / SUPPLY - P&D 100-J-210 1/2 & 2/2 HSS 100x100x9.5 TYP. AGNICO EAGLE HSS 100x100x9.5 TYP. POR CONSTRUCTION
DESCRIPTION
REVISIONS DETAIL SCALE: 1:8 DETAIL SCALE: 1:8 DETAIL SCALE: 1:8 DETAIL 2022-05-17 TYP. > 6 V TYPE WELD DETAIL U.O.S.





FILE NO. 61-680-270-005_R0.dwg























Agnico Eagle Mines Ltd / Meadowbank division

Client Doc. Nº: 6134-680-132-REP-001

Client Project Nº: 6134

DESIGN REPORT

NEW 3.3 ML FUEL TANK AND ITS CONTAINEMENT FACILITIES

Tt Doc. N°: 6134-680-132-REP-001		
Tt Project Nº: 711-47731		
Area: 680		
Work Package: NA		
Date: 2022-05-24	Revision: R0	

APPENDIX B – EARTHWORKS CONSTRUCTION DRAWINGS (TETRA TECH)

Number	Title	Rev
61-680-230-001	AGNICO EAGLE - MEADOWBANK DIVISION 680- FUEL FARM 230- GENERAL EARTH WORKS PLAN VIEW 3,3 ML FUEL TANK FARM PROPOSED LAYOUT	R0
61-680-230-002	AGNICO-EAGLE - MEADOWBANK DIVISION 680- FUEL FARM 230- GENERAL EARTH WORKS PLAN VIEW AND SECTIONS 3,3 ML FUEL TANK FARM EXCAVATION	R0
61-680-230-003	AGNICO-EAGLE - MEADOWBANK DIVISION 680- FUEL FARM 230- GENERAL EARTH WORKS SECTIONS AND DETAILS 3,3 ML FUEL TANK FARM FILL	R0
61-680-230-004	AGNICO-EAGLE - MEADOWBANK DIVISION 680- FUEL FARM 230- GENERAL EARTH WORKS PLAN VIEW 3,3 ML FUEL TANK FARM CROSS-SECTIONS KEY PLAN	R0
61-680-230-005	AGNICO-EAGLE - MEADOWBANK DIVISION 680- FUEL FARM 230- GENERAL EARTH WORKS SECTIONS 3,3 ML FUEL TANK FARM CROSS-SECTIONS	R0

NO. DESSIN 61-680-230-001 WORK AREA REQUIRED MATERIAL CONSTRUCTION QUANTITIES ESTIMATION +10% CONTINGEN DIKE BERM
TOP CREST WIDTH = 0.6 m
TOP DIKE ELEVATION = 151.05m
BERM \$1.0FE = 174:2H
REFER TO DWG 61-680-230-003 FOR FILL DETAIL 4 708 HDPE Geomembrane (m2) GROUNDING CABLE
(REFER TO ELECTRICAL DRAWING
AND NOTE 4) N:7213487.46 -E:638231.88 ELV.:149.67 3421 IMPERVIOUS AREA WITH LINER S=1602 m² ELV.:149.69 TANK PAD FOUNDATION
REFER TO DWG 61-680-230-002 FOR EXCAVATION DETAIL
REFER TO DWG 61-680-230-003 FOR FILL DETAIL
REFER TO DWG 61-680-230-004 AND 005
FOR CROSS-SECTIONS S=1602 m² TOP OF LINER ELEVATION= 150.9m REFER TO DWG 61-680-230-002 FOR EXCAVATION DETAIL REFER TO DWG 61-680-230-003 FOR FILL DETAIL REFER TO DWG 61-680-230-004 AND 005 FOR CROSS-SECTIONS NOTES GÉNÉRALES / GENERAL NOTES TABLE 1 : MATERIAL QUANTITIES THE UNITS SYSTEM IS METRIC AND THE COORDINATES SYSTEM IS UTM14NAD83. . A GEOTECHNICAL SURVEY CONSISTING OF DRILLING 11 HOLES IN THE FUTURE TANK AREA WAS UNDERTAKEN BY TAMRCO ON 2022-04-18. RESULTS ARE GIVEN ON DRAWING 61-680-230-002. REQUIRED CONTAINMENT CAPACITY 6 243 270 L NEW TANK 6168TNK035
NOMINAL DIAMETER = 21.039 m
NOMINAL HEIGHT = 9.677 m
MAXIMUM CAPACITY = 3.362 m²
REFER TO MECHANICAL DRAWINGS
FOR DETAILS SECONDARY CONTAINMEN AVAILABLE CAPACITY 7 394 000 L 3. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE SAFETY AND SLOPES OF ALL EXCAVATIONS, BACKFILL AND SHALL ABIDE BY ALL PELEVANT STANDARDS AND REGULATIONS. THE STABILITY, DEWATERING AND MAINTENANCE OF ALL EXCAVATIONS SUMP PIT TOP ELEVATION: 147.70 RFFFR TO DETAIL 3 ON DWG 61-680-230-003 ELV.:151.05--ELV.:151.05 FREEBOARD EVALUATION 2.6% N-7213468 63 -ELV.:149.75 TABLE 2 : SECONDARY CONTAINMENT CAPACITY OR BACKFILL SHALL BE THE CONTRACOR'S RESPONSIBILITY. NESPONSIBILITY.

THE CONTRACTOR MUST COORDINATE WITH THE OTHER CONTRACTORS ON SITE (MECHANICA/ELECTRICAL/INSTRUMENTATION) RESPONSIBLE FOR THE FUEL TANK, PIPES, GROUNDING CABLE, ETC. BEFORE FINALZIMO THE CIVIL WORKS. N:7213463.00 -E:638251.68 ELV::147.40 ASTM TEST METHOI TEST PARAMETER N:7213462.87 -E:638255.49 ELV.:149.33 -ELV.:150.39 EXISTING FUEL PIPE TO BE REMOVED (REFER TO MECHANICAL DRAWINGS) Elongation (%) . THE CONTRACTOR SHALL COLLABORATE WITH THE PERSON IN CHARGE OF THE -ELV.:150.40 ELV.:150.00 2.6% WITH THE PERSON IN CHARGE OF THE
QUALITY CONTROL (QA/CQ) DURNING
CONSTRUCTION, VISUAL INSPECTION AND
ESTIME DOCUMENTATION SHALL BE
PERSONNELL BY
FILLING A NEW LAYER OF LINES.

AN AS-BULL TORNING SHALL BE
PROVIDED ATTER CONSTRUCTION. THE
AS-BULL SHAYEY SHALL BENCLOSE THE
ENTIRE TANK FARM, INLOUDING THE DIKES
AROUAD THE EXISTING TANK. Tear (N / Ibs) -ELV.:150.39 4,560 / 1,025 N:7213464.64 E:638208.11 ELV::150.00 ELV.:149. Weight (g/m² / oz/yd²) -ELV.:150.40 ELV.:150.40 EXISTING FUEL PIPE TO BE KEPT IN PLACE N:7213464.60 E:638205.76 ELV.:151.05 SLOPE 1V:120H TABLE 3: REQUIRED MINIMUM NON-WOVEN
GEOTEXTILE PROPERTIES -ELV.:150.39 2.6% -FLV -150.09 Chromatic c-comme of it is prompt at which that call of the extends on abuse, was unbounds for whicher, that measures or comple a wine of that allocate while of that you subset chromatics for rela-tion before 2, pages part of 19. FLV::150:00-ELV.:150.40-THE INFORMATION COLD IN THE PROPERTY OF ARREST CHARLE US. NO MICH SE ANIMARIS (FOR ARREST, STREET WITHOUT ANY COPYON THE LONG AND PROPERTY, STREET WITHOUT AND ARREST CORE CO. ELV.:150.39-ASTM TEST METHOD ELV.:149.59-DESSINS EN RÉFÉRENCE / REFERENCE DRAWING TEST PARAMETER N:7213460.10 --E:638258.15 ELV.:153-05 TITRE / TITLE # DWG AS-BULT 2009-03-31 V02259-W08-001 1.5 / 60 05994 N:7213457.22 -E:638249.25 ELV:149.39 FUTURE FUEL PIPE - (REFER TO MECHANICAL DRAWINGS) 2.2% ELV.:151.05 D638 Modified Die 50 mm/ 1% -ELV.:149.62 Stress @ Yield (kN/m / ppi) ELV.:149.76 WORKS AREA LIMITS TIE-IN WITH EXISTING GROUND FUTURES PIPES AND
ELECTRICAL CABLE
(REFER TO MECHANICAL AND
ELECTRICAL DRAWINGS) -FLV -151 05 Stress @ Break (kN/m / ppi AGNICO EAGLE 187 / 42 Tear Resistance (N / Ibs' N:7213443.45 -E:638237.72 ELV:150.05 N:7213438.72 -E:638242.26 ELV::150.05 Puncture Resistance (N / Ibs) 400 / 90 Method 2065

TABLE 4 : REQUIRED MINIMUM HDPE GEOMEMBRANE PROPERTIES

N:7213441.03 E:638235.20 ELV::150.05 REVISIONS PERMITTO PRACTICE TETRATECH OF NC. LINER TO BE WELDED WITH THE EXISITNG ONE S=30m² REFER TO DETAIL 4 ON DWG 61-680-230-003 0562 H 302 N:7213438.29 E:638235.05 CONNECTION CHANNEL WIDTH =3.5m
TOP ELEVATION=150.05m
REFER TO DWG 61-680-220-003 FOR FILL DETAIL
REFER TO DWG 61-680-220-004 AND 005 FOR CROSS-SECTIONS² E/TITLE
AGNICO EAGLE — MEADOWBANK DIVISION
680 — FUEL FARM 680-TK-240 EXISITING TANK MAXIMUM CAPACITY = 5675.5 m3 N:7213436.33 E:638239.71 ELV.:150.05 230 - GENERAL EARTH WORKS PLAN VIEW

3.3 ML FUEL TANK FARM
PROPOSED LAYOUT POUR CONSTRUCTION
FOR CONSTRUCTION EDUARDO RODRIGUEZ - EXISTING DIKE BOTTOM SOLENE MOREAU EXISTING FUEL PIPE TO BE KEPT IN PLACE JOSEF ALARIE 61-680-230-001 PLAN VIEW 1:200 61 (TT#47731)

FILE NO. 61-680-230-001.dw

RO

DATE 2022-04-2

2022-04-

2022-04-1 2022-04-20

