



Robin Ikkutisluk <robin.ikkutisluk@nwb-oen.ca>

Fwd: question licence 2BE-MEA1318

5 messages

Christine Wilson <Christine.Wilson@aandc-aadnc.gc.ca>
To: robin.ikkutisluk@nunavutwaterboard.org

Mon, Nov 18, 2013 at 2:20 PM

hey can you forward this email over to who ever is working on this file. Thanks!!

Chris

----- Forwarded message -----

From: David Frenette <david.frenette@agnicoeagle.com>
To: "Christine Wilson (Christine.Wilson@aandc-aadnc.gc.ca)" <Christine.Wilson@aandc-aadnc.gc.ca>
Cc:
Date: Mon, 18 Nov 2013 13:40:40 -0500
Subject: question licence 2BE-MEA1318

Hello Christine,

I have a question for you, related to the licence 2BE-MEA1318. We will have to install a new fuel deposit for the exploration in the north side of our property (IVR area). Do I have to request an amendment to the licence to install this deposit? In the part H3 of the licence, the requirement related to a fuel cache are written. How many fuel you can stock in an area and consider that a cache? If we talk of 50 000 liters?

3. The Licensee shall prevent any chemicals, petroleum products or wastes associated with the project from entering Water. All sumps and fuel caches shall be located at a distance of at least thirty one (31) metres from the ordinary High Water Mark of any adjacent water body and inspected on a regular basis. An exception to this condition is provided for in Part H, Item 4.

David Frenette
Coordonnateur environnement

david.frenette@agnicoeagle.com

T: 819.874.5980 x3622

Agnico Eagle Mines Limited
765, chemin de la mine Goldex
Val-d'Or, QC, Canada
J9P 4N9

agnicoeagle.com



AGNICO EAGLE



Christine Wilson <Christine.Wilson@aandc-aadnc.gc.ca>
To: David Frenette <david.frenette@agnicoeagle.com>
Cc: Robin Ikkutisluk <robin.ikkutisluk@nunavutwaterboard.org>

Mon, Nov 18, 2013 at 2:32 PM

Hi David,

Two questions

What is the IVR area ?
Will AEM continue to use the fuel tanks onsite or replacing/ modifying them?
Will the fuel storage area become larger?
What type of fuel storage barrels, tanks, bladders?

There is section in the license which allows for small changes referred to as modifications. These changes must be improvements which do not change the scope of the license. I have forwarded your emails off to a Tech at NWB and hopefully you will be able to clarify these questions I asked before they respond to your questions below.

Regards,

Christine Wilson

Water Resource Officer- Kivalliq Region
Field Operations Unit
Aboriginal Affairs and Northern Development Canada
Nunavut Regional Office
P.O. Box 100
Iqaluit, Nunavut X0A 0H0
Ph: 867-975-4296
Fx: 867-979-6445

>>> David Frenette <david.frenette@agnicoeagle.com> 11/18/2013 1:40 PM >>>

Hello Christine,

I have a question for you, related to the licence 2BE-MEA1318. We will have to install a new fuel deposit for the exploration in the north side of our property (IVR area). Do I have to request an amendment to the licence to install this deposit? In the part H3 of the licence, the requirement related to a fuel cache are written. How many fuel you can stock in an area and consider that a cache? If we talk of 50 000 liters?

3. The Licensee shall prevent any chemicals, petroleum products or wastes associated with the project from entering Water. All sumps and fuel caches shall be located at a distance of at least thirty one (31) metres from the ordinary High Water Mark of any adjacent water body and inspected on a regular basis. An exception to this condition is provided for in Part H, Item 4.

David Frenette
Coordonnateur environnement

david.frenette@agnicoeagle.com

T: 819.874.5980 x3622

Agnico Eagle Mines Limited
765, chemin de la mine Goldex
Val-d'Or, QC, Canada
J9P 4N9

agnicoeagle.com



AGNICO EAGLE



Robin Ikkutisluk <robin.ikkutisluk@nwb-oen.ca>
To: Karén Kharatyan <karen.kharatyan@nwb-oen.ca>
Cc: Phyllis Beaulieu <phyllis.beaulieu@nwb-oen.ca>

Mon, Nov 18, 2013 at 3:20 PM

Hi Karen,

Please see correspondence between AANDC and Agnico Eagle regarding the Meadowbank file 2BE-MEA1318.

Regards,
Robin Ikkutisluk
Licence Administrator Assistant
Nunavut Water Board

Forwarded conversationSubject: **Fwd: question licence 2BE-MEA1318**

From: **Christine Wilson** <Christine.Wilson@aandc-aadnc.gc.ca>
Date: Mon, Nov 18, 2013 at 2:20 PM
To: robin.ikkutisluk@nunavutwaterboard.org

hey can your forward this email over to who ever is working on this file. Thanks!!

Chris

----- Forwarded message -----

From: David Frenette <david.frenette@agnicoeagle.com>
To: "Christine Wilson (Christine.Wilson@aandc-aadnc.gc.ca)" <Christine.Wilson@aandc-aadnc.gc.ca>
Cc:
Date: Mon, 18 Nov 2013 13:40:40 -0500
Subject: question licence 2BE-MEA1318

Hello Christine,

I have a question for you, related to the licence 2BE-MEA1318. We will have to install a new fuel deposit for the exploration in the north side of our property (IVR area). Do I have to request an amendment to the licence to install this deposit? In the part H3 of the licence, the requirement related to a fuel cache are written. How many fuel you can stock in an area and consider that a cache? If we talk of 50 000 liters?

3. The Licensee shall prevent any chemicals, petroleum products or wastes associated with the project from entering Water. All sumps and fuel caches shall be located at a distance of at least thirty one (31) metres from the ordinary High Water Mark of any adjacent water body and inspected on a regular basis. An exception to this condition is provided for in Part H, Item 4.

David Frenette
Coordonnateur environnement

david.frenette@agnicoeagle.com

T: 819.874.5980 x3622

Agnico Eagle Mines Limited
765, chemin de la mine Goldex
Val-d'Or, QC, Canada
J9P 4N9

agnicoeagle.com



AGNICO EAGLE



From: **Christine Wilson** <Christine.Wilson@aandc-aadnc.gc.ca>
Date: Mon, Nov 18, 2013 at 2:32 PM
To: David Frenette <david.frenette@agnicoeagle.com>
Cc: Robin Ikkutisluk <robin.ikkutisluk@nunavutwaterboard.org>

[Quoted text hidden]

Karén Kharatyan <karen.kharatyan@nwb-oen.ca>
To: david.frenette@agnicoeagle.com
Cc: Christine.Wilson@aandc-aadnc.gc.ca, [Phyllis Beaulieu <Phyllis.Beaulieu@nwb-oen.ca>](mailto:Phyllis.Beaulieu@nwb-oen.ca), [Robin Ikkutisluk <Robin.Ikkutisluk@nwb-oen.ca>](mailto:Robin.Ikkutisluk@nwb-oen.ca)

Hi David,

The Licence 2BE-MEA0813 doesn't specify the number of fuel caches and actual volume of fuel of fuel cache. If the addition means a construction/installation

of a bulk fuel station involving many hundred thousands or more L it could require a Board approval through an amendment. However, I believe an additional 50000 L cache is not that case and wouldn't require construction/installation of a bulk fuel station, and may be considered as a non major modification without an amendment to the licence.

I hope it helps,
Karen



Karén Kharatyan, Ph. D- ԵՄԻԱԿԱՆ ԲՏՈՒՆՔ

Technical Advisor- Conseiller technique

ᐱᓗᑦᑐᑦ ᐱᓗᑦᑐᑦ ᐱᓗᑦᑐᑦ ᐱᓗᑦᑐᑦ - Piluaqnaqtuliginigmun Ikayuqti

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᓴᓐ ᐱᓕᓂᓴᓐ ᓂᓄᓴᓐᓴᓐ - NUNAVUT IMALIRIYIN KATIMAYINGI
www.nwb-oen.ca

P.O. Box 119
Gjoa Haven, NU, X0B 1J0

C.P. 119
Gjoa Haven (Nunavut), X0B 1J0

በበኛኞች 119
 ጥያቄ, ጤና X0B 1J0

Titigaqavua 119
Uqhuqtuuq, NU, X0B 1J0

Toll Free / Sans Frais / ᐱᕈᖅᓴᑦᑐᖅ / Akiittuq: 1-855-521-3745

Tel / Téléphone / ᐃᑭᐅᑦ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᐃᑭᐅᑦ / Fax-kut: (867) 360-6369

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courrier électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

[Quoted text hidden]

Karén Kharatyan <karen.kharatyan@nwb-oen.ca>

Wed, Dec 4, 2013 at 6:37 AM

To: david.frenette@agnicoeagle.com

Cc: Christine.Wilson@aandc-aadnc.gc.ca, Phyllis Beaulieu <phyllis.beaulieu@nwb-oen.ca>, Robin Ikkutisluk <robin.ikkutisluk@nwb-oen.ca>

Find please below my reply sent on November 19, 2013.



Karén Kharatyan, Ph. D- ԵՌԱԳ ԲՏՈՂԴԱՐԱՆ

Technical Advisor- Conseiller technique

ᐱᓗᑦᑐᐃᐅᕐᓂᐊᕐᒃ ᐃᔭᕐᓂᐊ- Piliuqnaqtuliginigmun Ikayuqti

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᑦ ᐱᓕᓂᐸᑦ ᓅᓃᓴᐸᑦ - NUNAVUT IMALIRIYIN KATIMAYINGI
www.nwb-oen.ca

www.nwb-oen.ca

P.O. Box 119
Gjoa Haven, NU, X0B 1J0

C.P. 119
Gjoa Haven (Nunavut), X0B 1J0

၂၀၁၆-၁၇ ၁၁၉
၂၀၁၆-၁၇, ၁၁၉ X0B 1J0

Titigaqavua 119
Uqhuqtunq, NU, X0B 1J0

Toll Free / Sans Frais / ᐱᕈᖅᕐᕐᕐᕐ / Akiittuq: 1-855-521-3745

Tel / Téléphone / ᐅᑦᓴᐃᑦ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᐅᑦᓴᐃᑦ / Fax-kut: (867) 360-6369

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(s) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courriel électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



 Merci de penser à l'environnement avant d'imprimer ce courriel / Thank you for thinking of the environment before printing this email

[Quoted text hidden]