



March 12th, 2016 Sewage spill

Please find the following information as a follow up to the Spill report submitted March 13th, 2016 by Agnico Eagle Meadowbank division. This detailed report is submitted to the Inspector in compliance with the conditions under the Nunavut Water Board License 2AM-MEA1525, Part H, Item 8c.

Spill Description

On March 12th, 2016, a fitting on the sewage line bringing treated sewage to the Stormwater Management Pond broke and resulted in sewage being discharge upstream of its usual location. Although the product was still being discharge within the Stormwater pond area, a portion of the sewage went underneath the road and was contained in a section facing north between the airstrip and the road.

Stormwater Management Pond



Water

There were no off site impact or discharge to any receiving watercourses.