

Richard Dwyer

From: Stéphane Robert [stephane.robert@agnico-eagle.com]
Sent: Monday, February 02, 2009 1:29 PM
To: Richard Dwyer
Cc: Spavor, Carrie [lqa]; Wilson, Anne [Yel]; Sylvain Doire; Rachel Gould
Subject: RE: 2AM-MEA0815 Meadowbank Project December 2008 Monitoring Report

Hi Richard

In December and January, a misunderstanding occurs between AEM and the lab and the nitrate and nitrite was not analyzed. Starting today, AEM will make sure that all the analysis would be made according to his Sewage Treatment plant O&M manual.

If you have any questions do not hesitate to contact me.



Stéphane Robert
Environment superintendent
Agnico-Eagle
Meadowbank Division
Phone: 819-759-3700 ext. 814
Cel: 819-763-0229
stephane.robert@agnico-eagle.com

From: Wilson, Anne [Yel] [mailto:Anne.Wilson@EC.GC.CA]
Sent: Sunday, February 01, 2009 1:43 PM
To: Richard Dwyer
Cc: Stéphane Robert; Spavor, Carrie [lqa]
Subject: RE: 2AM-MEA0815 Meadowbank Project December 2008 Monitoring Report

Hi Richard,

Thank you for forwarding the Dec. 2008 monitoring report. I noted that the sewage treatment plant effluent was not analysed for ammonia (just nitrate + nitrite) and would suggest this should be measured. At some point the ammonia balance will need to be reviewed, and this is a measurable source. Also, the Sewage Treatment Plant O&M manual specifies that ammonia will be tested:

Water quality sampling of the input and final discharges from the Seprotech and Biodisk RBC units is conducted weekly. Water samples are tested for:

- Ammonia
- Biological Oxygen Demand (BOD₅)
- Faecal Coliforms
- pH
- Total Suspended Solids
- Total Phosphate

Regards,

Anne

From: Richard Dwyer [mailto:licensingadmin@nunavutwaterboard.org]

Sent: Friday, January 30, 2009 10:26 AM

To: stephane.robert@agnico-eagle.com

Cc: 'AEM Kathryn McIvor'; 'AEM Larry Connell'; 'AEM Louise Grondin'; 'AEM Martin Bergeron'; 'AEM Rachel Gould'; 'Baker Lake HTO'; 'Bill Tilleman'; 'CGS Robert Chapple'; 'CLEY'; 'CLEY Julie Ross'; 'CLO Arviat'; 'CLO Baker Lake'; 'DFO Amy Liu'; 'DFO Bradley Flynn'; 'DFO Gary Cooper'; 'DFO Julian Lim'; 'DFO Keith Pelley'; 'DOE Earle Baddaloo'; 'DOE Mike Mifflin'; 'Wilson, Anne [Yel]'; 'Lambert, Stacey [Edm]'; 'INAC Andrea Cull'; 'INAC Andrew Keim'; 'INAC Chris Keats'; 'INAC David Abernethy'; 'INAC David Ningeongan'; 'INAC Froydis Reinhart'; 'INAC Kevin Buck'; 'INAC Peter Kusugak'; 'INAC Spencer Dewar'; 'INAC Tanya Trenholm'; 'John Donihee'; 'Justice Ken Landa'; 'KIA Baker Lake'; 'KIA Jose Kusugak'; 'KIA Luis Manzo'; 'KIA M Serra'; 'KIA Stephen Hartman'; 'KIA Veronic Tattauinee'; 'NAM Lewis Gidzinski'; 'NIRB Amanda Hanson'; 'NIRB Leslie Payette'; 'NPC Bobby Suluk'; 'NPC Brian Aglukark'; 'NTI Carson Gillis'; 'NTI George Hakongak'; 'NTI Keith Morrison'; 'NWB David Hohnstein'; 'NWB Deon Bridge'; 'NWB Dionne Filiatrault'; 'NWB Don Carr'; 'NWB/BGC Jack Seto'; 'NWB/TLA Karlette Tunaley'; 'NWB/TLA Steve Lines'; 'NWMB Joe Justus'; 'NWMB Paul Frame'; 'PC Paula Hughson'; 'Rosemary Kilpatrick'

Subject: 2AM-MEA0815 Meadowbank Project December 2008 Monitoring Report

Good morning;

Agnico-Eagle have submitted December 2008 monitoring report (attached), this submission is distributed for information. The Nunavut Water Board will review comments received on report.

Regards,

Richard Dwyer
Licensing Administrator
Nunavut Water Board
PH: 867-360-6338 ext.29
FX: 867-360-6369