

MEADOWBANK DIVISION

Monitoring Program Summary Report

July 2011

Type A Water License 2AM-MEA0815

Table of Contents

SECTION 1 •

SECTION 2 •

2.1 Water Usage	2
2.2 SEWAGE TREATMENT PLANT MONITORING	2
2.3 DEWATERING	3
2.3.1 Northwest Arm of Second Portage Lake	3
2.3.2 Bay Goose Impoundment Area	6
SECTION 3 • SPILL MANAGEMENT SUMMARY	
List of Tables	
Table 2-1: Freshwater Usage (m ³)	2

Table 2-2: STP Effluent Results2Table 2-3: Second Portage Arm Dewatering Monitoring – pH and Al3Table 2-4: Second Portage Arm Dewatering Monitoring – TSS and Turbidity5Table 2-5: Bay Goose Impoundment Area Dewatering Monitoring – pH and Al6Table 2-6: Bay Goose Impoundment Area Dewatering Monitoring – TSS and Turbidity6Table 3-1: Summary of AEM Internal Spill Reports7

SECTION 1 • BACKGROUND

As required under Part I, Item 25 of Type A Water License 2AM-MEA0815, this report documents the water management and monitoring activity at the mine site for the month. This activity includes: water usage, sewage treatment plant discharge water quality and dewatering monitoring.

Additionally, a summary of the AEM internal spill reporting for the month is included.

SECTION 2 • WATER MANAGEMENT

2.1 WATER USAGE

Freshwater usage for July 2011 is summarized in Table 2.1 below. Freshwater usage for the month totals 94,595 m³. The consumption of fresh water for mine and mill operations (including production drills, batch plant and dust control) was 89,247 m³ and the consumption of reclaim water in the mill was 209,868 m³.

Table 2-1: Freshwater Usage (m³)

	July
Camp	3186
Mine & Mill Operations	89247
Emulsion Plant	193
Water Truck	1970
Total	94,595

2.2 SEWAGE TREATMENT PLANT MONITORING

Four water samples were taken at the effluent of the sewage treatment plants (STP) in July. The results showed the system is working well.

Table 2.2 presents the monitoring results.

Table 2-2: STP Effluent Results

Date	Units	4-Jul-11	12-Jul-11	18-Jul-11	25-Jul-11
Ammonia	mg/L	< 0.05	<0.05	< 0.05	< 0.05
BOD-5	mg/L	4	4	4	1
COD (mg/L)	mg/L	54	59	41	45
Total Suspended Solids	mg/L	16	8	11	6
Nitrite	mg N/L	<0.01	<0.01	0.01	<0.01
Nitrate	mg N/L	39.4	40.9	43.0	38.9
pH *	units	3.60	3.80	4.10	3.60
Total Phosphorus	mg/L	11.8	11.8	13.8	12.8
Fecal Coliform	UFC/100 mL	<4	2	<2	4
Total Coliform	UFC/100 mL	600	10	20	4

2.3 DEWATERING

2.3.1 Northwest Arm of Second Portage Lake

Dewatering of the northwest arm of Second Portage Lake continued throughout the month. The water treatment plants were in operation for 23 of the 30 days.

The pH and Aluminum concentrations at the outlets of the TSS water treatment plants were as follows:

- pH 24 hour minimum/maximum: 6.33/7.13 units (Limit is 6-9 units)
- Al 24 hour maximum concentration: 0.963 mg/L (Limit is 1.5 mg/L)

Table 2.3 summarizes the dewatering monitoring results for pH and Aluminum for the month.

Table 2-3: Second Portage Arm Dewatering Monitoring – pH and Al

	DD-WTP-01		DD-V	VTP-02	Both WT	P Outlets
Date	рН	Total Al	рН	Total Al	pH 24- hour Mean	Al 24- hour Mean
	units	mg/L	units	mg/L	units	mg/L
2011-07-04	6.31	0.687	6.34	0.689	6.33	0.688
2011-07-05	6.67		6.56		6.62	
2011-07-06	6.63		6.51		6.57	
2011-07-10	6.62		6.93		6.78	
2011-07-11	6.62	0.694			6.62	0.694
2011-07-12	6.71		6.72		6.72	
2011-07-13	6.71		6.78		6.75	
2011-07-14			6.71		6.71	
2011-07-15	6.76				6.76	
2011-07-16	6.90				6.90	
2011-07-17	6.71		6.67		6.69	
2011-07-18	6.79	0.805	6.53	1.120	6.66	0.963
2011-07-20	6.51		6.77		6.64	
2011-07-21	6.94		7.00		6.97	
2011-07-22			7.13		7.13	
2011-07-23			6.63		6.63	
2011-07-24			6.66		6.66	
2011-07-25			6.54	0.560	6.54	0.560
2011-07-26			6.80		6.80	
2011-07-27			6.72		6.72	
2011-07-30	6.61				6.61	
2011-07-31	6.94				6.94	

There was one exceedance of the 24 hour mean regulatory criteria (22.5 mg/L) for Total Suspended Solids (TSS); July 31 (80 mg/L). The plant operators took immediate mitigative measures to reduce the TSS concentrations at the outlet; the following day the TSS concentration was below the regulatory criteria (7 mg/L). The 30 day mean TSS concentration remained below the regulatory criteria of 15 mg/L.

A representative from John Meunier Inc., the water treatment plant supplier, has been working at the site since July 23, 2011. A performance review of the water treatment plant was completed; all equipment settings were adjusted to optimize TSS removal. A review of the operating parameters and procedures, and an identification of equipment repairs, if any, was also completed.

The turbidity and TSS concentrations at the outlets of the TSS water treatment plants were as follows:

- NTU 24 hour mean maximum concentration: 9.9 NTU (Maximum Limit is 30 NTU)
- TSS 24 hour mean maximum concentration: 80 mg/L (Maximum Limit is 22.5 mg/L)
- NTU 30 days mean maximum concentration: 4.6 NTU (Maximum Limit is 15 NTU)
- TSS 30 days mean maximum concentration: 12 mg/L (Maximum Limit is 15 mg/L)

Table 2.4 summarizes the dewatering monitoring results for turbidity and TSS for the month.

Table 2-4: Second Portage Arm Dewatering Monitoring – TSS and Turbidity

	DD-WTF	P-01(Out)	DD-WTF	P-02(Out)		Both WTP	Outlets	
	24-hour		24-hour		NTU 24-	TSS 24-	NTU 30-	TSS 30-
Date	Mean	Lab TSS	Mean	Lab TSS	hour	hour	day	day
					Mean	Mean	Mean	Mean
	NTU	mg/L	NTU	mg/L	NTU	mg/L	NTU	mg/L
2011-07-01		peration		peration				
2011-07-02		peration		peration				
2011-07-03		peration		peration				
2011-07-04	3.6	11	3.19	10	3.4	11	3.5	10
2011-07-05	3.2	6	2.79	10	3.0	8	3.6	10
2011-07-06	1.9	7	1.69	9	1.8	8	3.6	10
2011-07-07		peration		peration				
2011-07-08		peration		peration				
2011-07-09		peration	Not in o	peration				
2011-07-10	3.6	10	8.11	4	5.9	7	3.8	10
2011-07-11	3.9	11		peration	3.9	11	3.9	10
2011-07-12	2.7	6	1.97	2	2.3	4	3.9	10
2011-07-13	4.4	12	2.50	7	3.5	10	3.9	11
2011-07-14	Not in c	peration	5.01	12	5.0	12	4.0	11
2011-07-15	9.9	14	Not in o	peration	9.9	14	4.3	11
2011-07-16	3.5	5	Not in o	peration	3.5	5	4.4	11
2011-07-17	5.6	5	4.90	17	5.3	11	4.5	11
2011-07-18	3.8	14	4.71	16	4.3	15	4.6	11
2011-07-19	Not in operation		Not in o	peration				
2011-07-20	2.2	8	2.55	8	2.4	8	4.6	11
2011-07-21	2.2	6	2.72	7	2.4	7	4.5	11
2011-07-22	Not in c	peration	1.36	3	1.4	3	4.5	11
2011-07-23	Not in c	peration	0.79	4	0.8	4	4.4	10
2011-07-24	Not in c	peration	0.35	4	0.4	4	4.3	11
2011-07-25	Not in c	peration	0.32	9	0.3	9	4.3	11
2011-07-26	Not in c	peration	1.62	4	1.6	4	4.3	11
2011-07-27	Not in c	peration	0.38	2	0.4	2	4.2	10
2011-07-28	Not in c	peration	Not in o	peration				
2011-07-29	Not in c	peration	Not in o	peration				
2011-07-30	1.8	3	Not in o	peration	1.8	3	4.0	10
2011-07-31	1.8	80	Not in o	peration	1.8	80	3.8	12

2.3.2 Bay Goose Impoundment Area

Dewatering of the Bay Goose impoundment area began on July 26, 2011. One pump was in operation for the last week of July.

The pH and Aluminum concentrations at the pump intakes were as follows:

- pH 24 hour minimum/maximum: 6.72/7.31 units (Limit is 6-9 units)
- Al 24 hour maximum concentration: 0.256 mg/L (Limit is 1.5 mg/L)

Table 2.5 summarizes the dewatering monitoring results for pH and Aluminum for the month.

Table 2-5: Bay Goose Impoundment Area Dewatering Monitoring – pH and Al

	BG-PUMP-1		BG-PUMP-2		Both PUMPS	
Date	рН	Total Al	рН	Total Al	pH 24- hour Mean	Al 24- hour Mean
	units	mg/L	units	mg/L	units	mg/L
2011-07-26	6.94		Not in	Not in operation		
2011-07-27	6.95		Not in	Not in operation		
2011-07-28	6.72	0.256	Not in	operation	6.72	0.256
2011-07-30	6.81		Not in operation		6.81	
2011-07-31	7.31		Not in	operation	7.31	

The turbidity and TSS concentrations at the pump intakes were as follows:

- NTU 24 hour mean maximum concentration: 6.1 NTU (Maximum Limit is 30 NTU)
- TSS 24 hour mean maximum concentration: 4 mg/L (Maximum Limit is 22.5 mg/L)

30-day means for TSS and turbidity will be calculated once the pumps have been in operation for 30 days.

Table 2.6 summarizes the dewatering monitoring results for turbidity and TSS for the month.

Table 2-6: Bay Goose Impoundment Area Dewatering Monitoring – TSS and Turbidity

	BG-PUMP-1		BG-PUMP-2		Both PUMPS			
Date	24-hour Mean	Lab TSS	24-hour Mean	Lab TSS	NTU 24- hour Mean	TSS 24- hour Mean	NTU 30- day Mean	TSS 30-day Mean
	NTU	mg/L	NTU	mg/L	NTU	mg/L	NTU	mg/L
2010-07-26	6.6	4	Not in operation			4		
2010-07-27	8.8	2	Not in operation			2		
2010-07-28	4.9	1	Not in operation			1		
2010-07-30	6.1	2	Not in operation		6.1	2		
2010-07-31	4.1	2	Not in o	peration	4.1	2		

SECTION 3 • SPILL MANAGEMENT SUMMARY

AEM has developed a system of tracking spills on-site. Table 3.1 summarizes the AEM internal spill reports for the month. Eleven spills occurred on site and two were reported to the GN spill hotline.

Table 3-1: Summary of AEM Internal Spill Reports

Date of Spill	Hazardous Material	Quantity	Location	Cause of spill	Clean-up action taken	Reported to Spill Hot Line
2011-07-01	Hydraulic oil	~ 20 L (numerous spots)	Along AWPAR from Meadowbank to Emulsion	Tractor trailer went off the road and tipped	Contaminated soil taken to Hazmat area	N
2011-07-03	Fuel	80 L	Wash Bay	Rock pierced the fuel line	Contaminated soil taken to Hazmat area	N
2011-07-04	Anti-Freeze	3 L	Truck Shop	Broken hose	Contaminated soil taken to Hazmat area	N
2011-07-05	Glycol	30 L	Old genset	Gasket not tight enough	Contaminated soil taken to Hazmat area	N
2011-07-06	Hydraulic oil	~ 8 L	Drill bit shop	The intercooler of the skytrack cracked	Contaminated soil taken to Hazmat area	N
2011-07-18	Fuel	280 L	Road in front of the TCG-Sana pad	Fire in the injection unit	Contaminated water was stored in totes for treatment; contaminated soil taken to Quarry 22	Υ
2011-07-19	Hydraulic oil	35 L	Dewatering pump on Second portage arm	Broken hydraulic hose	Contaminated soil taken to Hazmat area	N
2011-07-21	Fuel	500 L	Baker Lake refueling station	Over-filling	Contaminated soil taken to Quarry 22	Υ
2011-07-22	Fuel	5 L	AWPAR km 80	Tractor trailer went on the side and tipped	Contaminated soil taken to Hazmat area	N
2011-07-24	Hydraulic oil	80 L	South portage pit	Broken hydraulic hose	Contaminated soil taken to Hazmat area	N
2011-07-26	Hydraulic oil	90 L	South portage pit	Broken hydraulic hose	Contaminated soil taken to Hazmat area	N