



MEADOWBANK DIVISION

Monitoring Program Summary Report

July 2017

Type A Water License 2AM-MEA1525

Table of Contents

SECTION 1 • BACKGROUND 3

SECTION 2 • WATER MANAGEMENT 4

2.1 WATER USAGE4

2.2 WASTE ROCK STORAGE FACILITY SEEPAGE4

2.3 CENTRAL DIKE SEEPAGE4

2.4 ASSAY ROAD SEEPAGE4

2.5 SEEPAGE AND RUNOFF FROM THE LANDFILL.....4

2.6 SEEPAGE AT PIT WALL AND PIT WALL FREEZE/THAW AND PERMAFROST AGGRADATION5

2.7 SEWAGE TREATMENT PLANT5

2.8 VAULT ATTENUATION POND EFFLUENT6

2.9 EAST DIKE SEEPAGE EFFLUENT.....6

2.10 NON CONTACT WATER7

SECTION 3 • SPILL MANAGEMENT 8

SECTION 1 • BACKGROUND

As required under Part I, Item 20 of Type A Water License 2AM-MEA1525, this report documents the water management and monitoring activities at the mine site for the month. This includes water usage, Vault Attenuation Pond discharge water quality, East Dike Seepage discharge water quality, RSF Seepage, Central Dike Seepage, Assay Road Seepage, and sewage treatment plant discharge water quality (which are directed to the onsite storm water management pond).

In addition, a summary of spills/actions for the month is reported.

SECTION 2 • WATER MANAGEMENT

2.1 WATER USAGE

Fresh and reclaim water usage for July 2017 is summarized in Table 2-1 below.

Table 2-1: Freshwater Usage (m³)

Water Location	Source	January	February	March	April	May	June	July	Total 2017
Camp	Third Portage Lake	3,623	3,144	3,444	3,490	3,692	3,697	3,818	24,908
Mill (freshwater tank)	Third Portage Lake	45,068	41,345	33,328	53,001	53,152	39,661	43,494	309,049
Emulsion plant	No-name Lake	86	97	97	96	101	100	129	706
Total Freshwater Usage (m³)		48,777	44,586	36,869	56,587	56,945	43,458	47,441	334,663
Reclaim Water Usage (m³)	Tailing Pond	252,232	232,324	247,396	227,667	246,007	247,131	251,549	1,704,306

2.2 WASTE ROCK STORAGE FACILITY SEEPAGE

In July 2017, 5,025 m³ of water was pumped back to the North Cell TSF from the ST-16 sump. Of that amount, 960 and 1,836 m³ were transferred from the WEP1 and WEP2 sumps respectively to the ST-16 sump.

As per the 2017 Freshet Action Plan, Agnico Eagle completed in July the freshet inspections at the Portage and Vault RSFs, and NP-2 Lake. No major issues were observed. Open water sampling at WEP1 (Station ST-30) and WEP2 (Station ST-31) required under the Freshet Action Plan was completed in July. Open water sampling was also completed in July for ST-16, NP-2 and the downstream lakes.

2.3 CENTRAL DIKE SEEPAGE

In July 2017, 424,499 m³ of water was pumped from the ST-S-5 sump back into the South Cell TSF. Total year to date is 3,118,829 m³.

Sampling was conducted monthly at ST-S-5 and the South Cell TSF (ST-21) as per the requirements of the NWB water license.

Daily visual inspections were also completed by the Engineering Department.

2.4 ASSAY ROAD SEEPAGE

In July 2017, 4,961 m³ of water was pumped back from well MW-203 back to the mill. Weekly inspections of the area were conducted this month. Well monitoring for CN downstream of the trench as well as open water monitoring required under the Freshet Action Plan were completed in July.

2.5 SEEPAGE AND RUNOFF FROM THE LANDFILL

The landfill was inspected weekly and no seepage or runoff was observed.

2.6 SEEPAGE AT PIT WALL AND PIT WALL FREEZE/THAW AND PERMAFROST AGGRADATION

In July, 31,502 m³ were pumped out from Vault Pit to the Vault Attenuation Pond. A total of 21,273 m³ was pumped out from Portage Pit North to the South Cell TSF. No water was pumped out from the Portage Pit South.

2.7 SEWAGE TREATMENT PLANT

One (1) effluent wastewater sample was collected at the onsite sewage treatment plant (STP) in July 2017.

The Seprotech STP results are shown in Table 2.7.1 below; the LJ-Mix STP results are shown in Table 2.7.2. The effluent is discharged to the Stormwater Management pond which is pumped to the South Cell TSF twice a year during summer months. In July, a total of 28,193 m³ has been discharged from the Stormwater Management pond to the South Cell TSF.

Table 2.7.1: Seprotech Effluent Results

Parameters	Units	July 17, 2017
Ammonia (NH ₃)	mg N/L	0.17
Ammonia-Nitrogen (NH ₃ -NH ₄)	mg N/L	7.27
Total Kjeldahl Nitrogen	mg N/L	42.9
BOD-5	mg/L	10
COD	mg/L	84
Total Suspended Solids	mg/L	14
Nitrate	mg N/L	3.5
Nitrite	mg N/L	1.22
pH*	Units	7.2
Fecal Coliform	UFC/100 mL	480
Total Coliform	UFC/100 mL	**

*Parameter measured by STP operators, ** No result

Table 2.7.2: LJ-Mix Effluent Results

Parameters	Units	July 17, 2017
Ammonia (NH ₃)	mg N/L	0.04
Ammonia-Nitrogen (NH ₃ -NH ₄)	mg N/L	11.4
Total Kjeldahl Nitrogen	mg N/L	18
BOD-5	mg/L	7
COD	mg/L	25
Total Suspended Solids	mg/L	14
Nitrate	mg N/L	16.1
Nitrite	mg N/L	0.34
pH*	Units	6.4
Fecal Coliform	UFC/100 mL	3100

Total Coliform	UFC/100 mL	110,000
----------------	------------	---------

*Parameter measured by STP operators

2.8 VAULT ATTENUATION POND EFFLUENT

Discharge from the Vault Attenuation Pond into Wally Lake was in operation throughout the month of July. A total of 277,065 m³ of water was discharged.

TSS monitoring results for July 2017 are shown in Table 2.8.1 below. No Actiflo Water Treatment Plant was necessary during the month as the TSS levels were below the effluent criteria stated in Part F, Item 4 of Water Licence 2AM-MEA1525. Four (4) weekly effluent samples were taken at ST-10 in July. Results are presented in table 2.8.2. No water license exceedances were recorded.

Table 2.8.1: July 2017 Vault attenuation pond effluent results for TSS

Parameters	Units	3-July-17	10-July-17	17-July-17	24-July-17	Maximum Average Concentration
Total Suspended Solids	mg/L	<1	10	4	<1	3.75

Table 2.8.2: July 2017 Vault attenuation pond effluent results

Parameters	Units	3-July-17	10-July-17	17-July-17	24-July-17
Aluminum	mg/L	0.104	0.101	0.098	0.092
Sulphate	mg/L	31	32.7	40.1	41.6
Arsenic	mg/L	<0.0005	0.0043	<0.0005	<0.0005
Copper	mg/L	0.0026	0.0024	0.0031	0.0028
Nickel	mg/L	0.0045	0.0038	0.0048	0.0051
Lead	mg/L	0.0083	0.1225	<0.0003	<0.0003
Zinc	mg/L	0.003	<0.001	<0.001	0.002
Radium 226	mg/L	ND	ND	ND	0.003
Total Cyanide	mg/L	<0.001	0.205	0.002	0.001

2.9 EAST DIKE SEEPAGE EFFLUENT

On May 9, East Dike Discharge exceeded TSS results regarding the maximum allowable grab sample concentration (30 mg/L) and maximum average concentration (15 mg/L) permitted by Water License, Part F, Item 6. The event was reported via an email sent to the NU Spill Line on May 11 2017. More details were provided in May report.

In July, there was still no discharge from the East Dike Seepage to Second Portage Lake. Agnico Eagle has put in place a daily TSS monitoring program to follow the water quality.

Once the results are satisfying for Agnico Eagle and compliant with the MMER regulation for a period judged acceptable for confirmation that the TSS level meets discharge criteria, the water discharge will resume in Second Portage Lake.

2.10 NON CONTACT WATER

In July, Agnico Eagle completed inspections at ST-5 and ST-6 as per the 2017 Freshet Action Plan. Portage Area East (ST-5) and West diversion ditches (ST-6) water quality results are shown in Tables 2.10.1 and 2.10.2, respectively. TSS results did not exceed the maximum average concentration (15 mg/L) and maximum allowable grab sample concentration (30 mg/L) permitted by the Water License, Part F, Item 6.

Table 2.10.1: Portage Area East Diversion Ditch (ST-5) Results

Parameters	Units	3-July-17
Total Suspended Solids	mg/l	1

Table 2.10.2: Portage Area West Diversion Ditch (ST-6) Results

Parameters	Units	3-July-17
Total Suspended Solids	mg/l	<1

SECTION 3 • SPILL MANAGEMENT

Figure 3.1 shows reported and non-reported spills for 2017 broken down per month and Table 3.1 summarizes Agnico spill reports for July 2017. All spills reported internally (26) and to regulators (3) were managed appropriately on site according to Agnico's spill contingency plan. Spills were contained and cleaned, contaminated material was disposed to the appropriate area (landfarm, TSF if required), and the clean-up actions were monitored closely by the Environment Department. There was no off site impact to any watercourses.

Figure 3.1 2017 Reported and Non-Reported Spills




Table 3.1: Summary of Agnico Eagle Internal Spill Reports, July 2017

Date of Spill	Hazardous Material	Quantity	Units (L / Kg)	Location	Cause of spill	Clean-up action taken	Reported to Spill GN HotLine
July 1, 2017	Fuel	35	L	Portage Rock Storage Facility	The fuel tank had expended because of the high temperature and fuel overflowed	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 1, 2017	Hydraulic oil	10	L	Portage pit	Loose fitting	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 2, 2017	Hydraulic oil	200	L	Pushback parking	Broken O'ring	Spill was contained and contaminated soil picked up and disposed of appropriately	Yes
July 3, 2017	Hydraulic oil	40	L	Vault pit	Leak during mechanical works	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 3, 2017	Hydraulic oil	20	L	Tailing pound	Broken hydraulic hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 3, 2017	Coolant	80	L	Vault parking	Broken coolant hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 6, 2017	Coolant	40	L	Vault pit	Broken coolant hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 6, 2017	Coolant	25	L	Pushback parking	Broken coolant hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 7, 2017	Hydraulic oil	10	L	Vault pit	Broken hydraulic pan	Spill was contained and contaminated soil picked up and disposed of	No

Type A Water License 2AM-MEA1525
Monitoring Program Summary Report

						appropriately	
July 8, 2017	Diesel	30	L	Maintenance Shop	Fuel leak	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 9, 2017	Hydraulic Oil	20	L	Portage Rock Storage Facility	Broken hydraulic hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 10, 2017	Coolant	20	L	Vault pit	Broken coolant hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 13, 2017	Coolant	50	L	Vault pit	Broken coolant hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 14, 2017	Hydraulic oil	40	L	Vault pit	Broken hydraulic hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 14, 2017	Hydraulic oil	5	L	Vault camp	Loose fitting	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 15, 2017	Coolant	30	L	Vault road	Broken coolant hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 16, 2017	Coolant	30	L	Vault pit	The water pump blew	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 19, 2017	Hydraulic oil	40	L	Portage pit	Broken hydraulic hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No

Type A Water License 2AM-MEA1525
Monitoring Program Summary Report

July 19, 2017	Hydraulic oil	40	L	Portage pit	Broken hydraulic hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 22, 2017	Coolant	20	L	Portage pit	Broken hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 22, 2017	Coolant	30	L	Saddle dam access road	Broken coolant hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 22, 2017	Coolant	50	L	Vault pit	Broken coolant hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 23, 2017	Hydraulic oil	80	L	Vault pit	Broken hydraulic hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 25, 2017	Hydraulic oil	10	L	Saddle Dam 4	Broken hydraulic hose	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 26, 2017	Hydraulic oil	50	L	Vault pit	Broken O'ring	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 27, 2017	Transmission Fluid	30	L	Vault pit	Broken transmission line	Spill was contained and contaminated soil picked up and disposed of appropriately	No
July 28, 2017	Fuel	200	L	Vault Camp	An instrumentation technician was there to pass and terminate a cable that was running by the fuel tank. When he got there, he noticed the	Spill was contained and contaminated soil picked up and disposed of appropriately	Yes

Type A Water License 2AM-MEA1525
Monitoring Program Summary Report

					spill.		
July 29, 2017	Coolant	120	L	Vault pit	High pressure caused leak	Spill was contained and contaminated soil picked up and disposed of appropriately	Yes
July 29, 2017	Coolant	5	L	Vault Rock Storage Facility	Engine over heated and coolant came out of the overflow	Spill was contained and contaminated soil picked up and disposed of appropriately	No