

PQCC40 AOAC 67775601060

Kivalliq Inuit Association

∩∩%b%b%b%b/P.O. Box 340, b%∩%bぐσ%/Rankin Inlet, ஹ௳≫</Nunavut XOC 0G0 ▷%b∴C/Tel: (867) 645-2800 ~bb√bdc/Fax: (867) 645-2348/◁Р%™∩℃♂bdc/Toll free: 1-800-220-6581

August 11, 2020

Richard Dwyer Manager of Licensing Nunavut Water Board P.O. Box 119 Gjoa Haven, NU XOB 1JO

Sent via email: richard.dwyer@nwb-oen.ca

Dear Richard

RE: Design Report for the Sewage Treatment Plant Upgrade for Water License 2AM-MEL1631

The Design Report for the Sewage Treatment Plant Upgrade for Water License 2AM-MEL1631 has been reviewed by the Kivalliq Inuit Association (KivIA).

The KivIA would like a clarification with regard to the design flow of the sewage treatment plant. In Appendix D of the Operation and Maintenance manual two different numbers are stated as the design flow. In Table 2 on page 9 it is stated as 216 cubic metres / hour and in Table 4 on page 10 it is stated as 206 cubic metres / hour.

Other than the above clarification the KivIA has no concerns with this submission.

Regards

Luis Manzo, P.Ag Director of Lands

Kivalliq Inuit Association