


LEGEND:

- PRIMARY FLOW
- SECONDARY FLOW
- INTERMITTENT OR ALTERNATE FLOW
- MATERIAL FLOW
- VENDOR PACKAGE LIMIT

- NOTES:**
1. TANK LOCATED ADJACENT TO SEWAGE TREATMENT PLANT TANKS SHALL BE INSULATED AND HEATED
 2. AT MINIMUM TREATED EFFLUENT SHALL MEET NUNAVUT WATER BOARD LICENCE FOR DISCHARGE CRITERIA. ADDITIONALLY IT WILL MEET HEALTH CANADA GUIDE LINE FOR DOMESTIC RECLAIMED WATER FOR USE IN TOILET AND URINAL FLUSH (JAN 2010, CAT. H128-1/10-602E)
 3. SEWAGE SHALL BE TRUCKED FROM REMOTE FACILITY. TRUCK WILL DRAW TANK AT REMOTE FACILITY AND DELIVER TO EQUALIZATION TANK.
 4. ALL EXPOSED PIPING AND EQUIPMENT SHALL BE INSULATED AND HEATED



DRAWING NO. H337697-4330-05-030-0001		DRAWING TITLE		REFERENCE DRAWINGS		REVISIONS		ISSUE AUTHORIZATION		DESIGNED BY R.KAPADIA DATE 2011-08-03 CHECKED BY R.KAPADIA DATE 2011-08-24 PROJ. DES. COORD. H. CHARALAMBU		DRAWN BY J.FESAR DATE 2011-08-02 DISCIP. ENGR. A.ZLATIC DATE PROJ. ENGR. J. CASSON DATE		PROCESS FLOW DIAGRAM MARY RIVER (MINE SITE) SEWAGE TREATMENT PLANT EXTERNAL MBR BASED SYSTEM		SCALE DWG. NO. H337697-4330-05-030-0001		REV. B	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20