

March 2, 2019

Manager of Licensing Nunavut Water Board P.O. Box 119 Gjoa Haven, NU X0B 1J0 Water Resources Officer CIRNAC P.O. Box 100 Igaluit, NU X0A 0H0

RE: Water Licence 2AM-MRY1325 Monthly SNP Report – January 2019

The following is the monthly report for January 2019 as required under Part I, Item 21 of the Type 'A' Water Licence 2AM-MRY1325 (the Licence). Part I, Item 21 of the above referenced Water Licence states:

"The Licensee shall submit to the Board, within thirty (30) days following the month being reported, a Monthly Monitoring Report. The Report shall include:

- a. All data and information required by this Part and generated by the Monitoring Program in the tables of Schedule I;
- b. An assessment of data to identify areas of non-compliance with regulated discharge parameters referred to in Part F"

Monitoring Program

During the month of January 2019, water samples were collected as part of the Water Licence Monitoring Program.

Table 1 presents a list of samples/monitoring required under the Licence and the details concerning which water quality samples were collected along with sample date/laboratory identification number as appropriate. Analytical water quality testing results received are presented in Table 2. Volumes consumed for domestic and industrial water purposes and the volumes of effluent discharged at the Mary River Mine Site and Milne Port are presented in the attached Table 3.

Monitoring Program Results

A) Water Sampling and Analysis Results

Table 2 provides the analytical results related to the Monitoring Program sampling requirements for January 2019. There were no exceedences of the applicable criteria during the sampling period.

B) Flow and Volume Measurements

Table 3 provides a breakdown of volume measurements as required by Part I, Item 9 of the Licence for January 2019.

We trust that the information provided in this monthly report is acceptable and should you have any questions regarding this report please contact myself, Connor Devereaux (ext. 6016), or Timothy Ray Sewell at 416.364.8820 ext. 6054.

Regards,

Reviewed by:

William Bowden

Environmental Superintendent

Bill Barder

Christopher Murray

Environmental & Regulatory Compliance Manager

Attach: Tables 1, 2, and 3

Cc: Jeremy Fraser, Justin Hack (CIRNAC); Grant Goddard, Megan Lord-Hoyle, Timothy Ray Sewell, Sylvain Proulx, Gerald Rogers, Francois Gaudrau, Connor Devereaux (Baffinland); Fai Ndofor, Sean Joseph (QIA)

Table 1: Monitoring Program Water Sampling Summary for January 2019

Monitoring Program Station	Sampling Date	Lab ID#	Comment		
Milne Port					
MP-01 (Sewage Treatment Facility)	01/16/2019	L2222169-1	Volume reported daily during discharge		
MP-0101 (Field Duplicate of Sewage Treatment Facility)	01/16/2019	L2222169-4	Volume reported daily during discharge		
MP-01a (Polishing Waste Stabilization Pond)	N/A	N/A	No flow.		
MP-MRY-3 (Freshwater Intake from Km 32 Lake - Winter)	N/A	N/A	No flow.		
MP-MRY-04 (RBC at Exploration Camp)	N/A	N/A	No flow.		
MP-03 (Bulk Fuel Storage Facility Stormwater)	N/A	N/A	No flow.		
MP-04 (Landfarm Facility & Snow Containment Facility)	N/A	N/A	No flow.		
MP-05 (Ore Stockpile Sedimentation Pond (East))	N/A	N/A	No flow.		
MP-06 (Ore Stockpile Sedimentation Pond (West)	N/A	N/A	No flow.		
MP-MRY-12 (Bulk Sample Stockpile Area Seepage)	N/A	N/A	No flow.		
MP-C-A (Downstream of Construction Area)	N/A	N/A	No flow.		
MP-C-B (Downstream of Construction Area)	N/A	N/A	No flow.		
MP-C-B01 (Downstream of Construction Area)	N/A	N/A	No flow.		
MP-C-D (Downstream of Construction Area)	N/A	N/A	No flow, location is being retired due to lack of flow.		
MP-C-E (Downstream of Construction Area)	N/A	N/A	No flow, location is being retired due to lack of flow.		
MP-C-F (Downstream of Construction Area)	N/A	N/A	No flow.		
MP-C-H (Downstream of Construction Area)	N/A	N/A	No flow.		
MP-Q1-01 (Downstream of Q1 Quarry)	N/A	N/A	No flow.		

Monitoring Program Station	Sampling Date	Lab ID#	Comment
MP-Q1-02 (Downstream of Q1 Quarry)	N/A	N/A	No flow.
Mary River Mine Site			
MS-01 (Sewage Treatment Facility)	01/16/2019	L2222163-1	Discharge volume reported daily
MS-0101 (Field Duplicate of Sewage Treatment Facility)	01/16/2019	L2222163-3	Discharge volume reported daily
MS-01b (Sewage Treatment Facility)	01/16/2019	L2222158-1	Discharge volume reported daily
MS-MRY-1 (Freshwater Intake Camp Lake)	N/A	N/A	No flow.
MS-MRY-04a	N/A	N/A	No flow.
MS-MRY-04b	N/A	N/A	No flow.
MS-MRY-04c	N/A	N/A	No flow.
MS-MRY-04c MS-03 (Milne Site Bulk Fuel Storage	N/A	N/A N/A	No flow.
Facility Stormwater) MS-06	, .	, .	1.0
(Ore Stockpile Pond Stormwater)	N/A	N/A	No flow.
MS-08 (Mine Waste Rock Stockpile pond)	N/A	N/A	No flow.
MS-MRY-6 (Exploration Camp Bladder Farm Stormwater)	N/A	N/A	No flow.
MS-MRY-09 (Bulk Sample Pit)	N/A	N/A	No flow.
MS-MRY-10 (Weathered Ore Bulk Sample Stockpile)	N/A	N/A	No flow.
MS-MRY-11 (Processing Bulk Sample Stockpile)	N/A	N/A	Area is being retired due to lack of flows
MS-MRY-13A (Downstream Non-Hazardous Landfill)	N/A	N/A	No flow.
MS-MRY-13B (Downstream Non-Hazardous Landfill)	N/A	N/A	No flow.
MS-C-A (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-B (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-C (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-D (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.

Monitoring Program Station	Sampling Date	Lab ID#	Comment
MS-C-E (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-F (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-G (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-H (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MQ-C-A (Downstream of QMR2 Quarry)	N/A	N/A	No flow.
MQ-C-B (Downstream of QMR2 Quarry)	N/A	N/A	No flow.
MQ-C-D (Downstream of QMR2 Quarry)	N/A	N/A	No flow.
Steensby Port			
Steensby Exploration Camp is presently not active.	N/A	N/A	

TABLE 2.1 - WATER QUALITY RESULTS FOR WATER LICENCE MONITORING LOCATION - MP-01

		Sam	ple ID	MP-01	MP-0101 L2222169-4	
		ALS Laborat	tory Sample ID	L2222169-1		
Analyte		Sample D	Date & Time	2019-01-16 13:45	2019-01-16 13:45	
		QA/QC S	ample Type	N/A	Field Duplicate	
	Units	LOR	Water Licence Criteria ¹			
рН	pH units	0.1	6.0 - 9.5	7.25	7.23	
Total Suspended Solids	mg/L	/L 2 <120		2.7	3	
Alkalinity, Total (as CaCO3)	mg/L	10	-	68	65	
Ammonia, Total (as N)	mg/L	0.02	-	0.143	0.161	
Total Kjeldahl Nitrogen	mg/L	0.15	-	1.9	1.6	
Phosphorus, Total	mg/L	g/L 0.003 -		7.76	7.75	
Fecal Coliforms	CFU/100mL	U/100mL 0 10,000		0	2	
BOD	mg/L	2	100	<2.0	2.1	
COD	mg/L	mg/L 10 -		38	36	
Oil and Grease, Total	mg/L	2			<2.0	

Grey and bold highlight indicate results that exceeded the applicable water quality criteria.

¹Type A Water Licence (2AM-MRY1325 - Amend. 1) - Table 5: Effluent Quality Discharge Limits for Sewage Treatment Facilities to the Ocean

TABLE 2.2 - WATER QUALITY RESULTS FOR WATER LICENCE MONITORING LOCATION - MS-01

		Sam	ple ID	MS-01	MS-0101 L2222163-3 2019-01-16 15:00	
	A	ALS Laborat	ory Sample ID	L2222163-1		
Analyte		Sample D	ate & Time	2019-01-16 15:00		
		QA/QC Sample Type Units LOR Water Licence Criteria ¹		N/A	Field Duplicate	
	Units					
рН	pH units	0.1	6.0 - 9.5	7.43	7.43	
Total Suspended Solids	mg/L	2 35		10.8	10.7	
Alkalinity, Total (as CaCO3)	mg/L	10	-	75	81	
Ammonia, Total (as N)	mg/L	0.02	4	0.179	0.221	
Total Kjeldahl Nitrogen	mg/L	0.15 -		1	1.22	
Phosphorus, Total	mg/L	0.003 4		0.667	0.727	
Fecal Coliforms	CFU/100mL	OmL 0 1,000		37	110	
BOD	mg/L	2 30		3.7	2.4	
COD	mg/L	10 -		39	41	
Oil and Grease, Total	mg/L	2	No Visible Sheen	<2.0	<2.0	

Grey and bold highlight indicate results that exceeded the applicable water quality criteria.

¹Type A Water Licence (2AM-MRY1325 - Amend. 1) - Table 4: Effluent Quality Discharge Limits for Sewage Treatment Facilities to Freshwater Receiving Environment

TABLE 2.3 - WATER QUALITY RESULTS FOR WATER LICENCE MONITORING LOCATION - MS-01B

		Sam	MS-01B L2222158-1 2019-01-16 14:45		
		ALS Laborat			
Analyte		Sample D			
		QA/QC Sa	N/A		
	Units	LOR	Water Licence Criteria ¹		
рН	pH units	0.1	6.0 - 9.5	7.60	
Total Suspended Solids	mg/L	2	35	<2.0	
Alkalinity, Total (as CaCO3)	mg/L	10	-	78	
Ammonia, Total (as N)	mg/L	0.02	4	0.503	
Total Kjeldahl Nitrogen	mg/L	0.15	-	1.09	
Phosphorus, Total	mg/L	0.003	4	0.918	
Fecal Coliforms	CFU/100mL	0	1,000	87	
BOD	mg/L 2		30	<2.0	
COD	mg/L	10	-	17	
Oil and Grease, Total	mg/L	2	No Visible Sheen	<2.0	

Grey and bold highlight indicate results that exceeded the applicable water quality criteria.

¹Type A Water Licence (2AM-MRY1325 - Amend. 1) - Table 4: Effluent Quality Discharge Limits for Sewage Treatment Facilities to Freshwater Receiving Environment

Table 3: Flow and Volume Measurements-Part I Item 11 - January 2019

DATE	Camp Lake Freshwater for Demestic Use - Daily Water (m³) MS-MRY-1	Camp Lake Freshwater for Industrial Use - Daily Water (m³) MS-MRY-1	Treated Sewage Effluent (m³) from MS-01 to Discharge Location #1	Treated Sewage Effluent (m³) from MS-01b to Discharge Location #1	Sewage Sludge Removed (m³) from Mine Site WWTPs to Incinerator	Sewage Sludge Removed (m³) from Mine Site WWTP to PWSP at Mine Site - MS-MRY-4a	Sewage Sludge Removed (m³) from MS-01b to PWSP at Mine Site MS-MRY-4b	Km 32 Lake Milne Port Camp Daily Water (m³) MP-MRY-3	Treated Sewage Effluent (m³) from MP-01 to Milne Port	Sewage Sludge Removed (m³) from Milne Port WWTP to Incinerator	Sewage Sludge Removed (m³) from Lift Stations to PWSP at Milne Port - MP-01a	Sewage Sludge Removed (m³) from Milne Port WWTP to PWSP at Milne Port - MP-01a
1-Jan-19	106.2	0.0	57.5	48.7	0.7	0.0	0.0	40.8	51.0	0.3	0.0	0.0
2-Jan-19	127.6	0.0	71.0	56.6	0.9	0.0	0.0	37.9	51.0	0.0	0.0	0.0
3-Jan-19	110.0	0.0	64.3	45.7	1.0	0.0	0.0	40.1	49.0	0.0	0.0	0.0
4-Jan-19	141.4	0.0	99.2	42.2	1.0	0.0	0.0	34.6	43.0	0.3	0.0	0.0
5-Jan-19	115.6	0.0	64.1	51.5	0.7	0.0	0.0	44.4	46.0	0.3	0.0	0.0
6-Jan-19	111.2	0.0	58.1	53.1	0.5	0.0	0.0	32.2	47.0	0.3	0.0	0.0
7-Jan-19	124.5	0.0	68.5	56.0	0.1	0.0	0.0	36.2	47.0	0.5	0.0	0.0
8-Jan-19	111.0	0.0	80.3	30.7	0.1	0.0	0.0	44.2	44.0	0.3	0.0	4.0
9-Jan-19	84.6	0.0	68.1	16.5	0.1	0.0	0.0	52.0	48.0	0.0	0.0	4.0
10-Jan-19	68.5	0.0	68.5	0.0	0.1	20.1	0.0	44.0	47.0	0.0	0.0	0.0
11-Jan-19	118.9	0.0	72.1	46.8	0.0	0.0	0.0	38.8	42.0	0.7	0.0	0.0
12-Jan-19	117.4	0.0	53.9	63.5	0.2	0.0	0.0	31.9	40.0	0.7	0.0	0.0
13-Jan-19	164.4	0.0	75.9	88.5	0.1	3.0	0.0	38.8	42.0	0.7	0.0	0.0
14-Jan-19	118.9	0.0	43.9	75.0	0.7	0.0	3.0	41.2	43.0	0.7	0.0	0.0
15-Jan-19	135.0	0.0	71.0	64.0	0.4	2.0	3.0	51.0	49.0	0.7	0.0	0.0
16-Jan-19	167.0	0.0	94.7	72.3	0.6	0.0	3.0	42.9	48.0	0.3	0.0	0.0
17-Jan-19	124.0	0.0	47.2	76.8	0.6	0.0	0.0	48.1	49.0	0.7	0.0	0.0
18-Jan-19	182.4	0.0	105.6	76.8	0.5	0.0	0.0	54.5	51.0	0.7	0.0	0.0
19-Jan-19	158.1	0.0	97.3	60.8	0.6	0.0	0.0	35.5	63.0	0.3	0.0	0.0
20-Jan-19	110.8	0.0	54.2	56.6	0.5	0.0	0.0	46.8	49.0	0.3	0.0	0.0
21-Jan-19	121.6	16.7	65.4	56.2	0.5	0.0	0.0	43.2	49.0	0.0	0.0	0.0
22-Jan-19	127.1	0.0	67.3	59.8	0.6	0.0	0.0	38.6	44.0	0.0	0.0	0.0
23-Jan-19	104.9	0.0	42.8	62.1	0.7	0.0	0.0	56.9	39.0	0.3	0.0	5.6
24-Jan-19	127.6	0.0	61.9	65.7	0.7	0.0	0.0	39.3	50.0	0.3	0.0	0.0
25-Jan-19	166.0	0.0	103.5	62.5	0.6	0.0	0.0	46.8	48.0	0.0	4.6	0.0
26-Jan-19	128.4	0.0	70.8	57.6	0.6	0.0	0.0	44.4	35.0	0.3	0.0	8.0
27-Jan-19	117.5	0.0	41.9	75.6	0.6	0.0	0.0	38.1	47.0	0.3	0.0	0.0
28-Jan-19	139.7	0.0	80.5	59.2	0.6	0.0	0.0	53.0	50.0	0.7	0.0	4.3
29-Jan-19	105.6	0.0	48.2	57.4	0.7	0.0	0.0	34.2	49.0	0.7	0.0	0.0
30-Jan-19	134.8	0.0	74.0	60.8	0.7	0.0	0.0	54.9	52.0	0.3	0.0	0.0
31-Jan-19	121.1	0.0	42.1	79.0	0.9	0.0	0.0	37.0	46.0	0.0	0.0	0.0
Total	3770.8	16.7	2071.8	1699.0	16.0	25.1	9.0	1285.6	1412.0	11.1	4.6	25.9

WWTP - Waste Water Treatment Plant
PWSP - Polishing Waste Stabilization Pond