



March 30, 2019

Manager of Licensing  
Nunavut Water Board  
P.O. Box 119  
Gjoa Haven, NU X0B 1J0

Water Resources Officer  
CIRNAC  
P.O. Box 100  
Iqaluit, NU X0A 0H0

**RE: Water Licence 2AM-MRY1325 Monthly SNP Report – February 2019**

---

The following is the monthly report for February 2019 as required under Part I, Item 21 of the Type 'A' Water Licence 2AM-MRY1325 (the Licence). Part I, Item 21 of the above referenced Water Licence states:

*"The Licensee shall submit to the Board, within thirty (30) days following the month being reported, a Monthly Monitoring Report. The Report shall include:*

- a. All data and information required by this Part and generated by the Monitoring Program in the tables of Schedule I;*
- b. An assessment of data to identify areas of non-compliance with regulated discharge parameters referred to in Part F"*

**Monitoring Program**

During the month of February 2019, water samples were collected as part of the Water Licence Monitoring Program.

Table 1 presents a list of samples/monitoring required under the Licence and the details concerning which water quality samples were collected along with sample date/laboratory identification number as appropriate. Analytical water quality testing results received are presented in Table 2. Volumes consumed for domestic and industrial water purposes and the volumes of effluent discharged at the Mary River Mine Site and Milne Port are presented in the attached Table 3.

**Monitoring Program Results**

**A) Water Sampling and Analysis Results**

Table 2 provides the analytical results related to the Monitoring Program sampling requirements for February 2019. There were no exceedences of the applicable criteria during the sampling period.

**B) Flow and Volume Measurements**

Table 3 provides a breakdown of volume measurements as required by Part I, Item 9 of the Licence for February 2019.

We trust that the information provided in this monthly report is acceptable and should you have any questions regarding this report please contact myself, Connor Devereaux (ext. 6016), or Timothy Ray Sewell at 416.364.8820 ext. 6054.

Regards,

A handwritten signature in black ink, appearing to read "Bill Bowden".

William Bowden  
Environmental Superintendent

Reviewed by:

A handwritten signature in black ink, appearing to read "Chris Murray".

Christopher Murray  
Environmental & Regulatory Compliance Manager

Attach: Tables 1, 2, and 3

Cc: Jeremy Fraser, Justin Hack (CIRNAC); Grant Goddard, Megan Lord-Hoyle, Timothy Ray Sewell, Sylvain Proulx, Gerald Rogers, Francois Gaudrau, Connor Devereaux (Baffinland); Jared Ottenhof (QIA)

**Table 1: Monitoring Program Water Sampling Summary for February 2019**

<b>Monitoring Program Station</b>	<b>Sampling Date</b>	<b>Lab ID#</b>	<b>Comment</b>
<b>Milne Port</b>			
MP-01 (Sewage Treatment Facility)	02/19/2019	L2235207-1	Volume reported daily during discharge
MP-01a (Polishing Waste Stabilization Pond)	N/A	N/A	No flow.
MP-MRY-3 (Freshwater Intake from Km 32 Lake - Winter)	N/A	N/A	No flow.
MP-MRY-04 (RBC at Exploration Camp)	N/A	N/A	No flow.
MP-03 (Bulk Fuel Storage Facility Stormwater)	N/A	N/A	No flow.
MP-04 (Landfarm Facility & Snow Containment Facility)	N/A	N/A	No flow.
MP-05 (Ore Stockpile Sedimentation Pond (East))	N/A	N/A	No flow.
MP-06 (Ore Stockpile Sedimentation Pond (West))	N/A	N/A	No flow.
MP-MRY-12 (Bulk Sample Stockpile Area Seepage)	N/A	N/A	No flow.
MP-C-A (Downstream of Construction Area)	N/A	N/A	No flow.
MP-C-B (Downstream of Construction Area)	N/A	N/A	No flow.
MP-C-B01 (Downstream of Construction Area)	N/A	N/A	No flow.
MP-C-D (Downstream of Construction Area)	N/A	N/A	No flow.
MP-C-E (Downstream of Construction Area)	N/A	N/A	No flow.
MP-C-F (Downstream of Construction Area)	N/A	N/A	No flow.
MP-C-H (Downstream of Construction Area)	N/A	N/A	No flow.
MP-Q1-01 (Downstream of Q1 Quarry)	N/A	N/A	No flow.
MP-Q1-02 (Downstream of Q1 Quarry)	N/A	N/A	No flow.
<b>Mary River Mine Site</b>			

<b>Monitoring Program Station</b>	<b>Sampling Date</b>	<b>Lab ID#</b>	<b>Comment</b>
MS-01 (Sewage Treatment Facility)	02/19/2019	L2235199-1	Discharge volume reported daily
MS-01b (Sewage Treatment Facility)	02/19/2019	L2235218-1	Discharge volume reported daily
MS-MRY-1 (Freshwater Intake Camp Lake)	N/A	N/A	No flow.
MS-MRY-04a	N/A	N/A	No flow.
MS-MRY-04b	N/A	N/A	No flow.
MS-MRY-04c	N/A	N/A	No flow.
MS-03 (Milne Site Bulk Fuel Storage Facility Stormwater)	N/A	N/A	No flow.
MS-06 (Ore Stockpile Pond Stormwater)	N/A	N/A	No flow.
MS-08 (Mine Waste Rock Stockpile pond)	N/A	N/A	No flow.
MS-MRY-6 (Exploration Camp Bladder Farm Stormwater)	N/A	N/A	No flow.
MS-MRY-09 (Bulk Sample Pit)	N/A	N/A	No flow.
MS-MRY-10 (Weathered Ore Bulk Sample Stockpile)	N/A	N/A	No flow.
MS-MRY-11 (Processing Bulk Sample Stockpile)	N/A	N/A	No flow.
MS-MRY-13A (Downstream Non-Hazardous Landfill)	N/A	N/A	No flow.
MS-MRY-13B (Downstream Non-Hazardous Landfill)	N/A	N/A	No flow.
MS-C-A (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-B (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-C (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-D (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-E (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-F (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.

<b>Monitoring Program Station</b>	<b>Sampling Date</b>	<b>Lab ID#</b>	<b>Comment</b>
MS-C-G (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MS-C-H (Downstream of Construction and Borrow Areas)	N/A	N/A	No flow.
MQ-C-A (Downstream of QMR2 Quarry)	N/A	N/A	No flow.
MQ-C-B (Downstream of QMR2 Quarry)	N/A	N/A	No flow.
MQ-C-D (Downstream of QMR2 Quarry)	N/A	N/A	No flow.
<b>Steensby Port</b>			
Steensby Exploration Camp is presently not active.	N/A	N/A	

**TABLE 2.1 - WATER QUALITY RESULTS FOR WATER LICENCE MONITORING LOCATION - MP-01**

Analyte	Sample ID			MP-01
	ALS Laboratory Sample ID			L2235207-1
	Sample Date & Time			2019-02-19 13:45
	QA/QC Sample Type			N/A
	Units	LOR	Water Licence Criteria <sup>1</sup>	
pH	pH units	0.1	6.0 - 9.5	7.98
Total Suspended Solids	mg/L	2	<120	12.2
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	10	-	248
Ammonia, Total (as N)	mg/L	0.02	-	0.063
Total Kjeldahl Nitrogen	mg/L	0.15	-	1.79
Phosphorus, Total	mg/L	0.003	-	10.7
Fecal Coliforms	CFU/100mL	0	10,000	2
BOD	mg/L	2	100	2.4
COD	mg/L	10	-	51
Oil and Grease, Total	mg/L	2	No Visible Sheen	<2.0

**Notes:**

Grey and bold highlight indicate results that exceeded the applicable water quality criteria.

<sup>1</sup>Type A Water Licence (2AM-MRY1325 - Amend. 1) - Table 5: Effluent Quality Discharge Limits for Sewage Treatment Facilities to the Ocean

**TABLE 2.2 - WATER QUALITY RESULTS FOR WATER LICENCE MONITORING LOCATION - MS-01**

Analyte	Sample ID			MS-01
	ALS Laboratory Sample ID			L2235199-1
	Sample Date & Time			2019-02-19 15:00
	QA/QC Sample Type			N/A
	Units	LOR	Water Licence Criteria <sup>1</sup>	
pH	pH units	0.1	6.0 - 9.5	7.39
Total Suspended Solids	mg/L	2	35	7.2
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	10	-	68
Ammonia, Total (as N)	mg/L	0.02	4	0.092
Total Kjeldahl Nitrogen	mg/L	0.15	-	0.45
Phosphorus, Total	mg/L	0.003	4	1.360
Fecal Coliforms	CFU/100mL	0	1,000	18
BOD	mg/L	2	30	3.8
COD	mg/L	10	-	46
Oil and Grease, Total	mg/L	2	No Visible Sheen	<2.0

**Notes:**

Grey and bold highlight indicate results that exceeded the applicable water quality criteria.

<sup>1</sup>Type A Water Licence (2AM-MRY1325 - Amend. 1) - Table 4: Effluent Quality Discharge Limits for Sewage Treatment Facilities to Freshwater Receiving Environment

TABLE 2.3 - WATER QUALITY RESULTS FOR WATER LICENCE MONITORING LOCATION - MS-01B

Analyte	Sample ID			MS-01B
	ALS Laboratory Sample ID			L2235218-1
	Sample Date & Time			2019-02-19 14:45
	QA/QC Sample Type			N/A
	Units	LOR	Water Licence Criteria <sup>1</sup>	
pH	pH units	0.1	6.0 - 9.5	7.56
Total Suspended Solids	mg/L	2	35	8.3
Alkalinity, Total (as CaCO <sub>3</sub> )	mg/L	10	-	55
Ammonia, Total (as N)	mg/L	0.02	4	0.101
Total Kjeldahl Nitrogen	mg/L	0.15	-	0.77
Phosphorus, Total	mg/L	0.003	4	1.060
Fecal Coliforms	CFU/100mL	0	1,000	24
BOD	mg/L	2	30	2
COD	mg/L	10	-	25
Oil and Grease, Total	mg/L	2	No Visible Sheen	<2.0

**Notes:**

Grey and bold highlight indicate results that exceeded the applicable water quality criteria.

<sup>1</sup>Type A Water Licence (2AM-MRY1325 - Amend. 1) - Table 4: Effluent Quality Discharge Limits for Sewage Treatment Facilities to Freshwater Receiving Environment

Table 3: Flow and Volume Measurements-Part I Item 11 - February 2019

DATE	Camp Lake Freshwater for Domestic Use - Daily Water (m <sup>3</sup> ) MS-MRY-1	Camp Lake Freshwater for Industrial Use - Daily Water (m <sup>3</sup> ) MS-MRY-1	Treated Sewage Effluent (m <sup>3</sup> ) from MS-01 to Discharge Location #1	Treated Sewage Effluent (m <sup>3</sup> ) from MS-01b to Discharge Location #1	Sewage Sludge Removed (m <sup>3</sup> ) from Mine Site WWTPs to Incinerator	Sewage Sludge Removed (m <sup>3</sup> ) from Mine Site WWTP to PWSP at Mine Site - MS-MRY-4a	Sewage Sludge Removed (m <sup>3</sup> ) from Mine Site WWTP to PWSP at Mine Site - MS-MRY-4b	Km 32 Lake Milne Port Camp Fresh Water for Domestic Use - Daily Water (m <sup>3</sup> ) MP-MRY-3	Treated Sewage Effluent (m <sup>3</sup> ) from MP-01 to Milne Port	Sewage Sludge Removed (m <sup>3</sup> ) from Milne Port WWTP to Incinerator	Sewage Sludge Removed (m <sup>3</sup> ) from Lift Stations to PWSP at Milne Port - MP-01a
1-Feb-19	152.1	0.0	85.3	66.8	0.9	0.0	0.0	53.1	50.0	0.3	0.0
2-Feb-19	107.2	0.0	54.6	52.6	1.0	0.0	0.0	41.4	54.0	0.7	0.0
3-Feb-19	112.3	0.0	64.7	47.6	0.7	0.0	0.0	46.4	40.0	0.7	0.0
4-Feb-19	112.8	0.0	62.5	50.3	0.9	0.0	0.0	37.9	48.0	0.3	0.0
5-Feb-19	144.6	0.0	95.7	48.9	0.9	0.0	0.0	20.6	51.0	0.3	0.0
6-Feb-19	137.2	0.0	68.3	68.9	1.0	0.0	0.0	66.7	61.0	0.3	0.0
7-Feb-19	122.9	0.0	45.9	77.0	1.0	0.0	0.0	38.2	59.0	0.5	0.0
8-Feb-19	97.9	0.0	52.4	45.5	1.1	0.0	0.0	50.9	55.0	0.7	0.0
9-Feb-19	124.5	0.0	68.1	56.4	1.2	0.0	0.0	40.9	57.0	0.0	0.0
10-Feb-19	100.8	0.0	58.4	42.4	0.5	4.0	0.0	43.6	44.0	0.0	0.0
11-Feb-19	136.1	0.0	94.6	41.5	0.0	0.0	0.0	43.7	45.0	0.7	0.0
12-Feb-19	76.0	0.0	76.0	0.0	0.0	0.0	0.0	40.8	44.0	0.5	0.0
13-Feb-19	45.0	0.0	45.0	0.0	0.0	0.0	0.0	52.3	58.0	0.5	0.0
14-Feb-19	162.5	0.0	114.7	47.8	0.0	0.0	0.0	45.9	61.0	0.7	0.0
15-Feb-19	55.8	8.3	55.8	0.0	0.3	0.0	33.2	43.3	61.0	0.6	0.0
16-Feb-19	72.5	0.0	32.6	39.9	0.5	0.0	8.3	46.8	61.0	0.6	0.0
17-Feb-19	166.9	16.7	109.3	57.6	0.0	0.0	0.0	34.6	46.0	0.7	0.0
18-Feb-19	133.5	10.6	71.3	62.2	0.9	0.0	0.0	44.6	46.0	0.7	0.0
19-Feb-19	149.3	0.0	85.5	63.8	0.5	0.0	0.0	45.3	61.0	0.3	0.0
20-Feb-19	166.8	0.0	91.3	75.5	0.8	0.0	0.0	41.0	54.0	0.3	0.0
21-Feb-19	140.1	0.0	74.2	65.9	0.8	0.0	0.0	52.5	52.0	0.3	0.0
22-Feb-19	129.7	10.6	63.7	66.0	1.0	0.0	0.0	40.4	49.0	0.3	0.0
23-Feb-19	168.5	0.0	108.5	60.0	0.8	0.0	0.0	56.4	63.0	0.7	0.0
24-Feb-19	133.2	0.0	73.1	60.1	0.8	0.0	0.0	49.1	57.0	0.7	9.5
25-Feb-19	152.0	0.0	89.1	62.9	0.8	0.0	0.0	51.2	46.0	0.3	0.0
26-Feb-19	134.0	8.3	68.7	65.3	0.8	0.0	0.0	48.3	60.0	0.7	0.0
27-Feb-19	154.6	0.0	74.8	79.8	0.5	0.0	0.0	42.1	62.0	0.3	0.0
28-Feb-19	148.3	0.0	76.0	72.3	0.3	0.0	0.0	57.4	60.0	0.3	0.0
<b>Total</b>	<b>3537.1</b>	<b>54.5</b>	<b>2060.1</b>	<b>1477.0</b>	<b>17.9</b>	<b>4.0</b>	<b>41.5</b>	<b>1275.3</b>	<b>1505.0</b>	<b>13.3</b>	<b>9.5</b>

Notes:

WWTP - Waste Water Treatment Plant

PWSP - Polishing Waste Stabilization Pond