

March 30, 2026

Manager of Licensing  
Nunavut Water Board  
P.O. Box 119  
Gjoa Haven, Nunavut X0B 1J0

Resource Management Officer, CIRNAC  
Nunavut District, Nunavut Region  
P.O. Box 100  
Iqaluit, NU X0A 0H0

**RE: Water Licence 2AM-MRY2540 Monthly Surveillance Network Program (SNP) Report  
February 2026**

The following is the monthly report for February 2026 as required under Part I, Item 19 of the Type 'A' Water Licence 2AM-MRY2540 (the Licence), which states:

*"The Licensee shall submit to the Board, within thirty (30) days following the month being reported, a Monthly Monitoring Report. The Report shall include:*

- a) All data and information required by this Part and generated by the Monitoring Program in the tables of Schedule I*
- b) An assessment of data to identify areas of non-compliance with regulated discharge parameters referred to in Part F"*

**Monitoring Program**

Table 1 presents a list of samples/monitoring conducted in February under the Licence at sites with discharge/flowing water conditions and the details concerning the collected water quality samples, including sample dates and laboratory identification numbers. Analytical water quality testing results are presented in Table 2. Table 3.1 presents water volumes consumed for domestic and industrial water purposes as well as select volumes of effluent and waste discharged and/or disposed at the Mary River Mine Site and Milne Port during February 2026.

**Monitoring Program Results**

*Water Sampling and Analysis Results*

Table 2 provides the analytical results related to the Sewage Treatment Plant (STP) facilities. There were no exceedances of applicable water quality criteria observed at STP monitoring stations in February 2026. Due to frozen winter conditions, no other water samples were collected during the month of February.

It should be noted that the Wastewater Treatment Plant associated with Monitoring Station MP-01B (the 380-person camp) experienced a thermal event on February 11 that necessitated a complete shutdown of the facility. Until repairs are completed and the plant can be returned to service, wastewater is being redirected for treatment at the PSC Wastewater Treatment Plant (Monitoring Station MP-01) and may also be transported to the PWSP for treatment as required.

### *Flow and Volume Measurements*

Table 3.1 provides a breakdown of volume measurements for February 2026, as required by Part I, Item 6 of the Licence. There were no exceedances of the source-specific daily volume withdrawal limits in February 2026.


We trust that the information provided in this monthly report is acceptable. If you have any questions regarding this report, please contact the undersigned.

Prepared by:

A handwritten signature in black ink that reads "Allison Parker".

Allison Parker  
Environmental Specialist

Reviewed by:

A handwritten signature in black ink that reads "Todd Swenson".

Todd Swenson  
Environmental Superintendent

cc: Jeremy Fraser, Omer Pasalic, Sean Naullaq, Darren Kennedy (CIRNAC)  
Conor Goddard, Chris Spencer (QIA)  
Megan Lord-Hoyle, Lou Kamermans, Elisabeth Luther, Francois Gaudreau, William Bowden, Laurence Serra,  
Allison Parker, Irniq Lecompte, Shannon Mulhall (Baffinland)

### **Attachments**

Attachments – Table 1, Table 2, Table 3.1



**Table 1.1: Monitoring Program  
Water Sampling Summary**

Location	Location Description	Sample Date	Sample Type	Lab Sample ID
MP-01	Sewage Treatment Facility	2026-02-03	P	WT2602354-003
MP-01B	Sewage Treatment Facility	2026-02-03	P	WT2602354-001
MS-01B	Sewage Treatment Facility	2026-02-03	P	WT2602348-001

**Notes:**

Sample Types:

P - Permitted Sample

FB - Field Blank

FD - Field Duplicate

TB - Trip Blank

NST - No Sample Taken



**Table 2 : Water Quality Results for Water Licence  
Monitoring Location - MP-01**

Location Name		MP-01
Sample Date & Time		2026-02-03 12:00
ALS Laboratory Work Order		WT2602354-003
Sample Type		P
Analyte	Units	
pH, Lab	pH units	7.55
Total Suspended Solids	mg/L	< 1
Total Dissolved Solids	mg/L	857
Turbidity	NTU	0.21
Alkalinity, Total	mg/L	48
Ammonia, Total (as N)	mg/L	0.0343
Phosphorus, Nutrient	mg/L	5.7
Total Kjeldahl Nitrogen	mg/L	10.7
Fecal Coliforms	CFU/100mL	< 1
BOD	mg/L	< 2
Oil and Grease, Total	mg/L	< 5
Visible Sheen	-	No Visible Sheen

Notes:

Highlight indicate result exceeded applicable criteria.

Sample Type:

P-Permitted

FD-Field Duplicate

FB-Field Blank

TB-Trip Blank



**Table 2 : Water Quality Results for Water Licence  
Monitoring Location - MP-01B**

Location Name		MP-01B
Sample Date & Time		2026-02-03 10:50
ALS Laboratory Work Order		WT2602354-001
Sample Type		P
Analyte	Units	
pH, Lab	pH units	7.16
Total Suspended Solids	mg/L	< 1
Total Dissolved Solids	mg/L	749
Turbidity	NTU	0.12
Alkalinity, Total	mg/L	32.8
Ammonia, Total (as N)	mg/L	0.0465
Phosphorus, Nutrient	mg/L	8.95
Total Kjeldahl Nitrogen	mg/L	7.81
Fecal Coliforms	CFU/100mL	98
BOD	mg/L	< 2
Oil and Grease, Total	mg/L	< 5
Visible Sheen	-	No Visible Sheen

Notes:

Highlight indicate result exceeded applicable criteria.

Sample Type:

P-Permitted

FD-Field Duplicate

FB-Field Blank

TB-Trip Blank



**Table 2 : Water Quality Results for Water Licence  
Monitoring Location - MS-01B**

		Location Name	MS-01B
		Sample Date & Time	2026-02-03 14:30
		ALS Laboratory Work Order	WT2602348-001
		Sample Type	P
Analyte	Units	Criteria	
pH, Lab	pH units	6.0-9.5	8.06
Total Suspended Solids	mg/L	30	< 1
Total Dissolved Solids	mg/L	-	875
Turbidity	NTU	-	0.14
Alkalinity, Total	mg/L	-	136
Ammonia, Total (as N)	mg/L	4	0.0224
Phosphorus, Nutrient	mg/L	4	0.561
Total Kjeldahl Nitrogen	mg/L	-	6.47
Fecal Coliforms	CFU/100mL	1000	23
BOD	mg/L	30	< 2
Oil and Grease, Total	mg/L	-	< 5
Visible Sheen	-	No Visible Sheen	No Visible Sheen

Notes:

Highlight indicate result exceeded applicable criteria.

Sample Type:

P-Permitted

FD-Field Duplicate

FB-Field Blank

TB-Trip Blank

Table 3.1: Flow and Volume Measurements - Part I Item 11 - February 2026

DATE	Camp Lake Freshwater for Domestic Use - Daily Water MS-MRY-1 (m <sup>3</sup> ) <sup>1</sup>	Camp Lake Freshwater for Industrial Use - Daily Water MS-MRY-1 (m <sup>3</sup> ) <sup>1</sup>	Treated Sewage Effluent from MS-01 to Discharge Location #1 (m <sup>3</sup> )	Treated Sewage Effluent from MS-01B to Discharge Location #1 (m <sup>3</sup> )	Sewage Sludge Removed from Mine Site WWTPs to Incinerator or Disposal Offsite by Backhaul (m <sup>3</sup> )	Sewage Sludge/Off-Spec Effluent Removed from Mine Site WWTPs to PWSP at Mine Site (m <sup>3</sup> )	Sewage Sludge Removed from Lift Stations to PWSP at Mine Site (m <sup>3</sup> )	Km 32 Lake Milne Port Camp Daily Water Use for Domestic Purposes MP-MRY-3 (m <sup>3</sup> )	Km 32 Lake Milne Port Camp Daily Water Use for Industrial Purposes MP-MRY-3 (m <sup>3</sup> )	Treated Sewage Effluent from MP-01 to Milne Inlet (m <sup>3</sup> )	Treated Sewage Effluent from MP-01B to Milne Inlet (m <sup>3</sup> )	Sewage Sludge Removed from Milne Port WWTPs to Incinerator or Disposal Offsite by Backhaul (m <sup>3</sup> )	Sewage Sludge Removed from Lift Stations to PWSP at Milne Port (m <sup>3</sup> )	Sludge Removed from Milne Port WWTPs/WTPs to PWSP at Milne Port (m <sup>3</sup> )
1-Feb-26	101.0	51.6	0.0	85.9	0.2	0.0	0.0	38.2	1.0	19.0	19.3	0.0	0.0	1.0
2-Feb-26	102.0	0.0	0.0	101.4	0.2	0.0	0.0	43.1	1.0	22.0	4.4	0.1	0.0	0.0
3-Feb-26	90.4	6.3	0.0	96.1	0.2	0.0	0.0	29.4	0.0	18.0	36.0	0.1	0.0	0.0
4-Feb-26	105.1	0.0	0.0	98.7	0.2	0.0	0.0	36.4	0.0	19.0	25.4	0.1	0.0	0.0
5-Feb-26	79.7	6.0	0.0	89.7	0.2	0.0	0.0	47.0	2.0	21.0	0.0	0.2	0.0	0.0
6-Feb-26	79.2	7.3	0.0	98.3	0.2	0.0	0.0	41.5	0.0	18.0	13.1	0.2	0.0	0.0
7-Feb-26	72.4	12.7	0.0	96.0	0.2	0.0	0.0	40.6	0.0	19.0	16.9	0.1	1.5	0.0
8-Feb-26	86.6	69.2	0.0	85.5	0.1	0.0	0.0	39.8	0.0	20.0	18.9	0.1	1.5	0.0
9-Feb-26	94.0	115.7	0.0	75.2	0.2	0.0	0.0	38.4	0.0	23.0	12.2	0.0	1.5	0.0
10-Feb-26	96.0	59.4	0.0	93.9	0.2	0.0	0.0	37.0	0.0	19.0	19.8	0.1	1.5	0.0
11-Feb-26	97.4	104.2	0.0	94.7	0.4	0.0	0.0	45.2	0.0	20.0	16.6	0.0	11.0	0.0
12-Feb-26	91.3	0.0	0.0	111.8	0.2	0.0	0.0	41.2	0.0	18.0	0.0	0.0	15.0	0.0
13-Feb-26	106.4	0.0	0.0	101.2	0.2	0.0	0.0	12.3	0.0	14.0	0.0	0.1	5.0	0.0
14-Feb-26	94.6	0.0	0.0	106.2	0.2	0.0	0.0	50.3	0.0	15.0	0.0	0.1	0.0	0.0
15-Feb-26	109.9	13.6	0.0	101.3	0.2	0.0	0.0	50.3	0.0	31.0	0.0	0.0	0.0	0.0
16-Feb-26	72.7	149.5	0.0	109.6	0.2	0.0	0.0	29.6	0.0	40.0	0.0	0.1	0.0	0.0
17-Feb-26	103.3	35.1	0.0	98.7	0.2	0.0	0.0	29.3	0.0	38.0	0.0	0.1	0.0	0.0
18-Feb-26	85.4	56.5	0.0	94.1	0.2	0.0	0.0	39.1	0.0	41.0	0.0	0.1	0.0	0.0
19-Feb-26	80.8	54.6	0.0	90.0	0.2	0.0	0.0	41.2	0.0	39.0	0.0	0.1	0.0	0.0
20-Feb-26	88.2	0.0	0.0	99.5	0.2	0.0	0.0	26.9	0.0	35.0	0.0	0.1	0.0	0.0
21-Feb-26	93.2	0.0	0.0	102.4	0.1	0.0	0.0	24.2	0.0	30.0	0.0	0.0	0.0	0.0
22-Feb-26	93.2	64.3	0.0	89.1	0.2	0.0	0.0	87.4	0.0	39.0	0.0	0.1	0.0	0.0
23-Feb-26	79.9	41.4	0.0	99.8	0.2	0.0	0.0	47.8	0.0	46.0	0.0	0.1	0.0	0.0
24-Feb-26	94.2	79.3	0.0	90.7	0.2	0.0	0.0	49.5	0.0	41.0	0.0	0.1	0.0	0.0
25-Feb-26	98.4	107.0	0.0	96.4	0.2	0.0	0.0	37.1	0.0	41.0	0.0	0.1	0.0	0.0
26-Feb-26	99.2	77.7	0.0	91.1	0.2	0.0	0.0	20.5	0.0	42.0	0.0	0.1	0.0	0.0
27-Feb-26	103.3	48.3	0.0	105.1	0.2	0.0	0.0	34.0	0.0	41.0	0.0	0.0	0.0	0.0
28-Feb-26	121.0	38.7	0.0	113.4	0.2	0.0	0.0	66.2	0.0	30.0	0.0	0.1	0.0	0.0
<b>Total</b>	<b>2,618.7</b>	<b>1,198.0</b>	<b>0.0</b>	<b>2,715.8</b>	<b>6.6</b>	<b>0.0</b>	<b>0.0</b>	<b>1,123.4</b>	<b>4.0</b>	<b>799.0</b>	<b>182.3</b>	<b>1.9</b>	<b>37.0</b>	<b>1.0</b>

**Notes:**

WWTP - Waste Water Treatment Plant

PWSP - Polishing Waste Stabilization Pond

<sup>1</sup> Tracking may be influenced by reported data to the Pi data system; variances between reported domestic and industrial values have potential to occur. However, total daily withdrawal is not influenced by the tracking methodology.