

From: [Wilson, Anne \[Yel\]](#)
To: licensing@nunavutwaterboard.org
Cc: [Spavor, Carrie \[Iqa\]](#); [Lambert, Stacey \[Yel\]](#)
Subject: Modification for Sewage Disposal Facility at the Boston Camp
Date: Wednesday, April 22, 2009 3:10:02 PM

Hi Phyllis,

I've reviewed the proposed modifications for the new sewage treatment system, and have spoken with Chris Hanks for clarification on the system performance as well as sludge disposal. It is my understanding that the system will be comparable to the Doris North one in effluent quality, and will continue to discharge overland into Spider Lake. Sludge will be taken to Doris camp for incineration.

Accordingly, EC as not identified any concerns with the proposed modifications, and commends the proponent for installing the new system, as it will enhance treatment considerably.

Thanks,
Anne

*Anne Wilson
Water Pollution Specialist
Environmental Protection Operations, EC
Nova Coast Plaza 4th Floor
P.O. Box 2310
5019-52 Street
Yellowknife, NT X1A 2P7
Ph. 867-669-4735
Fax 867-873-8185*