



145 King Street East, Suite 400  
Toronto, Ontario M5C 2Y7  
416-947-1212

**Sent by Email**

**July 24, 2025**

Licensing  
Nunavut Water Board  
P.O. Box 119  
Gjoa Haven, NU  
X0B 1J0

**Re: June 2025 – Monthly Monitoring Report for Water Licence 2BB-BOS1727**

---

This report is comprised of monitoring requirements as set out in Part J of water license 2BB-BOS1727. Boston Camp is used to support surface exploration programs.

Boston camp was closed on the 31st of August 2022 and will possibly be reopened in 2025 for planned exploration programs.

**Part J Item 2: Water Use Volumes**

No water was used as the camp was not operational.

**Part J Item 3: Mine water Discharge Volumes**

Mine water was not pumped from underground during this period.

**Part J Items 4 and 5: Sewage Disposal Facility Daily Effluent Discharge and Sewage Sludge**

Effluent was not discharged at BOS-3 and no sludge was removed from the sewage disposal facility as the camp was not operational.

**Part J Items 5: Daily Quantities of Effluent Discharged – Containment Pond, Bulk Fuel Storage, Landfarm and Portal Decline**

No water was discharged from the Containment Pond (BOS-2), Bulk Fuel Storage Facility (BOS-5), the Landfarm (BOS-6) or the Portal Decline (BOS-9).

The water was tested in BOS-2, BOS-5, and BOS-9 on 23 June 2025, and the results are reported in Appendix C (attached). The water in BOS-2 and BOS-9 passed on all parameters, but the water in BOS-5 exceeded in Arsenic and Lead. The water in BOS-2 and BOS-9 will be discharged to the tundra as per the water license Part D Item 8. The water in BOS-5 will be re-tested at the earliest convenience.

**Part J Items 6 and 7: Water Source and Waste Disposal Coordinates**

GPS coordinates of locations of water sources and waste associated with camp and drilling activities are kept on file. No water sources were utilized to support domestic water use or drilling activities this month.

**Part J Items 8, 11 and 12 (also Part D Items 6, 17 and 19): Sampling at Containment Pond, Bulk Fuel Storage, Landfarm and Portal Decline**

No samples for the Containment Pond (BOS-2), Bulk Fuel Storage Facility (BOS-5), the Landfarm facility (BOS-6) or the Portal Decline (BOS-9) were taken this month.

**Part J Item 9: Sewage Disposal Facility Effluent**

No samples were taken at monitoring station BOS-3 as the camp was not operational. No samples were taken at monitoring station BOS-4 as there was no discharge from the Sewage Disposal Facility this month.

**Part J Item 11: Seepage Monitoring**

Seepage at Boston (BOS-8) is monitored seasonally when water is available to sample. Seepage was not observed during the month.

**Part J Item 14 (also Part F Item 7): Under-Ice Water Quality Sampling**

Not applicable as on-ice drilling did not occur pertaining to license 2BB-BOS1727.

**Incident Reporting**

No spills were reported during the month.

Should there be any questions regarding this monthly report, please contact me at [jason.inkster@agnicoeagle.com](mailto:jason.inkster@agnicoeagle.com)

Yours sincerely,



Jason Inkster – Supervisor, Environment  
Hope Bay Project  
(819) 759-3555 ext. 4600101

Cc:

Jonathan Mesher, Water Resources Officer, CIRNAC  
Marc-Olivier Vachon, General Manager – Hope Bay, Agnico Eagle  
Cyril Jenkins, Environment Superintendent – Hope Bay, Agnico Eagle  
Guy Dufour, Environment General Supervisor – Hope Bay, Agnico Eagle

Figure 1. 2BB-BOS1727 SNP Monitoring Locations

