



P.O. BOX 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓂᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYINGI
OFFICE DES EAUX DU NUNAVUT

File No.: **2BB-BOS0712**

August 7, 2009

To: Hope Bay Mining Limited
Cc: Kitikmeot Distribution

RE: Licence 2BB-BOS0712, Boston Advanced Exploration Project

NOTICE OF ERRATA

Part B, Item 21 incorrectly identified the effluent quality standards, units of measure as milligrams per litre where it should have been in micrograms per litre. The following indicates the correct units of measure for the parameters indicated.

PART B CONDITIONS APPLYING TO WASTE DISPOSAL

21. All effluent being discharged from the Bulk Fuel Storage Facilities, and the Landfarm at Monitoring Stations BOS-5 and BOS-6 respectively, shall not exceed the following effluent quality standards:

Parameter	Maximum Concentration of Any Grab Sample (ug/L)
Benzene	370
Toluene	2
Ethylbenzene	90
Lead	1
Oil & Grease	15,000 and no visible sheen

Original signed by:

Phyllis Beaulieu
Manager of Licensing
Nunavut Water Board