



P.O. Box 119
GJOA HAVEN, NU X0B 1J0
TEL: (867) 360-6338
FAX: (867) 360-6369

ᓄᓇᓂᓪ ᐃᓕᓕᓂᓪ ᑲᑎᓕᓪ
NUNAVUT WATER BOARD
NUNAVUT IMALIRIYIN KATIMAYIT
OFFICE DES EAUX DU NUNAVUT

File No.: **2BB-BOS1217**

August 28, 2012

To: Kitikmeot Distribution

RE: **Licence 2BB-BOS1217, Boston Advanced Exploration Project**

NOTICE OF ERRATA

PART D CONDITIONS APPLYING TO WASTE DISPOSAL

Part D, Item 9, the Effluent quality table, omitted the values for parameters pH and Oil and Grease under the Maximum Average Concentration (mg/L) column. The following table indicates the corrected criteria.

Parameter	Maximum Average Concentration (mg/L)	Maximum Concentration of any Grab Sample (mg/L)
Total Arsenic	0.5	1.00
Total Copper	0.30	0.60
Total Lead	0.20	0.40
Total Nickel	0.50	1.00
Total Zinc	0.50	1.00
Total Suspended Solids	25	50
Oil and Grease	No visible sheen	No visible sheen
pH	6.0-9.5	6.0-9.5

Part D, Item 12 indicated a distance of thirty (30) metres. The correct distance is thirty one (31) metres. This condition is corrected to read:

The Licensee shall dispose of sludge removed from the Sewage Disposal Facility in a sump located a minimum of thirty one (31) meters from the normal high water mark and such that they do not enter any water body, or as otherwise approved by the Board in writing under Part D, Item 13.

Part D, Item 19, Effluent quality table, indicated an incorrect value (15.0) based on the units in the column heading. The Licence shall be corrected with the value as indicated in the following table.

Parameter	Maximum Allowable Grab Sample Concentration (ug/L)
Benzene	370
Toluene	2
Ethylbenzene	90
Lead	1
Oil & Grease	15,000 and no visible sheen

Original signed by:

Phyllis Beaulieu
Manager of Licensing
Nunavut Water Board