



NWB Tools

Phyllis Beaulieu <phyllis.beaulieu@nwb-oen.ca>

Re: question licence 2BE-MEA1318

1 message

Karén Kharatyan <karen.kharatyan@nwb-oen.ca>

Wed, Dec 4, 2013 at 6:37 AM

To: david.frenette@agnicoeagle.com

Cc: Christine.Wilson@aandc-aadnc.gc.ca, Phyllis Beaulieu <phyllis.beaulieu@nwb-oen.ca>, Robin Ikkutisluk <robin.ikkutisluk@nwb-oen.ca>

Find please below my reply sent on November 19, 2013.



Karén Kharatyan, Ph. D- ԵՂԵՐԵՐ ԵՄԵՐԻԿԱՆԵՐԸ

Technical Advisor- Conseiller technique

ᐱᓗᑦᓴᓂᓇ ᓄᓔᑐᓕᓂᓂᓃᒃᑦ Δᓖᓚᓂ- Piluaqnaqtuliginigmun Ikayuqti

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
 ᓄᓇᓂᓪ ᓄᓄᓄᓂᓪ ᓄᓄᓄᓂᓪ - NUNAVUT IMALIRIYIN KATIMAYINGI
www.NunavutWaterBoard.org

P.O. Box 119
Gjoa Haven, NU, X0B 1J0

C.P. 119
Gjoa Haven (Nunavut), X0B 1J0

በበኛው 119
ጥቅም, ጥቅም X0B 1J0

Titigaqavua 119
Uqhuqtuuq, NU, X0B 1J0

Tel / Téléphone / ᐅᐅᐅᐅ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᐅᐅᐅᐅ / Fax-kut: (867) 360-6369

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(s) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courriel électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



On Tue, Nov 19, 2013 at 12:19 AM, Karén Kharatyan <karen.kharatyan@nwb-oen.ca> wrote:

Hi David,

The Licence 2BE-MEA0813 doesn't specify the number of fuel caches and actual volume of fuel of fuel cache. If the addition means a construction/installation of a bulk fuel station involving many hundred thousands or more L it could require a Board approval through an amendment. However, I believe an additional 50000 L cache is not that case and wouldn't require construction/installation of a bulk fuel station, and may be considered as a non major modification without an amendment to the licence.

I hope it helps,
Karen



Karén Kharatyan, Ph. D- ԵՄԻԱԿԱՆ ԲՏՈՒՆՔ

Technical Advisor- Conseiller technique

ᐱᓗᑦᑐᑦ ᐅᑕᐱᓂᑦᑭᑦ ᐃᑲᑦᑎ- Piliuaqnaqtuliginigmun Ikayuqti

NUNAVUT WATER BOARD - OFFICE DES EAUX DU NUNAVUT
ᓄᓇᓐ ᓄᓕᓕᓐ ᓅᓂᓄᓐᓴᓐ - NUNAVUT IMALIRIYIN KATIMAYINGI
www.NunavutWaterBoard.org

P.O. Box 119
Gjoa Haven, NU, X0B 1J0

C.P. 119
Gjoa Haven (Nunavut), X0B 1J0

၂၀၁၆ ခုနှစ် ၁၁၉
 ၁၁၆၆, ၁၁၆၆ X0B 1J0

Titigaaqvia 119
Uqhuqtuaq, NU, X0B 1J0

Tel / Téléphone / ᐃᑭᐃᑦ / Hivayauta: (867) 360-6338 | Fax / Télécopieur / ᐃᑭᐃᑦ / Fax-kut: (867) 360-6369

WARNING - This communication, including any attachments contains confidential information intended only for the addressee(s) noted above. Any unauthorized distribution, copying, or disclosure is strictly prohibited. If you have received this by mistake, please notify the sender immediately and delete this message without printing or copying it. Thank you.

AVIS DE CONFIDENTIALITÉ - Ce message, et toute(s) pièce(s) jointe(s) est confidentiel et est à l'usage exclusif du(es) destinataire(s) ci-dessus. Toute autre personne est par la présente avisée qu'il lui est strictement interdit de le diffuser, le distribuer ou le reproduire. Si le destinataire ne peut être joint ou vous est inconnu, veuillez informer l'expéditeur par courriel électronique immédiatement et détruire ce message et toute copie de celui-ci. Merci pour votre collaboration.



On Mon, Nov 18, 2013 at 3:20 PM, Robin Ikkutisluk <robin.ikkutisluk@nwb-oen.ca> wrote:
Hi Karen,

Please see correspondence between AANDC and Agnico Eagle regarding the Meadowbank file 2BE-MEA1318.

Regards,
Robin Ikkutisluk
Licence Administrator Assistant
Nunavut Water Board

Forwarded conversation

Subject: **Fwd: question licence 2BE-MEA1318**

From: **Christine Wilson** <Christine.Wilson@aandc-aadnc.gc.ca>
Date: Mon, Nov 18, 2013 at 2:20 PM
To: robin.ikkutisluk@nunavutwaterboard.org

hey can you forward this email over to who ever is working on this file. Thanks!!

Chris

----- Forwarded message -----

From: David Frenette <david.frenette@agnicoeagle.com>
To: "Christine Wilson (Christine.Wilson@aandc-aadnc.gc.ca)" <Christine.Wilson@aandc-aadnc.gc.ca>
Cc:
Date: Mon, 18 Nov 2013 13:40:40 -0500
Subject: question licence 2BE-MEA1318

Hello Christine,

I have a question for you, related to the licence 2BE-MEA1318. We will have to install a new fuel deposit for the exploration in the north side of our property (IVR area). Do I have to request an amendment to the licence to install this deposit? In the part H3 of the licence, the requirement related to a fuel cache are written. How many fuel you can stock in an area and consider that a cache? If we talk of 50 000 liters?

3. The Licensee shall prevent any chemicals, petroleum products or wastes associated with the project from entering Water. All sumps and fuel caches shall be located at a distance of at least thirty one (31) metres from the ordinary High Water Mark of any adjacent water body and inspected on a regular basis. An exception to this condition is provided for in Part H, Item 4.

David Frenette
Coordonnateur environnement

david.frenette@agnicoeagle.com

T: [819.874.5980](tel:819.874.5980) x3622

Agnico Eagle Mines Limited
765, chemin de la mine Goldex

Val-d'Or, QC, Canada
J9P 4N9

agnicoeagle.com



AGNICO EAGLE



From: **Christine Wilson** <Christine.Wilson@aandc-aadnc.gc.ca>
Date: Mon, Nov 18, 2013 at 2:32 PM
To: David Frenette <david.frenette@agnicoeagle.com>
Cc: Robin Ikkutisluuk <robin.ikkutisluuk@nunavutwaterboard.org>

Hi David,

Two questions

What is the IVR area ?

Will AEM continue to use the fuel tanks onsite or replacing/ modifying them?

Will the fuel storage area become larger?

What type of fuel storage barrells, tanks, bladders?

There is section in the license which allows for small changes referred to a modifications. These changes must be improvements which do not change the scoop of the license. I have forwarded your emails off to a Tech at NWB and hopefully your will be able to clarify theses questions I asked before they respond to your questions below.

Regards,

Christine Wilson

Water Resource Officer- Kivalliq Region

Field Operations Unit

Aboriginal Affairs and Northern Development Canada

Nunavut Regional Office

P.O. Box 100

Iqaluit, Nunavut X0A 0H0

Ph: [867-975-4296](tel:867-975-4296)

Fx: [867-979-6445](tel:867-979-6445)

>>> David Frenette <david.frenette@agnicoeagle.com> 11/18/2013 1:40 PM >>>

Hello Christine,

I have a question for you, related to the licence 2BE-MEA1318. We will have to install a new fuel deposit for the exploration in the north side of our property (IVR area). Do I have to request an amendment to the licence to install this deposit? In the part H3 of the licence, the requirement related to a fuel cache are written. How many fuel you can stock in an area and consider that a cache? If we talk of 50 000 liters?

3. The Licensee shall prevent any chemicals, petroleum products or wastes associated with the project from entering Water. All sumps and fuel caches shall be located at a distance of at least thirty one (31) metres from the ordinary High Water Mark of any adjacent water body and inspected on a regular basis. An exception to this condition is provided for in Part H, Item 4.

David Frenette
Coordonnateur environnement

david.frenette@agnicoeagle.com

T: [819.874.5980](tel:819.874.5980) x3622

Agnico Eagle Mines Limited
765, chemin de la mine Goldex
Val-d'Or, QC, Canada
J9P 4N9

agnicoeagle.com



AGNICO EAGLE

