



NWB Tools

Richard Dwyer &lt;richard.dwyer@nwb-oen.ca&gt;

---

**Fw: [EXTERNAL] Re: 2BB-MEA1318 10 days notice for the pumping of water from the Newterra system**

---

**Karén Kharatyan** <karen.kharatyan@nwb-oen.ca>  
To: Richard Dwyer <richard.dwyer@nwb-oen.ca>

Thu, Mar 8, 2018 at 11:22 AM

For our records.

[Sent from my BlackBerry 10 smartphone on the Bell network.](#)

---

**From:** Wilson3, Christine (AADNC/AANDC) <[christine.wilson3@canada.ca](mailto:christine.wilson3@canada.ca)>  
**Sent:** Thursday, March 8, 2018 1:08 PM  
**To:** Isabelle Couture  
**Cc:** Martin Archambault; Robin Allard; Nancy Duquet Harvey; Didham, Curtis (EC); Karen Kharatyan  
**Subject:** Re: [EXTERNAL] Re: 2BB-MEA1318 10 days notice for the pumping of water from the Newterra system

---

Hi Isabelle,

I realize that the water licence only requires analysis for specific parameters but AEM is still obligated to confirm that the effluent is not considered a waste. I noted that you did not sample for any other parameters often associated with sewage effluent. I will be taking this into consideration during my next inspection and recommend a suite of samples to be taken to confirm the quality of the effluent.

To commission the STP means to bring the unit into working order, not just meet the criteria in a water licence.

If you have any questions about my comments above please feel free to contact me directly.

Regards,

Christine

---

**From:** Isabelle Couture <[isabelle.couture@agnicoeagle.com](mailto:isabelle.couture@agnicoeagle.com)>  
**Sent:** Thursday, March 8, 2018 8:31 AM  
**To:** Wilson3, Christine (AADNC/AANDC)  
**Cc:** Martin Archambault; Robin Allard; Nancy Duquet Harvey  
**Subject:** RE: [EXTERNAL] Re: 2BB-MEA1318 10 days notice for the pumping of water from the Newterra system

Good morning,

Please find attached the lab analysis reports for the samples collected.

Should you have any questions, do not hesitate to contact us.

Thanks,

**Isabelle Couture**  
**Compliance Technician**

[isabelle.couture@agnicoeagle.com](mailto:isabelle.couture@agnicoeagle.com)

T: [819.759.3555](tel:819.759.3555) x8061

Agnico Eagle Mines Limited  
Meadowbank Division  
Baker Lake, Nunavut, Canada  
X0C 0A0

[agnicoeagle.com](http://agnicoeagle.com)



**AGNICO EAGLE**



---

**From:** Wilson3, Christine (AADNC/AANDC) [<mailto:christine.wilson3@canada.ca>]

**Sent:** Wednesday, March 07, 2018 7:30 AM

**To:** Isabelle Couture

**Cc:** Martin Archambault; Robin Allard; Nancy Duquet Harvey

**Subject:** [EXTERNAL] Re: 2BB-MEA1318 10 days notice for the pumping of water from the Newterra system

Good Morning,

Notice Received.

Please send me a copy of the lab analysis report for the samples collected.

Thank you,

Christine

Sent from my BlackBerry 10 smartphone on the Bell network.

---

**From:** Isabelle Couture

**Sent:** Tuesday, March 6, 2018 11:18 AM

**To:** Wilson3, Christine (AADNC/AANDC)

**Cc:** Martin Archambault; Robin Allard; Nancy Duquet Harvey

**Subject:** FW: 2BB-MEA1318 10 days notice for the pumping of water from the Newterra system

Ms. Wilson,

As per Water Licence 2BB-MEA1318 Part D Item 17, please consider this as the 10 days notice to advise you that we will be commencing the water pumping from the membrane bioreactor wastewater treatment system (Monitoring Station MEA-2) to the tundra.

An estimated total of 20 m<sup>3</sup>/day will be pumped. To avoid erosion, the water will be directed in a natural boulder field located near the Newterra system, where direct flow into a water body is not possible. The discharge will occur only if the water meet the discharge criteria in accordance with Part D, Item 14 of the NWB Water Licence. Samples have been collected and work is scheduled to begin once we received the analyses results, as long as the results meet the discharge criteria.

Should you have any questions, please do not hesitate to contact us.

Best regards,

**Isabelle Couture**  
**Compliance Technician**

[isabelle.couture@agnicoeagle.com](mailto:isabelle.couture@agnicoeagle.com)

T: 819.759.3555 x8061

Agnico Eagle Mines Limited  
Meadowbank Division  
Baker Lake, Nunavut, Canada  
X0C 0A0

[agnicoeagle.com](http://agnicoeagle.com)



**AGNICO EAGLE**

