



Meliadine Gold Project
NWB 2BB-MEL1424
October 2020 Monthly Report

Prepared for:
Nunavut Water Board

Prepared by:
Agnico Eagle Mines Limited – Meliadine Division

November 30th, 2020

This monthly report is delivered under water license 2BB-MEL1424, PART J, Item 13.

1. The Licensee shall maintain Monitoring Stations at the following locations:

Table 1: Monitoring stations

Monitoring Station	Description	Status
MEL-1	Raw water supply intake at Meliadine Lake	Active (Volume m ³)
MEL-2	Raw water supply intake at Pump, A8 or other Lakes	Active (Volume m ³)
MEL-5	Point of discharge for the Bermed Fuel Containment Facilities	Inactive
MEL-6	Effluent from the Landfarm Treatment Facility prior to release	Inactive
MEL-7	Final Effluent Discharge from the BIODISK treatment system	Active (no direct discharge)
MEL-8	Point of discharge or runoff from the Non-Hazardous Waste landfill	Inactive

2. The Licensee shall measure and record, in cubic metres, the daily quantities of water utilized for camp, drilling and other purposes from all sources.

Table 2: Water quantities utilized (average)

MEL-1 ¹	Camp	m ³ /day	16.03
	Pump Shack	m ³ /day	0.00
	Construction	m ³ /day	0.00
MEL-2 (A8) ²	Underground	m ³ /day	0.00
	Drilling	m ³ /day	0.00
Not MEL-1 or MEL-2	Drilling	m ³ /day	38.03
Daily Average		m ³ /day	54.07
Total October 2020		m ³	1,676.06
Total 2020		m ³	15,269.09

3. The Licensee shall measure and record the volume of all soil from all locations entering the Landfarm Treatment Facility.

In October 2020, no material was deposited in the Type B landfarm. Any new contaminated soil generated will be deposited in the landfarm approved in the Type A Water License.

¹ MEL-1: 541943E, 6989174N

² MEL-2 (A8): 540076E, 6987731N

- 4. The Licensee shall assess and record the concentration of F1 – F4 fractions in petroleum hydrocarbon contaminated soil, according to the CCME Canada-Wide Standard for Petroleum Hydrocarbons (PHC) in Soil that is entering the Land Treatment Unit from all sources and excavations.**

No material was removed in October 2020.

- 5. The Licensee shall provide the GPS coordinates (in decimal degrees) of all locations where wastes associated with camp operations and exploration activities are deposited.**

No more waste from camp operations and exploration is deposited in locations related to Licence 2BB-MEL1424.

- 6. Licensee shall sample at Monitoring Program Station MEL-7, monthly during wastewater effluent discharge. Samples shall be analyzed for the parameters listed under Part D Item 11:**

pH

Biochemical Oxygen Demand – BOD5

Total Suspended Solids (TSS)

Fecal Coliforms

Oil and Grease (and visual)

From November 2017 to April 2019, all treated sewage from the Exploration Camp STP was trucked and deposited in CP1. From April 15th 2019 to early June 2019, due to inconsistency in the amount of people at the exploration camp resulting in unsteady STP effluent results, AEM decided to transfer all treated water from the exploration STP to the main camp STP for a second treatment before being discharged in CP-1. Since early June 2019, the treated sewage from the exploration camp is deposited in CP-1 as sampling results went back to normal.

If the Exploration Camp STP operators suspect any upsets in the Exploration Camp STP prior to receiving accredited lab results, the effluent will be placed in the arctic corridor lift station for additional treatment in the main camp sewage treatment plant.

Agnico continued to monitor the quality of the effluent; 4 samples were collected during the month. The summary of the results is provided in the following Table 3.

Table 3: Effluent testing results at STP-FINAL (MEL-7) sampling station, October 2020

MEL-7		Sample date	10/5/2020	10/12/2020	10/19/2020	10/26/2020
Parameter	Unit					
WQ02- Conventional Parameters						
pH	pH units		7.41	7.65	7.48	7.01
Specific conductivity	umhos/cm		540	590	510	560
Total alkalinity, as CaCO3	mg/L		120	130	66	80
Total suspended solids	mg/L		5	3	6	9
Volatile TSS	mg/L		5	3	6	8
WQ04- Nutrients and Chlorophyll a						
Biochemical Oxygen Demand, 5 Day	mg/L		7	5	6	12
Chemical oxygen demand	mg/L		65	73	66	85
Nitrate	mg/L		5.44	3.82	10.7	11.2
Nitrate + nitrite	mg/L		5.69	4.06	11.1	11.4
Nitrite	mg/L		0.255	0.247	0.469	0.172
Total ammonia	mg/L		20	23	12	13
Total Kjeldahl nitrogen	mg/L		23	25	13	17
Total phosphorus	mg/L		7.9	8.6	7.9	7.8
WQ05- General Organics						
Total oil and grease	mg/L		1.1	1.8	0.8	1
WQ13- Coliforms						
Aerobic heterotrophic bacteria	CFU/mL		1410	1545	1364	760
Atypical colonies	CFU/100mL		270	540	270	500
Escherichia coli	CFU/100mL		< 0	< 0	< 0	< 0
Fecal Coliform	CFU/100mL		< 0	2	2	< 0
Total Coliform	CFU/100mL		< 0	460	290	110

- 7. The Licensee shall, prior to the release of effluent from the Bermed Fuel Containment Facilities at Monitoring Program Station MEL-5 and the Landfarm Treatment Facility at Monitoring Program Station MEL-6 for the purpose of demonstrating compliance, sample for the parameters listed under Part D item 15.**

In October 2020, no water was discharged from the Fuel Containment Facilities (Monitoring station MEL-5) nor the Landfarm Treatment Facility (Monitoring Station MEL-6).

- 8. The Licensee shall obtain representative samples of the water column below any ice where required under part F, Items 5 and 6. Monitoring shall include but not limited to the following:**

Total Suspended Solids

***pH
Electrical Conductivity, and
Total trace Metals as determined by a standard ICP Scan (to include at a minimum,
the following elements: Al, Sb, Ba, Be, Cd, Cr, Co, Cu, Fe, Pb, Li, Mn, Mo, Ni, Se, Sn,
Sr, Tl, Ti, U, V, Zn), and Trace Arsenic and Mercury.***

On-ice drilling was conducted in March and April 2019; samples are collected before, during and after drilling and sent for analysis. The complete set of analyses results was submitted with the May 2019 report.

9. Modify the monthly monitoring reports, starting April 2016, to include, at a minimum, waste water treatment options; and modifications of the freshet action plan.

From November 2017 to April 2019, all treated sewage from the Exploration Camp STP was trucked and deposited in CP1. From April 15th 2019 to June 2019, due to inconsistency in the amount of people at the exploration camp resulting in unsteady STP effluent results, AEM decided to transfer all treated water from the exploration STP to the main camp STP for a second treatment before being discharged in CP-1. Since early June 2019, the treated sewage from the exploration camp is deposited in CP-1 as sampling results went back to normal.