

## Richard Dwyer

---

**From:** Jim Millard [jim.millard@baffinland.com]  
**Sent:** Tuesday, May 31, 2011 7:38 AM  
**To:** Ian Rumbolt  
**Cc:** David Hohnstein; Richard Dwyer; Salamonie Shoo  
**Subject:** Re: Discharge of snow melt and stormwater from lined storage facilities at Milne Inlet Camp - Notification

**Follow Up Flag:** Follow up  
**Flag Status:** Flagged

Hi Ian. To this end we will be taking a series of verification samples where we will be treating the water and recirculating/discharging back to the containment facility. We will do field testing and external lab analyses on samples collected during the recirculating process. We will send the results to you and Salamonie prior to discharge to the receiving environment. I trust this addresses the concerns you have. If not please contact me and we can discuss further.

Jim. 902-403-1337

Sent from my BlackBerry device

---

**From:** "Ian Rumbolt" <[Ian.Rumbolt@inac-ainc.gc.ca](mailto:Ian.Rumbolt@inac-ainc.gc.ca)>  
**Date:** Tue, 31 May 2011 08:49:36 -0400  
**To:** Jim Millard<[Jim.Millard@Baffinland.com](mailto:Jim.Millard@Baffinland.com)>  
**Cc:** 'David Hohnstein'<[dts@nunavutwaterboard.org](mailto:dts@nunavutwaterboard.org)>; Richard Dwyer<[licensingadmin@nunavutwaterboard.org](mailto:licensingadmin@nunavutwaterboard.org)>; 'Salamonie Shoo'<[landadmin@gja.ca](mailto:landadmin@gja.ca)>  
**Subject:** Re: Discharge of snow melt and stormwater from lined storage facilities at Milne Inlet Camp - Notification

Good Morning Jim,

I would like you to take at least one set of samples prior to the treatment of the stormwater to determine if the system you will be using onsite is working properly. All other sampling in the program provided seems satisfactory.

Regards,

Ian Rumbolt  
Water Resource Officer  
Indian and Northern Affairs Canada  
P.O. Box 100  
Iqaluit, Nunavut  
X0A 0H0

Tele: (867) 975-4548  
Fax: (867) 979-6445  
[Ian.Rumbolt@inac-ainc.gc.ca](mailto:Ian.Rumbolt@inac-ainc.gc.ca)

### CONFIDENTIALITY WARNING:

This e-mail message and attachments may contain privileged and confidential information. If you have received this message in error, please immediately notify the sender and delete this e-mail message.

>>> "Jim Millard" <[Jim.Millard@Baffinland.com](mailto:Jim.Millard@Baffinland.com)> 5/29/2011 11:18 AM >>>  
Good Day Ian,

In accordance with Part D, Section 10 of our Water Licence 2BB-MRY1114, we are notifying you of our intention to commence discharge of stormwater from the lined storage facilities at Milne Inlet Camp, specifically, the Milne Inlet Bulk Fuel Storage Facility (MRY-7). The treatment system to be utilized this year is similar to previous years, with some minor changes to piping, pumps, and additional filtration media to make the system more robust. Discharge from the lined storage facilities will be to the MRY-7 discharge ditch that reports to Milne Inlet, all in accordance with or current Site Water Management and Comprehensive Environmental Monitoring Plans. The attached memo describes the system to be used as well as the sampling and planned analytical programs to support this work.

The high intensity pre-discharge, process, and final effluent sampling that is planned and presented in the attached memo significantly exceeds the requirements of the water licence and will therefore result in a high level of protection for the receiving environment.

Please let me know if you have any questions or comments.

Kind regards,

Jim Millard, M.Sc., P.Geo.  
Senior Environmental Superintendent  
Mary River Project  
Baffinland Iron Mines Corporation  
work site tel 403-450-8843